

BICYCLE LAKE AAF, CA, USA

WMO: 746110

Lat: 35.283N

Lon: 116.633W

Elev: 248

StdP: 14.56

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 03182

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	30.6	33.8	-7.5	3.7	45.0	-3.7	4.6	45.8	39.8	50.8	34.4	47.6	4.3	310	0.520

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.4	105.7	65.6	103.1	64.6	100.5	63.7	69.0	91.1	68.0	92.2	66.8	93.0	8.9	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.7	86.0	77.8	58.8	74.8	80.0	54.7	64.1	82.8	33.2	90.2	32.3	91.8	31.4	93.5	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 33.2	27.7	24.3	DB	26.0	109.2	4.4	2.5	22.9	110.9	20.3	112.4	17.8	113.8	14.7	115.6	(4)
(5)			WB	19.3	70.8	3.4	1.4	16.8	71.8	14.9	72.7	13.0	73.5	10.5	74.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.5	50.2	53.1	59.2	65.7	70.7	83.0	88.2	87.0	80.2	68.0	56.3	48.0		
	DBStd	15.41	6.22	7.97	7.22	7.21	7.88	6.65	4.75	4.32	6.68	6.85	7.39	5.90		
	HDD50	288	77	59	11	2	0	0	0	0	0	1	27	111		
	HDD65	1966	460	336	206	78	37	1	0	0	2	45	273	528		
	CDD50	6688	82	145	296	472	643	991	1183	1148	905	560	216	47		
	CDD65	2892	0	2	26	98	215	542	718	683	457	139	12	0		
	CDH74	40511	0	16	257	1083	2616	7833	11049	10211	5958	1371	117	0		
	CDH80	23486	0	0	47	357	1171	4809	7104	6376	3201	414	7	0		
(14) Wind	WSAvg	9.2	6.6	8.8	10.5	11.6	11.6	11.0	9.7	9.1	8.7	8.0	7.3	7.5		
(15) Precipitation	PrecAvg	4.8	0.7	1.1	0.5	0.2	0.1	0.0	0.3	0.2	0.3	0.3	0.4	0.6		
	PrecMax	8.7	3.1	3.7	2.9	1.2	0.6	0.3	1.5	0.7	1.9	2.1	2.2	3.0		
	PrecMin	1.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
	PrecStd	2.4	0.9	1.1	0.7	0.3	0.2	0.1	0.4	0.2	0.5	0.5	0.5	0.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.4	76.1	84.7	92.4	97.3	109.1	109.2	106.3	101.8	91.0	80.8	68.6		
		MCWB	49.5	50.7	54.9	58.5	60.2	64.8	67.3	65.9	64.8	59.2	54.3	48.8		
	2%	DB	66.4	73.1	80.6	88.0	94.1	104.5	106.4	103.8	98.2	87.7	77.4	65.1		
		MCWB	47.6	50.0	53.5	56.7	58.9	63.6	66.2	65.2	63.6	58.2	52.2	48.2		
	5%	DB	63.4	70.1	76.5	84.0	90.5	101.4	103.8	101.4	96.0	84.5	74.1	62.2		
		MCWB	46.0	48.9	51.5	54.9	57.4	62.7	65.4	64.4	62.9	56.6	50.8	46.8		
	10%	DB	60.7	66.5	72.7	80.4	86.7	98.5	101.0	99.4	93.6	81.6	70.1	59.0		
		MCWB	44.7	47.6	50.2	53.6	56.5	61.4	64.4	63.6	61.6	55.2	49.7	44.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	53.0	56.1	56.3	59.5	61.1	66.7	70.5	70.7	68.4	64.1	55.5	53.8		
		MCDB	63.1	67.4	76.9	88.7	95.0	101.6	90.3	88.9	88.7	77.9	76.5	62.2		
	2%	WB	50.4	52.3	54.4	57.4	59.5	65.2	69.3	69.0	67.3	61.3	53.9	51.7		
		MCDB	59.0	65.4	76.0	84.3	91.7	100.9	92.1	89.8	88.7	78.0	73.7	59.8		
	5%	WB	49.1	50.1	52.8	55.8	58.2	63.9	68.3	67.8	66.1	59.2	52.3	49.8		
		MCDB	58.1	66.5	73.6	80.7	87.7	98.0	93.1	91.5	88.5	79.0	70.2	58.4		
	10%	WB	47.4	48.5	51.2	54.3	57.1	62.3	67.3	66.4	64.7	57.4	50.5	47.3		
		MCDB	57.7	64.5	69.7	77.2	84.4	95.1	94.1	93.3	87.8	77.5	67.1	55.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.1	19.0	20.5	23.0	23.8	26.2	23.4	23.5	22.6	21.9	21.0	17.8		
		MCDBR	20.9	22.2	24.2	27.0	27.0	28.5	26.4	25.1	23.9	24.2	27.2	23.0		
		MCWBR	11.4	10.5	10.2	10.8	9.6	9.0	8.8	8.8	9.0	10.9	13.7	13.5		
	5% WB	MCDBR	19.3	20.1	23.0	25.2	26.9	27.4	20.6	21.2	20.6	19.9	23.7	17.9		
		MCWBR	10.8	9.9	10.0	10.3	9.3	8.1	8.2	9.5	7.6	8.2	11.8	10.8		
(40) Clear-Sky Solar Irradiance	taub		0.289	0.299	0.311	0.349	0.365	0.361	0.397	0.383	0.356	0.326	0.292	0.290		
	taud		2.523	2.508	2.467	2.347	2.331	2.359	2.336	2.358	2.409	2.473	2.542	2.540		
	Ebn at Noon		293	302	306	296	291	291	279	282	286	287	289	285		
	Edh at Noon		25	29	33	39	40	39	40	38	35	30	25	24		
(44) All-Sky Solar Radiation	RadAvg		1009	1328	1798	2242	2531	2711	2476	2312	2007	1526	1133	908		
	RadStd		74	109	69	66	89	91	104	79	62	71	44	59		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)		+1.06	N/A	-3.53	N/A	N/A	N/A	N/A	-157	+346	+184

Nomenclature: See separate page