

STOVEPIPE WELLS 1 SW, CA, USA

WMO: 746130

Lat: 36.6020N

Lon: 117.1449W

Elev: 84

StdP: 14.65

Time Zone: -8.00 (NAP)

Period: 04-19

WBAN: 53139

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	39.3	41.9	-8.5	3.5	72.7	-3.5	4.6	69.2	19.6	58.8	16.5	56.6	2.7	N/A	0.414

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	23.2	118.9	68.6	116.7	68.2	114.5	67.6	73.4	103.8	72.3	105.2	71.1	106.0	8.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.5	88.0	90.6	59.3	75.5	95.0	55.4	65.6	89.5	36.8	103.3	35.7	104.3	34.6	106.4	78.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 16.9	14.4	12.3	DB	32.9	123.1	2.9	1.7	30.8	124.3	29.2	125.3	27.6	126.2	25.5	127.4	(4)
(5)			WB	26.4	75.8	1.5	1.9	25.3	77.2	24.4	78.3	23.6	79.4	22.5	80.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	78.1	54.8	60.5	69.2	77.4	86.2	97.3	103.4	100.6	92.2	77.7	63.8	52.9	(6)
(7)		DBStd	18.31	5.63	6.00	6.75	7.21	7.49	6.54	4.50	4.06	6.59	6.80	6.72	5.08	(7)
(8)		HDD50	51	20	2	0	0	0	0	0	0	0	0	2	27	(8)
(9)		HDD65	984	318	148	35	4	0	0	0	0	0	4	101	374	(9)
(10)		CDD50	10306	168	297	596	822	1123	1419	1654	1569	1267	858	415	118	(10)
(11)		CDD65	5764	2	23	165	376	658	969	1189	1104	817	397	64	0	(11)
(12)		CDH74	95454	15	210	1599	4585	10013	17414	22500	20335	13636	4615	530	2	(12)
(13)	CDH80	68389	1	30	562	2327	6415	13176	18037	15876	9587	2247	131	0	(13)	
(14)	Wind	WSAvg	4.8	3.3	3.9	4.7	5.9	6.2	6.1	6.0	5.5	4.8	4.2	3.4	3.4	(14)
(15)	Precipitation	PrecAvg	5.3	1.0	1.2	0.6	0.2	0.2	0.1	0.3	0.2	0.2	0.2	0.4	0.7	(15)
(16)		PrecMax	9.6	4.4	5.2	2.7	1.3	0.9	0.6	1.1	0.8	1.4	0.8	2.1	3.7	(16)
(17)		PrecMin	2.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	2.1	1.1	1.2	0.7	0.3	0.2	0.2	0.3	0.2	0.4	0.2	0.5	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.9	83.9	94.9	104.0	111.6	120.9	122.9	118.9	114.1	102.2	88.1	73.3	(19)
MCWB			51.4	54.0	58.7	62.5	64.7	68.2	70.5	69.1	67.8	64.0	57.2	51.1	(20)	
2%		DB	71.7	79.9	89.8	99.4	107.9	117.5	120.3	116.6	111.3	97.6	84.0	68.8	(21)	
		MCWB	49.4	53.2	56.9	60.4	63.0	67.3	69.5	68.6	67.5	62.6	55.8	49.9	(22)	
5%		DB	68.5	76.3	86.1	95.3	104.7	114.7	117.8	114.7	108.8	94.3	79.9	65.7	(23)	
		MCWB	48.6	51.9	55.6	59.0	61.9	66.3	68.9	68.1	66.3	60.6	53.8	48.8	(24)	
10%		DB	65.9	72.9	82.6	91.7	101.4	112.2	115.6	112.9	106.2	90.7	76.6	62.7	(25)	
		MCWB	47.8	50.6	54.4	57.8	61.2	65.3	68.3	67.2	65.2	59.0	52.4	46.8	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.2	58.4	59.7	63.8	65.2	71.2	75.2	74.9	72.9	69.4	58.7	57.8	(27)
MCD B			63.4	74.4	85.7	100.1	107.6	114.5	99.8	100.7	101.5	81.7	82.7	65.1	(28)	
2%		WB	54.5	55.6	58.2	61.8	63.8	69.4	73.9	73.3	70.9	66.7	56.9	54.8	(29)	
		MCD B	63.6	70.4	84.8	95.1	103.4	112.9	104.1	102.2	101.9	89.1	80.4	63.2	(30)	
5%		WB	52.2	54.0	56.9	60.1	62.5	68.1	72.7	72.0	69.4	63.9	55.0	52.6	(31)	
		MCD B	63.9	70.6	83.3	91.9	100.1	111.2	105.9	104.3	102.0	88.9	77.9	60.5	(32)	
10%		WB	50.0	52.4	55.4	58.7	61.5	66.4	71.5	70.7	68.0	61.8	53.1	50.2	(33)	
		MCD B	63.1	69.7	80.7	89.8	97.4	109.4	106.8	105.2	100.8	87.2	73.9	60.3	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	19.0	19.7	20.8	21.8	22.3	24.2	23.2	23.3	22.9	20.9	20.3	17.7	(35)
MCD BR			21.8	23.7	24.2	25.0	25.8	25.9	24.4	24.4	24.7	23.4	23.7	20.3	(36)	
MCWBR			10.8	10.6	9.8	9.6	9.1	8.1	7.4	7.7	8.3	9.0	11.2	9.9	(37)	
5% WB		MCD BR	18.4	20.9	22.4	22.6	24.7	23.5	21.3	21.0	20.1	18.9	22.3	14.8	(38)	
		MCWBR	9.2	9.8	9.5	9.1	8.3	7.4	6.1	6.4	6.9	7.3	10.7	7.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.282	0.293	0.303	0.340	0.357	0.349	0.376	0.367	0.342	0.310	0.286	0.282	(40)	
taud		2.586	2.563	2.521	2.400	2.391	2.423	2.419	2.419	2.483	2.566	2.592	2.596	(41)		
Ebn at Noon		294	303	307	298	293	294	285	286	290	292	290	287	(42)		
Edh at Noon		23	27	31	37	38	37	36	36	32	27	23	22	(43)		
(44)	All-Sky Solar Radiation	RadAvg	946	1262	1749	2200	2486	2728	2509	2334	1997	1487	1085	848	(44)	
(45)		RadStd	77	121	73	89	124	115	111	92	65	82	49	60	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.86	N/A	-2.54	N/A	-0.77	N/A	N/A	N/A	+239	+121

Nomenclature: See separate page