

STOVEPIPE WELLS 1 SW, CA, USA

WMO: 746130

Lat: 36.6020N

Lon: 117.1449W

Elev: 26

StdP: 101.02

Time Zone: -8.00 (NAP)

Period: 04-19

WBAN: 53139

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	4.1	5.5	-22.5	0.5	22.6	-19.7	0.7	20.7	8.7	14.9	7.4	13.7	1.2	N/A	0.414

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.9	48.3	20.3	47.0	20.1	45.9	19.8	23.0	39.9	22.4	40.7	21.7	41.1	3.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.5	12.6	32.5	15.2	10.8	35.0	13.0	9.4	32.0	67.6	39.6	65.1	40.2	62.6	41.3	25.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7.6	6.4	5.5	0.5	50.6	1.6	0.9	-0.6	51.3	-1.6	51.8	-2.5	52.4	-3.6	53.0
			-3.1	24.3	0.8	1.1	-3.7	25.1	-4.2	25.7	-4.7	26.3	-5.3	27.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.6	12.7	15.8	20.7	25.2	30.1	36.3	39.6	38.1	33.5	25.4	17.7	11.6		
	DBStd	10.17	3.13	3.34	3.75	4.01	4.16	3.63	2.50	2.26	3.66	3.78	3.73	2.82		
	HDD10.0	28	11	1	0	0	0	0	0	0	0	0	1	15		
	HDD18.3	547	177	82	19	2	0	0	0	0	0	2	56	208		
	CDD10.0	5726	93	165	331	457	624	788	919	872	704	477	231	66		
	CDD18.3	3202	1	13	92	209	366	538	661	613	454	221	36	0		
	CDH23.3	53030	8	117	888	2547	5563	9674	12500	11297	7576	2564	294	1		
(13)	CDH26.7	37994	1	17	312	1293	3564	7320	10021	8820	5326	1248	73	0		
(14)	Wind	WSAvg	2.1	1.5	1.7	2.1	2.6	2.8	2.7	2.4	2.1	1.9	1.5	1.5		
(15) Precipitation	PrecAvg	135	25	30	15	6	4	3	7	5	6	6	9	18		
	PrecMax	244	111	131	69	32	22	16	27	20	35	21	53	95		
	PrecMin	58	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	53	29	30	19	7	5	5	7	5	9	6	12	21		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.4	28.8	35.0	40.0	44.2	49.4	50.5	48.3	45.6	39.0	31.1	23.0		
		MCWB	10.8	12.2	14.8	17.0	18.2	20.1	21.4	20.6	19.9	17.8	14.0	10.6		
	2%	DB	22.1	26.6	32.1	37.4	42.2	47.5	49.0	47.0	44.0	36.5	28.9	20.5		
		MCWB	9.7	11.8	13.8	15.8	17.2	19.6	20.8	20.4	19.7	17.0	13.2	10.0		
	5%	DB	20.3	24.6	30.1	35.2	40.4	45.9	47.7	46.0	42.7	34.6	26.6	18.7		
		MCWB	9.2	11.1	13.1	15.0	16.6	19.0	20.5	20.0	19.0	15.9	12.1	9.3		
	10%	DB	18.8	22.7	28.1	33.2	38.6	44.6	46.4	44.9	41.2	32.6	24.8	17.1		
		MCWB	8.8	10.3	12.4	14.3	16.2	18.5	20.2	19.6	18.5	15.0	11.3	8.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.0	14.7	15.4	17.7	18.4	21.8	24.0	23.9	22.7	20.8	14.8	14.3		
		MCDB	17.5	23.6	29.9	37.9	42.0	45.8	37.7	38.2	38.6	27.6	28.2	18.4		
	2%	WB	12.5	13.1	14.6	16.5	17.6	20.8	23.3	22.9	21.6	19.3	13.8	12.7		
		MCDB	17.5	21.3	29.3	35.0	39.7	44.9	40.1	39.0	38.8	31.7	26.9	17.4		
	5%	WB	11.2	12.2	13.9	15.6	17.0	20.0	22.6	22.2	20.8	17.7	12.8	11.5		
		MCDB	17.7	21.4	28.5	33.3	37.8	44.0	41.1	40.2	38.9	31.6	25.5	15.9		
	10%	WB	10.0	11.3	13.0	14.9	16.4	19.1	21.9	21.5	20.0	16.5	11.7	10.1		
		MCDB	17.3	20.9	27.1	32.1	36.3	43.0	41.6	40.7	38.2	30.7	23.3	15.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.5	10.9	11.5	12.1	12.4	13.4	12.9	13.0	12.7	11.6	11.3	9.8		
		MCDBR	12.1	13.2	13.4	13.9	14.3	14.4	13.5	13.6	13.7	13.0	13.2	11.3		
		MCWBR	6.0	5.9	5.4	5.3	5.0	4.5	4.1	4.3	4.6	5.0	6.2	5.5		
	5% WB	MCDBR	10.2	11.6	12.4	12.6	13.7	13.1	11.8	11.7	11.2	10.5	12.4	8.2		
		MCWBR	5.1	5.5	5.3	5.0	4.6	4.1	3.4	3.5	3.8	4.0	5.9	3.9		
(40) Clear-Sky Solar Irradiance	taub		0.282	0.293	0.303	0.340	0.357	0.349	0.376	0.367	0.342	0.310	0.286	0.282		
	taud		2.586	2.563	2.521	2.400	2.391	2.423	2.419	2.419	2.483	2.566	2.592	2.596		
	Ebn at Noon		928	954	969	941	924	928	900	903	913	920	914	905		
	Edh at Noon		74	85	97	116	119	116	115	113	100	84	73	69		
(44) All-Sky Solar Radiation	RadAvg		2.98	3.98	5.51	6.93	7.84	8.60	7.91	7.36	6.29	4.69	3.42	2.67		
	RadStd		0.24	0.38	0.23	0.28	0.39	0.36	0.35	0.29	0.20	0.26	0.16	0.19		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (15 neighbors)	+0.48	N/A	-1.41	N/A	-0.43	N/A	N/A	N/A	+133	+67

Nomenclature: See separate page