

CREECH AFB, NV, USA

WMO: 746141

Lat: 36.583N

Lon: 115.683W

Elev: 955

StdP: 90.37

Time Zone: -8.00 (NAP)

Period: 05-19

WBAN: 23141

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-5.7	-4.0	-23.5	0.5	9.7	-20.7	0.7	12.4	11.9	12.6	10.3	9.4	1.0	250	0.498

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.8	40.3	17.7	38.9	17.3	37.8	17.2	21.4	34.2	20.2	32.7	19.5	32.2	4.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
17.9	14.4	25.5	16.3	13.0	26.1	14.5	11.6	27.7	66.4	34.0	62.2	32.1	59.4	32.0	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.0	10.4	8.6	-8.8	42.2	1.2	0.7	-9.6	42.7	-10.4	43.1	-11.1	43.4	-12.0	43.9		
(5)			-11.0	21.8	1.3	1.1	-11.9	22.6	-12.6	23.3	-13.3	23.9	-14.3	24.7	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.1	5.8	8.1	12.1	16.2	20.3	27.1	30.1	28.6	24.2	17.0	10.2	5.0	(6)
(7)		DBStd	9.28	3.31	3.57	3.65	3.86	3.95	3.29	2.34	2.20	3.60	3.44	3.76	3.19	(7)
(8)		HDD10.0	431	134	72	21	3	0	0	0	0	1	44	156		(8)
(9)		HDD18.3	1709	390	288	193	83	26	1	0	4	67	244	412		(9)
(10)		CDD10.0	3028	3	18	87	189	320	514	623	578	427	217	49	2	(10)
(11)		CDD18.3	1264	0	0	1	21	88	264	365	319	181	25	0	0	(11)
(12)		CDH23.3	19714	0	1	74	395	1320	4276	5852	4813	2544	421	18	0	(12)
(13)		CDH26.7	11632	0	0	11	107	573	2663	3803	2994	1368	112	1	0	(13)
(14)	Wind	WSAvg	2.8	2.0	2.6	2.9	3.5	3.7	3.4	3.4	3.1	2.9	2.3	1.9	1.9	(14)
(15)	Precipitation	PrecAvg	184	25	33	18	10	5	4	16	13	12	15	9	24	(15)
(16)		PrecMax	350	112	99	99	47	13	21	52	48	59	75	48	144	(16)
(17)		PrecMin	53	1	1	0	0	0	0	0	1	1	0	0	0	(17)
(18)		PrecStd	67	27	27	22	11	3	5	10	11	14	17	11	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.2	23.0	28.3	32.0	35.7	41.7	42.4	40.1	37.8	31.9	25.5	18.6	(19)
(20)		0.4%	MCWB	7.8	8.8	11.2	12.8	14.3	16.4	20.7	18.4	16.5	14.5	11.2	7.4	(20)
(21)		2%	DB	17.2	20.9	25.3	29.6	33.8	39.8	40.9	38.9	36.3	29.5	23.4	16.3	(21)
(22)		2%	MCWB	6.9	8.4	10.2	12.0	13.7	16.6	18.5	17.5	16.7	13.0	9.9	7.2	(22)
(23)		5%	DB	15.4	18.7	23.3	27.6	32.2	38.3	39.4	37.9	35.1	27.7	21.3	14.1	(23)
(24)		5%	MCWB	6.4	7.6	9.2	11.1	13.0	16.3	17.9	17.5	16.3	12.3	9.1	5.9	(24)
(25)		10%	DB	13.2	16.5	21.2	25.5	30.0	36.8	38.0	36.9	33.7	25.7	18.9	12.2	(25)
(26)		10%	MCWB	5.5	6.8	8.5	10.3	12.4	15.6	17.6	17.4	15.7	11.4	8.2	5.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.4	10.6	11.8	13.9	16.2	21.2	23.1	26.7	22.9	16.8	12.2	10.5	(27)
(28)		0.4%	MCDWB	14.0	17.6	25.3	29.2	32.9	37.8	40.8	36.3	33.4	24.0	23.1	15.3	(28)
(29)		2%	WB	8.8	9.2	10.8	12.7	14.8	18.9	21.2	21.3	19.0	15.4	10.9	9.0	(29)
(30)		2%	MCDWB	13.6	17.7	23.1	27.4	30.9	36.5	34.7	32.7	31.7	24.1	21.5	13.2	(30)
(31)		5%	WB	7.5	8.4	10.0	11.7	13.7	17.6	20.4	20.1	17.9	14.1	9.8	7.5	(31)
(32)		5%	MCDWB	13.1	17.2	21.5	25.4	29.6	35.4	33.0	31.8	31.1	22.6	19.7	12.0	(32)
(33)		10%	WB	6.2	7.3	9.0	10.8	12.9	16.4	19.8	19.2	16.9	13.1	8.7	6.0	(33)
(34)		10%	MCDWB	12.4	15.7	20.3	23.7	28.3	33.9	32.8	31.3	29.8	22.0	18.3	11.0	(34)
(35)	Mean Daily Temperature Range	MDBR	14.5	14.2	15.0	14.9	14.6	16.8	14.8	15.5	15.9	15.5	15.9	13.2	(35)	
(36)		5% DB	MCDBR	17.6	18.0	18.1	17.7	17.5	18.2	16.7	16.9	17.3	17.8	18.4	16.6	(36)
(37)		5% DB	MCWBR	9.9	8.9	8.3	7.9	7.3	7.8	7.0	7.1	7.7	8.0	9.4	9.5	(37)
(38)		5% WB	MCDWB	14.4	15.9	16.7	16.1	16.4	17.5	13.6	14.2	14.4	13.6	17.0	12.7	(38)
(39)		5% WB	MCWBR	8.8	8.1	7.9	7.1	7.2	9.6	6.0	7.3	7.8	6.0	9.3	7.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.261	0.269	0.279	0.307	0.324	0.322	0.354	0.348	0.312	0.291	0.265	0.263	(40)	
(41)		taud	2.612	2.598	2.564	2.467	2.445	2.467	2.446	2.448	2.533	2.580	2.617	2.614	(41)	
(42)		Ebn at Noon	956	984	997	975	957	953	920	922	945	943	943	931	(42)	
(43)		Edh at Noon	71	82	93	109	113	111	112	110	95	82	70	67	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.00	3.95	5.47	6.87	7.76	8.50	7.53	7.02	6.16	4.59	3.40	2.66	(44)	
(45)		RadStd	0.25	0.37	0.25	0.30	0.43	0.40	0.40	0.36	0.26	0.29	0.14	0.20	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (12 neighbors)	+0.50	N/A	-1.35	N/A	N/A	N/A	N/A	-116	+193	+87

Nomenclature: See separate page