

LAS CRUCES 20 N, NM, USA

WMO: 746320

Lat: 32.6137N

Lon: 106.7414W

Elev: 1319

StdP: 86.45

Time Zone: -7.00 (NAM)

Period: 07-19

WBAN: 03074

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-10.8	-8.7	-21.5	0.6	4.3	-19.3	0.8	5.1	9.3	12.4	8.2	13.1	0.7	N/A	0.430

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	37.3	15.9	36.1	15.9	35.0	16.0	20.0	26.2	19.5	26.4	19.1	26.5	3.0	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.8	16.0	21.1	18.0	15.2	21.1	17.2	14.5	21.3	63.5	25.7	61.8	26.2	60.2	26.2	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.2	6.9	5.8	-15.4	40.0	4.4	0.8	-18.6	40.6	-21.2	41.0	-23.7	41.5	-26.9	42.1		
			-16.6	21.3	4.9	0.7	-20.1	21.8	-22.9	22.2	-25.7	22.6	-29.2	23.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.5	3.9	6.9	11.2	14.9	19.0	25.4	26.5	25.6	22.1	15.9	9.0	4.7
	DBStd	8.68	3.79	4.50	3.83	3.56	3.24	2.51	1.86	1.88	2.48	3.85	4.09	4.22
	HDD10.0	571	191	101	34	5	1	0	0	0	0	4	67	169
	HDD18.3	1929	446	319	222	112	29	0	0	0	3	94	281	422
	CDD10.0	2568	3	16	70	151	280	463	511	484	363	186	37	6
	CDD18.3	883	0	0	1	8	51	213	252	226	116	17	0	0
	CDH23.3	13078	0	13	123	442	1332	3504	3103	2678	1430	433	19	0
	CDH26.7	6578	0	0	12	98	563	2096	1696	1399	610	104	0	0
Wind	WSAvg	2.0	1.6	2.1	2.4	2.9	2.7	2.3	1.9	1.7	1.6	1.7	1.6	1.7
Precipitation	PrecAvg	268	13	10	7	6	10	20	51	57	35	24	14	21
	PrecMax	507	42	53	28	60	91	115	135	167	93	87	78	100
	PrecMin	130	0	0	0	0	0	0	6	6	0	0	0	0
	PrecStd	86	11	11	7	10	16	24	32	30	25	21	17	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.8	25.2	28.3	31.1	35.1	39.4	38.3	37.1	34.8	31.1	25.4	20.7
		MCWB	7.6	9.7	10.4	11.6	13.2	15.2	16.5	17.4	16.0	13.9	10.8	8.7
	2%	DB	17.9	22.8	26.4	29.2	33.4	37.9	36.8	35.8	33.1	29.4	23.6	18.6
		MCWB	6.8	8.5	9.7	11.1	12.8	15.1	16.7	17.3	16.2	13.7	10.3	7.9
	5%	DB	16.0	20.5	24.7	27.7	31.7	36.7	35.6	34.8	31.8	27.7	21.6	16.2
		MCWB	6.0	7.6	8.9	10.6	12.3	14.9	16.8	17.5	15.9	13.0	10.0	7.1
	10%	DB	13.8	17.9	22.8	26.1	30.0	35.4	34.3	33.3	30.5	26.0	19.2	14.0
		MCWB	4.9	6.8	8.2	10.1	11.6	14.8	17.0	17.5	15.8	12.6	8.9	5.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.9	10.8	11.6	13.8	15.9	18.7	20.7	20.7	19.8	18.7	13.6	10.3
		MCDB	16.4	17.9	22.0	25.7	28.3	29.7	25.6	26.2	24.2	24.7	19.4	17.1
	2%	WB	7.9	9.7	10.4	12.5	14.7	17.9	20.1	20.0	19.1	16.8	12.3	9.0
		MCDB	15.0	19.9	23.0	25.0	27.4	29.7	25.8	26.8	24.6	22.7	17.8	16.6
	5%	WB	6.7	8.6	9.6	11.4	13.6	17.3	19.7	19.5	18.6	15.1	11.1	7.9
		MCDB	14.3	18.8	22.9	24.7	26.8	29.9	26.1	27.0	24.7	23.0	18.1	14.8
	10%	WB	5.6	7.4	8.8	10.6	12.6	16.7	19.2	19.1	18.0	14.1	9.8	6.6
		MCDB	13.0	17.4	21.5	24.6	26.9	30.4	26.4	27.1	24.9	22.6	17.9	13.3
Mean Daily Temperature Range	5% DB	MDBR	18.5	19.7	20.1	19.9	19.6	19.1	14.7	14.8	15.4	18.3	18.7	16.7
		MCDBR	21.6	23.5	23.4	22.2	22.4	21.3	17.3	17.2	18.0	20.2	21.2	19.4
		MCWBR	12.3	12.1	11.4	10.3	9.5	8.1	4.9	4.3	6.0	8.7	10.4	11.2
	5% WB	MCDBR	17.2	19.7	20.9	19.8	19.0	16.3	13.1	13.7	11.8	14.2	15.2	16.3
		MCWBR	9.9	10.5	10.3	9.3	8.1	5.6	3.2	3.7	4.1	6.3	8.2	9.5
Clear-Sky Solar Irradiance	taub	0.242	0.247	0.266	0.288	0.307	0.330	0.368	0.347	0.317	0.275	0.255	0.244	
	taud	2.664	2.654	2.558	2.469	2.465	2.425	2.407	2.443	2.505	2.623	2.627	2.651	
	Ebn at Noon	1007	1029	1021	1001	976	949	911	929	951	980	981	986	
	Edh at Noon	72	81	96	110	112	116	118	112	101	82	74	69	
All-Sky Solar Radiation	RadAvg	3.56	4.56	5.90	7.24	7.94	7.96	7.11	6.58	5.87	4.87	3.82	3.21	
	RadStd	0.25	0.36	0.31	0.29	0.27	0.35	0.34	0.23	0.27	0.37	0.23	0.17	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	-89	+146	+83

Nomenclature: See separate page