

LOS ALAMOS 13 W, NM, USA

WMO: 746330

Lat: 35.8584N

Lon: 106.5214W

Elev: 8716

StdP: 10.62

Time Zone: -7.00 (NAM)

Period: 04-19

WBAN: 03062

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.9	2.8	-10.7	4.3	11.3	-6.5	5.4	14.4	14.8	28.5	13.9	29.0	2.0	N/A	0.596

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.7	77.2	51.0	75.2	51.0	73.1	51.0	57.6	67.6	56.5	67.2	55.4	66.8	6.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
54.4	87.7	60.9	52.9	82.7	59.6	51.4	78.3	58.4	29.1	67.2	28.2	67.5	27.3	66.9	62.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.0	11.8	10.4	-13.9	81.4	4.7	2.4	-17.3	83.1	-20.0	84.4	-22.6	85.8	-26.0	87.5		
			-13.7	61.0	4.8	1.2	-17.1	61.9	-19.9	62.5	-22.6	63.2	-26.1	64.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.2	23.1	25.8	32.9	39.4	46.6	57.0	59.7	57.6	52.1	42.1	32.8	24.2
	DBStd	14.46	8.04	8.17	7.32	6.67	6.66	4.68	2.78	2.92	4.61	6.21	7.19	8.89
	HDD50	4116	835	678	531	322	144	6	0	1	31	251	517	800
	HDD65	8698	1300	1098	996	769	571	243	165	228	388	708	967	1265
	CDD50	892	0	0	0	2	38	215	300	237	93	7	0	0
	CDD65	3	0	0	0	0	0	2	1	0	0	0	0	0
	CDH74	290	0	0	0	0	1	146	108	31	4	0	0	0
	CDH80	7	0	0	0	0	0	6	1	0	0	0	0	0
Wind	WSAvg	4.7	4.6	5.3	5.4	5.8	5.5	5.1	3.8	3.6	3.9	4.4	4.5	4.6
Precipitation	PrecAvg	18.4	1.3	1.2	1.3	1.2	1.0	1.0	2.7	3.0	2.0	1.5	1.0	1.4
	PrecMax	25.3	3.9	2.8	3.1	3.6	3.1	2.2	4.9	5.9	4.1	4.0	3.4	4.1
	PrecMin	12.8	0.0	0.1	0.1	0.2	0.0	0.3	0.8	1.2	0.4	0.0	0.0	0.2
	PrecStd	3.4	1.0	0.8	0.7	0.9	0.8	0.6	1.1	1.3	0.9	1.1	0.9	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	49.5	52.1	60.3	64.4	72.6	80.8	79.4	77.2	74.3	67.0	59.9	52.4
		MCWB	34.4	35.5	39.7	41.9	45.0	50.1	52.2	51.5	51.2	44.3	39.9	34.2
	2%	DB	44.6	48.4	55.6	60.9	68.8	77.9	77.0	74.6	71.4	63.8	56.5	47.6
		MCWB	31.8	34.2	37.3	40.4	44.1	49.6	52.6	52.7	50.2	43.7	38.1	33.0
	5%	DB	40.7	45.2	51.5	58.4	66.0	75.4	75.0	72.4	68.8	61.1	53.0	43.3
		MCWB	30.3	32.8	35.2	39.5	43.1	48.7	52.6	53.3	49.3	42.7	36.6	31.0
	10%	DB	37.3	41.1	48.1	55.1	63.0	73.1	72.7	70.1	66.1	57.9	48.6	39.6
		MCWB	28.8	30.7	33.7	37.6	42.1	47.9	53.2	53.6	48.7	41.7	34.5	29.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	37.1	37.3	40.8	44.3	49.8	56.8	59.8	59.2	55.9	52.2	41.8	37.3
		MCDB	44.6	49.1	58.1	60.5	63.0	70.7	67.7	67.8	64.5	57.8	53.6	46.2
	2%	WB	33.5	35.2	38.6	42.3	46.4	54.9	58.1	57.5	54.1	48.3	39.3	34.7
		MCDB	41.4	46.1	54.6	57.2	60.9	69.5	67.7	67.3	64.1	56.6	50.4	43.2
	5%	WB	31.7	33.4	36.6	40.8	44.6	53.0	56.9	56.5	53.0	45.8	37.6	32.8
		MCDB	39.9	43.9	50.6	55.2	60.1	68.0	67.5	66.8	63.5	55.9	48.4	40.7
	10%	WB	29.8	31.8	34.8	39.0	43.0	51.3	55.8	55.4	51.7	43.7	35.7	31.0
		MCDB	36.8	41.9	47.3	53.5	59.6	67.0	67.2	66.2	62.1	55.7	46.5	39.1
Mean Daily Temperature Range	5% DB	MDBR	24.2	22.0	22.6	24.4	25.5	29.1	25.7	25.0	26.2	26.3	26.3	22.9
		MCDBR	30.1	27.8	28.5	30.0	30.2	32.9	29.9	29.0	30.7	32.3	33.8	28.5
		MCWBR	19.8	15.1	14.3	14.1	13.5	14.0	11.9	13.0	14.5	16.5	18.5	17.6
	5% WB	MCDBR	26.1	23.8	27.2	27.4	28.1	28.8	23.9	24.2	24.8	25.9	28.3	24.2
		MCWBR	17.7	14.1	14.1	13.8	13.7	13.6	11.6	12.2	13.1	14.8	16.3	15.4
Clear-Sky Solar Irradiance	taub	0.213	0.217	0.234	0.248	0.263	0.274	0.309	0.297	0.269	0.242	0.224	0.216	
	taud	2.735	2.752	2.684	2.638	2.631	2.588	2.553	2.551	2.657	2.721	2.709	2.716	
	Ebn at Noon	328	336	334	330	323	318	306	309	316	321	320	321	
	Edh at Noon	20	22	26	29	30	31	32	31	27	23	20	19	
All-Sky Solar Radiation	RadAvg	990	1282	1718	2105	2379	2522	2206	2030	1805	1444	1088	863	
	RadStd	80	107	120	103	139	126	111	85	81	112	71	56	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (14 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page