

DUPLIN COUNTY AP, NC, USA

WMO: 746929

Lat: 35.000N

Lon: 77.982W

Elev: 42

StdP: 100.82

Time Zone: -5.00 (NAE)

Period: 01-19

WBAN: 03702

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-6.4	-4.0	-16.3	0.9	-0.2	-13.0	1.2	1.3	8.5	6.9	7.6	7.4	1.1	330	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	35.1	24.4	33.7	23.9	32.4	23.6	26.3	31.3	25.7	30.4	25.2	29.7	2.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.1	20.4	28.0	24.1	19.1	27.2	23.9	18.9	27.0	82.4	30.6	79.1	31.0	76.7	29.7	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	5.8	5.1	DB	-10.2	37.1	1.7	1.3	-11.4	38.0	-12.5	38.7	-13.4	39.5	-14.7	40.4	(4)
(5)			WB	-11.0	27.3	2.2	1.1	-12.6	28.0	-13.8	28.6	-15.0	29.2	-16.6	30.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.6	6.3	7.4	11.5	16.6	20.8	24.9	26.7	25.8	22.5	17.1	11.3	8.3	(6)	
	DBStd	8.39	6.07	5.05	5.37	4.54	3.75	2.90	2.33	2.43	3.10	4.54	4.75	5.29	(7)	
	HDD10.0	446	148	103	48	5	0	0	0	0	0	4	40	98	(8)	
	HDD18.3	1618	374	308	218	86	21	1	0	0	6	78	214	312	(9)	
	CDD10.0	2868	33	29	96	202	333	446	516	488	375	223	80	46	(10)	
	CDD18.3	998	1	2	7	32	96	197	258	231	131	39	4	2	(11)	
	CDH23.3	9188	2	11	84	349	873	1908	2606	2079	961	281	26	8	(12)	
	CDH26.7	3639	0	1	9	83	286	811	1198	883	313	54	1	0	(13)	
(14) Wind	WSAvg	1.6	1.9	2.1	2.2	2.0	1.5	1.2	1.1	0.9	1.4	1.5	1.6	1.6	(14)	
(15) Precipitation	PrecAvg	1261	93	82	100	84	97	116	145	139	151	90	80	84	(15)	
	PrecMax	1652	158	188	164	146	202	300	236	320	663	222	202	183	(16)	
	PrecMin	925	30	30	36	29	58	34	76	58	26	1	13	25	(17)	
	PrecStd	178	37	40	33	31	38	58	43	57	123	48	49	37	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.4	25.1	27.8	31.2	33.7	36.2	37.2	36.3	33.2	30.9	26.1	24.5	(19)	
		MCWB	17.8	18.3	17.1	19.1	21.1	23.2	24.7	24.2	22.8	22.7	19.0	19.8	(20)	
	2%	DB	21.3	22.1	26.0	28.8	32.0	34.1	35.2	34.0	32.0	27.8	23.8	22.2	(21)	
		MCWB	16.9	16.7	17.0	18.2	21.6	23.5	25.1	24.5	22.9	21.0	18.2	18.2	(22)	
	5%	DB	18.8	19.0	23.6	27.4	29.8	32.7	33.7	32.6	30.1	26.3	22.2	20.0	(23)	
		MCWB	15.9	15.0	16.0	18.0	20.8	23.1	24.4	24.3	22.7	20.0	17.6	17.6	(24)	
	10%	DB	16.4	17.2	21.3	25.2	27.8	31.2	32.4	31.3	28.0	24.8	20.1	17.7	(25)	
		MCWB	13.1	13.2	15.4	17.8	20.3	22.9	24.0	24.0	21.9	19.6	16.7	15.3	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.5	19.7	20.4	23.1	24.2	26.2	27.5	27.4	25.6	24.7	21.8	21.1	(27)	
		MCDB	21.5	23.1	23.3	27.1	29.1	31.3	32.3	31.2	29.9	28.2	24.5	22.6	(28)	
	2%	WB	17.9	18.3	19.1	21.4	23.2	25.4	26.7	26.2	24.8	23.7	20.3	19.5	(29)	
		MCDB	19.9	20.8	22.6	25.0	27.7	30.6	31.7	30.5	28.7	26.1	22.2	21.1	(30)	
	5%	WB	16.2	16.4	17.9	20.2	22.5	24.8	25.9	25.6	24.1	22.5	18.8	17.8	(31)	
		MCDB	18.7	18.6	21.1	23.9	27.0	29.7	30.9	29.8	27.6	24.6	20.9	19.1	(32)	
	10%	WB	14.0	13.6	16.7	19.1	21.7	24.2	25.3	25.1	23.5	21.1	17.2	16.0	(33)	
		MCDB	16.1	16.1	20.0	23.1	26.1	28.7	30.1	29.1	26.4	23.4	19.1	17.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	11.6	12.3	13.4	13.6	12.3	11.4	10.8	10.5	10.4	12.1	13.0	11.8	(35)	
		MCDBR	14.0	15.5	15.8	15.5	13.8	12.7	12.2	12.0	12.4	13.1	14.3	12.8	(36)	
	5% WB	MCWBR	10.1	10.4	8.2	6.9	5.2	4.3	4.1	4.4	4.9	6.8	8.9	9.3	(37)	
		MCWBR	12.5	14.4	12.5	12.0	11.2	10.8	10.6	10.6	9.6	9.3	11.2	11.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.317	0.331	0.361	0.400	0.457	0.497	0.533	0.514	0.423	0.375	0.337	0.319	(40)	
		taud	2.498	2.453	2.398	2.287	2.170	2.104	2.020	2.063	2.317	2.426	2.488	2.527	(41)	
	Ebn at Noon		889	913	910	886	836	799	768	774	835	852	857	865	(42)	
		Edh at Noon	84	97	112	131	150	160	173	163	120	99	84	77	(43)	
(44) All-Sky Solar Radiation	RadAvg		2.65	3.34	4.41	5.54	6.08	6.37	6.07	5.47	4.58	3.80	2.92	2.33	(44)	
	RadStd		0.17	0.34	0.32	0.36	0.45	0.38	0.36	0.31	0.34	0.45	0.22	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (52 neighbors)		+0.47	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+163	+120

Nomenclature: See separate page