

LEMORE NAS, CA, USA

WMO: 747020

Lat: 36.333N

Lon: 119.950W

Elev: 232

StdP: 14.57

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23110

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 28.3	(c) 31.1	(d) 17.4	(e) 13.3	(f) 41.1	(g) 20.7	(h) 15.6	(i) 44.3	(j) 24.4	(k) 51.6	(l) 20.2	(m) 50.6	(n) 4.2	(o) 260	(p) 0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 34.5	(c) 103.7	(d) 70.0	(e) 101.3	(f) 69.1	(g) 98.9	(h) 68.4	(i) 73.2	(j) 97.4	(k) 71.4	(l) 96.1	(m) 69.9	(n) 94.6	(o) 8.4	(p) 10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.3	91.1	84.8	62.1	84.1	83.7	59.8	77.4	81.9	36.8	97.1	35.2	96.2	33.8	94.7	82.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 21.0	(b) 18.2	(c) 16.0	(e) 25.2	(f) 108.0	(g) 4.2	(h) 2.1	(i) 22.1	(j) 109.5	(k) 19.7	(l) 110.7	(m) 17.3	(n) 111.9	(o) 14.3	(p) 113.4		
			DB													
			WB													
				23.3	75.9	4.4	2.9	20.2	78.0	17.6	79.6	15.2	81.3	12.0	83.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.8	48.0	51.5	57.2	61.8	68.4	75.6	81.1	80.0	75.1	65.1	54.4	46.8
	DBStd	13.16	5.26	5.44	5.73	6.72	6.79	6.22	4.46	4.47	6.12	5.88	6.07	5.55
	HDD50	313	101	43	9	2	0	0	0	0	0	0	26	132
	HDD65	2293	526	378	247	140	42	3	0	0	4	70	319	564
	CDD50	5356	40	86	232	355	571	767	965	930	752	467	158	33
	CDD65	1861	0	0	6	43	148	320	500	465	306	72	1	0
	CDH74	27832	1	12	223	873	2397	4966	7324	6556	4141	1239	100	0
	CDH80	15952	0	1	40	321	1155	2923	4627	4069	2335	473	8	0
Wind	WSAvg	7.1	5.2	6.1	7.2	8.9	9.1	8.8	7.8	7.3	7.1	6.4	5.4	5.5
Precipitation	PrecAvg	6.9	1.3	1.4	1.3	0.6	0.3	0.1	0.0	0.0	0.2	0.3	0.9	0.9
	PrecMax	15.0	5.4	4.6	4.8	2.3	2.2	0.4	0.2	0.4	1.2	1.3	2.7	3.7
	PrecMin	3.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
	PrecStd	2.6	1.3	1.3	1.1	0.6	0.5	0.1	0.0	0.1	0.4	0.4	0.7	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.0	75.6	84.7	93.4	99.4	105.8	106.4	106.0	102.5	95.7	81.2	69.2
		MCWB	54.1	58.8	60.8	64.2	65.6	70.8	69.8	71.3	68.9	65.8	60.9	58.0
	2%	DB	64.5	70.4	79.7	88.2	95.0	102.0	103.7	102.5	99.5	89.6	77.1	64.1
		MCWB	54.4	57.5	60.0	62.4	64.3	68.6	70.0	70.0	67.8	63.4	59.1	55.2
	5%	DB	61.4	66.6	75.8	83.3	91.0	98.3	101.3	100.0	96.6	85.0	72.6	60.5
		MCWB	53.1	56.1	58.1	60.7	62.9	66.9	69.5	69.3	67.1	61.7	58.1	52.9
	10%	DB	58.4	63.2	72.0	78.9	86.8	94.8	98.6	97.4	93.1	81.2	68.1	57.0
		MCWB	52.1	54.8	57.1	58.8	61.4	65.7	69.2	68.1	66.2	60.4	55.8	51.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.6	62.3	64.1	67.3	68.3	73.2	75.5	76.6	74.2	68.2	63.1	60.7
		MCDB	64.7	69.6	78.6	86.8	93.7	101.2	99.1	99.4	95.4	88.0	76.9	66.1
	2%	WB	56.4	59.4	61.5	64.1	66.1	70.7	73.0	73.1	71.0	66.0	61.0	57.0
		MCDB	61.0	67.1	75.3	84.5	91.6	97.7	97.5	97.5	90.8	85.6	74.0	61.7
	5%	WB	54.5	57.4	59.7	61.8	64.2	68.6	71.3	70.9	68.6	63.9	59.1	54.6
		MCDB	59.3	65.0	72.7	80.5	88.1	94.8	97.0	95.4	92.0	81.4	70.4	58.4
	10%	WB	52.6	55.3	57.8	59.6	62.2	66.7	69.9	69.1	67.0	61.5	56.9	52.3
		MCDB	57.5	62.0	70.1	76.7	84.4	91.9	95.2	93.4	90.7	77.7	67.0	56.0
Mean Daily Temperature Range	5% DB	MDBR	19.6	21.8	26.3	29.1	30.4	33.8	34.5	34.8	33.2	30.7	26.0	19.3
		MCDBR	25.4	27.5	33.0	35.8	36.5	37.9	36.5	36.4	36.8	36.3	32.1	24.0
		MCWBR	17.3	17.2	17.0	17.1	15.1	14.7	14.1	14.0	15.1	17.5	19.4	16.3
	5% WB	MCDBR	19.4	23.4	28.7	32.4	33.8	35.7	34.0	34.8	34.0	31.3	28.4	16.8
		MCWBR	13.7	15.6	15.8	16.0	14.5	14.3	14.0	14.6	14.5	15.2	17.7	12.3
Clear-Sky Solar Irradiance	taub		0.349	0.363	0.364	0.362	0.362	0.356	0.374	0.355	0.362	0.383	0.375	0.347
	taud		2.371	2.340	2.347	2.374	2.391	2.406	2.385	2.414	2.406	2.304	2.278	2.385
	Ebn at Noon		264	275	286	292	292	292	286	290	283	263	250	257
	Edh at Noon		30	34	37	38	38	37	38	36	35	35	32	28
All-Sky Solar Radiation	RadAvg		794	1140	1617	2050	2428	2681	2570	2358	1968	1438	986	729
	RadStd		107	123	132	147	120	83	85	63	56	74	54	94

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (29 neighbors)		+0.95	N/A	-1.98	+0.92	N/A	N/A	N/A	-266	+319	+88

Nomenclature: See separate page