

LEMORE NAS, CA, USA

WMO: 747020

Lat: 36.333N

Lon: 119.950W

Elev: 71

StdP: 100.48

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 23110

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-2.0	-0.5	-8.1	1.9	5.0	-6.3	2.2	6.8	10.9	10.9	9.0	10.3	1.9	260	0.484

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.2	39.8	21.1	38.5	20.6	37.2	20.2	22.9	36.3	21.9	35.6	21.0	34.8	3.8	10

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.0	29.3	16.7	12.0	28.7	15.5	11.1	27.7	67.7	36.1	64.0	35.7	60.9	34.8	28.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.4	8.1	7.1	-3.8	42.2	2.3	1.2	-5.5	43.1	-6.8	43.7	-8.2	44.4	-9.9	45.2		
			-4.8	24.4	2.4	1.6	-6.6	25.5	-8.0	26.5	-9.3	27.4	-11.1	28.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.7	8.9	10.8	14.0	16.5	20.2	24.2	27.3	26.7	23.9	18.4	12.5	8.2
	DBStd	7.31	2.92	3.02	3.19	3.74	3.77	3.45	2.48	2.48	3.40	3.27	3.37	3.08
	HDD10.0	174	56	24	5	1	0	0	0	0	0	0	14	73
	HDD18.3	1274	292	210	137	78	23	2	0	0	2	39	177	313
	CDD10.0	2976	22	48	129	197	317	426	536	517	418	259	88	18
	CDD18.3	1034	0	0	3	24	82	178	278	258	170	40	1	0
	CDH23.3	15462	1	7	124	485	1332	2759	4069	3642	2301	688	56	0
	CDH26.7	8862	0	1	22	178	642	1624	2571	2261	1297	263	4	0
Wind	WSAvg	3.2	2.3	2.7	3.2	4.0	4.1	4.0	3.5	3.3	3.2	2.9	2.4	2.5
Precipitation	PrecAvg	175	34	35	32	15	7	2	0	1	4	8	22	24
	PrecMax	381	136	118	121	59	56	11	5	10	31	34	69	93
	PrecMin	98	0	0	0	0	0	0	0	0	0	0	0	2
	PrecStd	67	34	34	29	16	13	3	1	2	9	10	19	19
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.1	24.2	29.3	34.1	37.4	41.0	41.3	41.1	39.2	35.4	27.3	20.7
		MCWB	12.3	14.9	16.0	17.9	18.7	21.6	21.0	21.8	20.5	18.8	16.0	14.5
	2%	DB	18.0	21.3	26.5	31.2	35.0	38.9	39.8	39.1	37.5	32.0	25.0	17.8
		MCWB	12.5	14.2	15.6	16.9	17.9	20.4	21.1	21.1	19.9	17.5	15.0	12.9
	5%	DB	16.3	19.2	24.3	28.5	32.8	36.8	38.5	37.8	35.9	29.4	22.5	15.8
		MCWB	11.7	13.4	14.5	15.9	17.1	19.4	20.8	20.7	19.5	16.5	14.5	11.6
	10%	DB	14.7	17.3	22.2	26.1	30.5	34.9	37.0	36.3	33.9	27.3	20.1	13.9
		MCWB	11.2	12.7	13.9	14.9	16.4	18.7	20.7	20.0	19.0	15.8	13.2	10.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.3	16.8	17.9	19.6	20.2	22.9	24.2	24.8	23.4	20.1	17.3	15.9
		MCDB	18.2	20.9	25.9	30.4	34.3	38.5	37.3	37.5	35.2	31.1	24.9	18.9
	2%	WB	13.6	15.2	16.4	17.8	18.9	21.5	22.8	22.8	21.7	18.9	16.1	13.9
		MCDB	16.1	19.5	24.1	29.1	33.1	36.5	36.4	36.4	32.6	29.8	23.3	16.5
	5%	WB	12.5	14.1	15.4	16.5	17.9	20.3	21.9	21.6	20.4	17.7	15.0	12.5
		MCDB	15.2	18.3	22.6	26.9	31.2	34.9	36.1	35.2	33.3	27.4	21.3	14.7
	10%	WB	11.4	12.9	14.4	15.3	16.8	19.3	21.1	20.6	19.4	16.4	13.8	11.3
		MCDB	14.1	16.7	21.2	24.8	29.1	33.3	35.1	34.1	32.6	25.4	19.4	13.3
Mean Daily Temperature Range	5% DB	MDBR	10.9	12.1	14.6	16.2	16.9	18.8	19.2	19.3	18.5	17.1	14.4	10.7
		MCDBR	14.1	15.3	18.3	19.9	20.3	21.1	20.3	20.2	20.4	20.2	17.8	13.3
		MCWBR	9.6	9.6	9.4	9.5	8.4	8.2	7.8	7.8	8.4	9.7	10.8	9.0
	5% WB	MCDBR	10.8	13.0	16.0	18.0	18.8	19.8	18.9	19.3	18.9	17.4	15.8	9.3
		MCWBR	7.6	8.7	8.8	8.9	8.0	8.0	7.8	8.1	8.1	8.4	9.8	6.9
Clear-Sky Solar Irradiance	taub	0.349	0.363	0.364	0.362	0.362	0.356	0.374	0.355	0.362	0.383	0.375	0.347	
	taud	2.371	2.340	2.347	2.374	2.391	2.406	2.385	2.414	2.406	2.304	2.278	2.385	
	Ebn at Noon	833	867	902	920	920	921	902	915	892	830	789	809	
	Edh at Noon	93	108	117	120	120	118	119	113	109	110	101	87	
All-Sky Solar Radiation	RadAvg	2.50	3.59	5.10	6.46	7.65	8.45	8.10	7.43	6.21	4.53	3.11	2.30	
	RadStd	0.34	0.39	0.41	0.46	0.38	0.26	0.27	0.20	0.17	0.23	0.17	0.30	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	+0.53	N/A	-1.10	+0.51	N/A	N/A	N/A	-148	+177	+49

Nomenclature: See separate page