

IMPERIAL COUNTY AP, CA, USA

WMO: 747185

Lat: 32.834N

Lon: 115.579W

Elev: -58

StdP: 14.73

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 03144

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	35.9	38.5	9.2	8.8	61.0	13.1	10.7	61.1	26.8	63.0	23.9	63.5	4.6	260	0.468

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	26.3	111.9	72.7	109.5	72.3	107.8	72.0	80.9	97.1	79.5	96.3	78.2	95.9	7.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.9	140.0	88.5	75.0	130.8	88.8	72.9	121.8	89.2	44.3	97.0	42.9	95.8	41.5	96.1	89.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
26.1	22.3	18.8	DB	30.7	117.1	3.4	2.9	28.2	119.2	26.2	120.9	24.3	122.6	21.8	124.7
			WB	25.9	83.8	3.0	2.7	23.7	85.7	22.0	87.3	20.3	88.8	18.1	90.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.2	56.8	59.5	66.1	71.2	78.6	87.5	93.5	93.7	87.6	75.4	64.2	55.6	(6)
	DBStd	14.58	5.01	5.84	6.20	6.30	6.51	5.56	3.70	3.75	5.65	6.38	6.16	5.10	(7)
	HDD50	23	8	4	0	0	0	0	0	0	0	0	1	10	(8)
	HDD65	893	256	167	63	18	1	0	0	0	0	0	88	294	(9)
	CDD50	8869	220	270	500	635	888	1125	1350	1356	1128	787	427	183	(10)
	CDD65	4263	2	14	98	203	424	675	885	891	678	328	63	2	(11)
	CDH74	65067	108	339	1485	2737	5800	10323	14530	14580	10166	4057	881	61	(12)
	CDH80	41961	6	68	589	1324	3453	6938	10238	10257	6642	2164	279	3	(13)
(14) Wind	WSAvg	7.1	5.4	6.6	7.9	9.5	9.2	8.6	7.9	7.0	6.5	6.3	5.5	5.2	(14)
(15) Precipitation	PrecAvg	2.4	0.4	0.3	0.2	0.1	0.0	0.0	0.1	0.1	0.3	0.2	0.3	0.3	(15)
	PrecMax	4.9	1.5	1.3	1.0	0.6	0.1	0.0	1.1	0.5	3.0	1.9	1.7	1.6	(16)
	PrecMin	0.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	1.2	0.5	0.4	0.3	0.2	0.0	0.0	0.2	0.2	0.7	0.4	0.5	0.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.3	86.1	93.9	99.7	107.9	113.9	115.4	114.6	110.2	101.9	90.5	79.3	(19)
		MCWB	56.7	58.6	61.4	64.3	67.6	70.2	73.5	73.6	71.6	68.0	60.7	57.7	(20)
	2%	DB	77.1	82.0	90.2	95.4	102.5	110.0	112.1	111.5	107.8	98.6	86.7	75.2	(21)
		MCWB	55.0	57.6	60.4	62.5	65.9	69.7	73.3	73.4	71.2	66.9	59.6	55.3	(22)
	5%	DB	73.9	78.6	86.5	91.5	99.7	107.4	109.3	109.1	105.4	95.0	83.2	72.3	(23)
		MCWB	54.0	56.8	59.3	61.1	65.9	68.7	72.8	73.8	70.8	64.5	59.1	53.8	(24)
	10%	DB	71.2	74.4	82.6	88.0	96.4	104.3	107.4	107.0	102.3	91.3	79.4	68.9	(25)
		MCWB	53.4	55.0	58.2	60.1	64.3	67.9	72.6	73.7	71.1	63.4	57.7	52.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.9	63.7	65.6	67.9	73.5	78.2	81.9	84.0	81.8	75.1	64.9	61.3	(27)
		MCDB	74.2	78.6	85.1	90.8	96.6	101.4	101.5	99.9	96.4	91.1	80.9	72.8	(28)
	2%	WB	59.0	60.6	62.5	65.0	69.8	75.7	80.0	81.4	79.5	71.4	62.3	58.6	(29)
		MCDB	70.5	75.1	84.4	89.4	94.2	97.7	98.4	96.4	94.5	86.9	80.5	69.7	(30)
	5%	WB	56.9	58.3	60.8	63.1	67.6	73.4	78.6	80.0	77.6	68.5	60.5	56.6	(31)
		MCDB	68.9	73.6	82.6	87.4	94.1	96.6	97.1	95.9	94.0	87.3	79.5	67.5	(32)
	10%	WB	54.7	56.4	59.1	61.2	65.7	71.3	77.4	78.6	75.7	65.8	58.8	54.1	(33)
		MCDB	67.5	71.5	80.0	85.1	92.2	96.4	96.4	95.6	93.6	87.4	77.4	65.5	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	27.0	26.5	28.5	28.9	30.1	31.6	27.2	26.3	27.7	28.8	27.8	25.9	(35)
		MCDBR	31.6	31.8	33.6	33.7	34.2	34.5	30.1	29.1	30.1	32.5	31.8	29.7	(36)
	5% WB	MCWBR	16.9	15.5	14.4	13.5	12.6	12.8	11.2	11.3	11.5	13.2	14.8	15.8	(37)
		MCWBR	25.4	27.0	31.0	31.3	32.6	30.9	24.2	23.5	23.8	26.7	28.0	24.3	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.291	0.295	0.313	0.330	0.348	0.349	0.393	0.388	0.351	0.321	0.295	0.291	(40)
		taud	2.514	2.523	2.457	2.411	2.379	2.380	2.365	2.372	2.437	2.490	2.531	2.540	(41)
	Ebn at Noon	Ebn at Noon	297	307	307	304	297	295	282	282	290	293	293	291	(42)
		Edh at Noon	27	29	34	37	39	39	39	38	34	30	26	25	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1110	1419	1882	2300	2564	2675	2428	2260	1991	1602	1213	1004	(44)
	RadStd	RadStd	56	99	68	58	70	93	98	90	71	65	53	54	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (23 neighbors)	+0.86	N/A	-2.32	+1.06	N/A	N/A	N/A	-137	+313	+164

Nomenclature: See separate page