

CAMPO, CA, USA

WMO: 747186

Lat: 32.626N

Lon: 116.468W

Elev: 2641

StdP: 13.35

Time Zone: -8.00 (NAP)

Period: 01-19

WBAN: 03164

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	27.5	29.7	-2.6	5.3	52.3	1.5	6.5	52.1	31.2	52.0	27.5	54.1	4.5	50	0.556

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	35.1	98.2	64.5	95.4	64.1	92.9	63.7	69.8	88.3	68.5	87.5	67.3	86.7	12.9	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.2	99.2	75.9	62.1	92.1	76.9	59.8	84.7	76.4	35.4	88.4	34.2	87.8	33.1	86.6	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.6	22.0	19.1	DB	22.1	103.2	3.6	1.8	19.6	104.5	17.5	105.6	15.5	106.6	12.9	107.9
			WB	19.4	72.5	2.3	1.6	17.8	73.6	16.4	74.5	15.1	75.4	13.4	76.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.1	49.2	48.2	51.4	54.0	58.9	66.3	73.7	73.9	69.7	60.9	54.1	47.9
	DBStd	11.23	6.68	6.42	5.98	5.92	6.31	6.14	5.36	5.19	6.43	6.41	6.60	6.45
	HDD50	446	98	103	57	25	5	0	0	0	0	3	34	121
	HDD65	3039	490	472	422	332	209	54	6	3	32	158	330	531
	CDD50	3761	73	51	100	146	281	490	733	742	592	341	157	55
	CDD65	877	0	0	0	3	20	94	274	280	174	30	2	0
	CDH74	17090	26	41	149	318	892	2613	4299	4456	3025	1033	222	16
	CDH80	8501	3	3	21	78	333	1297	2344	2502	1555	337	28	0
(14) Wind	WSAvg	8.2	9.2	8.8	8.7	8.7	8.4	8.1	7.5	7.3	7.4	7.9	8.5	8.6
(15) Precipitation	PrecAvg	14.9	2.5	2.4	2.6	1.1	0.3	0.1	0.3	0.6	0.5	0.6	1.8	2.2
	PrecMax	30.9	11.8	8.8	9.9	6.0	1.1	0.6	1.9	4.1	2.8	3.1	9.0	12.3
	PrecMin	5.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	6.4	2.8	2.1	2.1	1.3	0.3	0.1	0.6	0.9	0.7	0.8	1.9	2.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.6	78.8	82.5	87.0	92.1	100.3	101.6	101.0	97.4	90.5	83.2	76.4
		MCWB	52.7	53.4	55.6	56.2	59.7	63.2	65.6	65.7	62.5	56.9	53.9	50.9
	2%	DB	72.3	74.4	78.7	81.9	88.1	95.5	97.4	98.1	94.6	87.5	79.8	71.8
		MCWB	49.0	50.5	54.0	54.6	58.9	62.3	65.6	65.0	63.3	57.3	53.0	49.1
	5%	DB	68.6	69.9	73.8	77.4	83.6	91.2	94.2	95.4	92.0	83.9	76.3	67.6
		MCWB	47.6	48.7	52.3	54.1	58.4	61.4	65.3	64.6	62.9	56.4	52.0	47.7
	10%	DB	64.4	64.6	70.0	73.0	78.9	87.9	91.2	92.4	89.7	80.5	72.2	63.1
		MCWB	46.3	47.3	51.3	52.7	57.1	60.2	64.5	64.1	62.1	55.5	50.2	46.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.4	56.9	58.9	60.4	64.4	68.1	71.4	71.5	70.4	65.2	57.7	55.5
		MCDB	66.8	69.1	75.6	76.5	83.8	88.9	88.5	89.2	86.5	76.7	69.7	65.0
	2%	WB	52.4	53.2	56.1	58.0	62.3	65.9	69.8	69.7	68.6	62.0	55.6	53.1
		MCDB	63.7	66.3	72.5	74.3	81.0	88.7	88.8	88.6	85.3	76.6	70.9	62.9
	5%	WB	50.5	51.1	54.2	56.0	60.3	64.0	68.4	68.4	67.1	59.6	53.9	51.0
		MCDB	61.4	64.7	69.7	72.3	78.3	85.7	88.2	88.0	83.7	75.5	70.5	60.1
	10%	WB	48.7	49.3	52.4	54.1	58.5	62.2	67.1	67.0	64.8	57.6	52.3	48.9
		MCDB	59.2	60.6	66.6	69.6	75.9	82.9	87.1	86.9	82.1	74.9	68.1	58.5
(35) Mean Daily Temperature Range	5% DB	MDBR	24.6	24.8	28.5	30.0	31.0	37.1	34.7	35.1	34.5	31.3	28.3	24.1
		MCDBR	32.3	35.9	38.4	40.3	41.4	42.5	37.3	38.0	37.3	38.6	35.8	33.3
		MCWBR	16.6	18.8	19.9	19.8	19.4	18.8	15.2	15.5	15.6	18.0	17.6	17.5
		MCDBR	26.3	30.9	34.6	35.3	37.1	38.7	31.1	31.0	29.6	32.7	31.8	25.0
	5% WB	MCWBR	15.4	18.0	19.7	19.2	19.1	18.7	13.3	13.1	12.9	17.2	17.7	15.2
(40) Clear-Sky Solar Irradiance	taub		0.282	0.288	0.299	0.308	0.326	0.332	0.361	0.363	0.326	0.324	0.286	0.287
	taud		2.559	2.557	2.513	2.494	2.463	2.448	2.451	2.428	2.508	2.481	2.578	2.574
	Ebn at Noon		302	310	312	311	304	300	291	290	298	292	298	293
	Edh at Noon		26	28	32	34	36	36	36	36	32	30	25	24
(44) All-Sky Solar Radiation	RadAvg		1090	1354	1819	2213	2444	2637	2412	2264	1983	1561	1195	987
	RadStd		73	121	91	86	133	101	119	92	75	94	53	61

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (33 neighbors)	+1.04	N/A	-2.79	+1.13	N/A	N/A	N/A	-162	+382	+209

Nomenclature: See separate page