

DESERT RESORTS, CA, USA

WMO: 747187

Lat: 33.627N

Lon: 116.159W

Elev: -118

StdP: 14.76

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 03104

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	31.7	34.9	4.4	6.9	65.7	8.8	8.6	64.7	20.8	62.0	18.1	62.6	3.0	340	0.471

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.4	112.6	72.0	109.7	71.5	107.8	71.0	79.6	97.1	78.2	97.0	77.0	97.0	7.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.9	130.3	88.9	72.8	121.2	89.3	70.6	112.1	90.1	42.9	96.6	41.5	96.9	40.2	96.8	88.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.6	18.3	16.2	24.7	118.7	3.9	3.1	21.9	121.0	19.6	122.8	17.4	124.6	14.6	126.8		
(5)			21.2	81.9	3.6	1.9	18.7	83.2	16.6	84.3	14.6	85.3	12.0	86.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.2	55.7	58.7	66.1	71.6	79.3	86.8	92.4	91.6	85.6	74.0	62.3	54.0	(6)
(7)		DBStd	14.55	5.57	5.91	6.40	6.56	6.10	5.57	4.51	4.46	5.34	5.99	6.47	5.38	(7)
(8)		HDD50	43	15	4	0	0	0	0	0	0	0	0	3	21	(8)
(9)		HDD65	1038	292	188	66	17	1	0	0	0	0	8	124	342	(9)
(10)		CDD50	8529	191	248	498	648	907	1103	1314	1291	1067	745	371	146	(10)
(11)		CDD65	4049	3	12	99	215	443	653	849	826	617	288	42	2	(11)
(12)		CDH74	65688	199	436	1728	3156	6285	10751	14676	14097	9419	3918	929	94	(12)
(13)		CDH80	42681	28	115	741	1611	3765	7322	10477	9942	6186	2156	329	9	(13)
(14)	Wind	WSAvg	6.5	4.7	5.5	7.1	8.7	9.1	8.2	7.0	6.4	6.4	5.9	4.8	4.5	(14)
(15)	Precipitation	PrecAvg	2.5	0.4	0.6	0.4	0.0	0.1	0.0	0.1	0.2	0.2	0.1	0.2	0.2	(15)
(16)		PrecMax	6.6	2.4	3.4	1.7	0.5	0.8	0.4	1.1	3.6	2.4	0.5	1.7	1.0	(16)
(17)		PrecMin	0.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
(18)		PrecStd	1.7	0.6	0.8	0.4	0.1	0.2	0.1	0.2	0.7	0.5	0.1	0.4	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	83.4	88.1	96.3	102.2	108.4	115.3	117.1	115.3	111.5	103.8	92.1	81.0	(19)
(20)			MCWB	55.8	58.3	61.2	64.0	68.8	70.9	74.9	72.4	71.2	67.0	60.8	56.7	(20)
(21)		2%	DB	79.2	83.6	91.5	97.5	103.7	110.2	112.4	111.9	108.0	99.2	88.0	76.5	(21)
(22)			MCWB	55.0	56.6	59.9	62.2	66.2	69.2	72.7	72.7	70.5	65.6	59.8	55.1	(22)
(23)		5%	DB	75.4	79.8	88.1	93.3	100.0	107.4	109.4	109.1	105.2	95.2	83.8	72.9	(23)
(24)			MCWB	53.7	55.8	58.9	60.9	65.3	68.7	72.0	72.5	69.9	63.6	58.5	53.1	(24)
(25)		10%	DB	72.0	75.2	83.9	89.4	96.7	104.4	107.2	106.4	102.1	91.6	79.5	69.5	(25)
(26)			MCWB	52.5	54.2	57.3	59.4	64.2	67.8	71.8	72.2	69.6	63.0	57.0	51.6	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.3	62.3	63.7	67.0	72.9	77.0	80.6	81.9	80.4	72.8	64.3	60.6	(27)
(28)			MCD B	74.3	79.4	87.4	96.5	102.5	103.3	99.0	97.9	95.2	90.2	83.3	74.9	(28)
(29)		2%	WB	58.0	59.5	61.9	64.3	69.5	74.1	78.9	80.2	78.0	69.8	61.8	58.0	(29)
(30)			MCD B	71.0	75.3	85.6	91.7	96.2	99.9	97.6	97.1	95.2	89.1	82.4	70.2	(30)
(31)		5%	WB	56.1	57.5	60.4	62.5	67.4	72.1	77.6	78.7	76.1	67.4	60.0	55.9	(31)
(32)			MCD B	70.0	73.9	83.4	88.6	93.4	99.4	97.6	96.8	94.4	90.0	80.3	68.0	(32)
(33)		10%	WB	54.1	55.9	58.9	60.9	65.7	70.3	76.5	77.4	74.1	65.1	58.4	53.6	(33)
(34)			MCD B	68.6	72.0	80.5	85.7	92.4	98.1	97.6	96.8	93.6	87.0	77.0	65.8	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	31.0	30.5	31.3	30.6	30.1	32.9	29.4	29.5	31.8	32.7	32.8	30.5	(35)
(36)			MCDBR	36.7	37.5	38.2	38.2	35.7	35.9	31.8	32.2	34.9	38.8	38.1	35.1	(36)
(37)			MCWBR	18.2	16.8	14.7	13.6	11.4	11.8	11.3	11.6	11.9	14.5	16.9	18.1	(37)
(38)		5% WB	MCDBR	30.8	31.0	34.0	34.3	33.9	34.5	26.3	26.0	27.6	33.1	33.7	29.1	(38)
(39)			MCWBR	16.2	14.9	13.7	12.8	11.5	13.1	11.1	12.3	12.7	13.9	15.7	16.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.305	0.308	0.328	0.352	0.369	0.369	0.405	0.395	0.360	0.337	0.309	0.308	(40)	
(41)		taud	2.496	2.505	2.435	2.373	2.353	2.368	2.367	2.380	2.446	2.470	2.524	2.521	(41)	
(42)		Ebn at Noon	289	300	301	296	291	289	278	280	286	286	286	282	(42)	
(43)		Edh at Noon	27	30	35	38	40	39	39	38	34	30	26	25	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1063	1363	1836	2247	2525	2681	2443	2279	1987	1564	1176	962	(44)	
(45)		RadStd	65	113	81	70	88	97	108	95	72	75	51	57	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.19	N/A	-3.04	N/A	-0.76	N/A	N/A	N/A	+387	+281
(47)	Regional (38 neighbors)	+0.97	N/A	-2.97	+1.06	N/A	N/A	N/A	-149	+346	+187

Nomenclature: See separate page