

HOLLOMAN AFB, NM, USAWMO: **747320**Lat: **32.850N**Lon: **106.100W**Elev: **1267**StdP: **87.00**Time Zone: **-7.00 (NAM)**Period: **94-19**WBAN: **23002****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-7.3	-5.3	-19.7	0.8	7.7	-17.6	0.9	9.5	11.9	12.5	10.3	11.9	2.2	0	0.508

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	38.0	16.9	36.9	17.0	35.7	17.0	20.6	29.3	20.1	29.1	19.6	28.9	4.2	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.9	16.0	21.7	17.8	15.0	22.2	17.0	14.2	22.7	64.9	28.7	62.8	28.8	61.1	28.7	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(4) 11.3	9.3	8.2		-11.5	40.4	4.3	1.3	-14.6	41.3	-17.1	42.0	-19.6	42.7	-22.7	43.6	
(5)				-12.5	22.4	4.0	1.8	-15.4	23.7	-17.7	24.8	-19.9	25.8	-22.8	27.1	(p)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	5.2	8.2	12.2	16.3	21.3	26.7	27.5	26.7	23.1	16.8	10.0	5.5	(6)
	DBStd	8.77	3.67	4.29	3.90	3.90	3.46	2.72	2.10	2.02	2.73	4.14	3.95	4.02	(7)
	HDD10.0	457	156	74	24	2	0	0	0	0	0	4	48	148	(8)
	HDD18.3	1709	408	283	192	83	14	0	0	0	3	78	251	398	(9)
	CDD10.0	2892	6	24	92	191	351	501	543	519	394	215	48	9	(10)
	CDD18.3	1103	0	0	1	22	106	251	285	261	147	31	1	0	(11)
	CDH23.3	14998	0	8	102	508	1686	3636	3683	3193	1683	482	17	0	(12)
	CDH26.7	7746	0	0	9	135	778	2143	2081	1714	746	139	0	0	(13)
(14) Wind	WSAvg	3.6	3.2	3.7	4.0	4.5	4.3	4.1	3.7	3.4	3.2	3.3	3.1	3.1	(14)
(15) Precipitation	PrecAvg	292	17	15	11	12	14	20	42	52	38	29	14	22	(15)
	PrecMax	474	49	68	23	47	75	96	86	196	100	83	42	102	(16)
	PrecMin	153	0	0	0	1	0	0	6	21	0	0	0	0	(17)
	PrecStd	72	14	15	8	13	17	20	19	38	28	23	12	25	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.5	24.8	28.2	32.1	36.6	40.4	39.5	37.9	35.8	32.2	25.2	20.7	(19)
		MCWB	8.5	9.4	10.8	12.6	14.7	16.4	17.0	18.2	17.0	15.4	11.4	8.9	(20)
	2%	DB	18.2	22.3	26.1	29.8	34.6	38.6	37.8	36.6	33.9	30.0	23.5	18.4	(21)
		MCWB	7.6	8.6	10.0	11.8	13.8	15.9	17.7	18.2	17.1	14.8	10.7	8.4	(22)
	5%	DB	16.2	20.2	24.3	28.1	32.7	37.2	36.5	35.4	32.5	28.1	21.5	16.1	(23)
		MCWB	6.4	8.0	9.3	11.1	13.5	16.0	18.0	18.4	16.6	13.9	10.1	7.1	(24)
	10%	DB	14.0	17.9	22.5	26.6	31.1	35.7	35.1	34.1	31.1	26.3	19.2	14.0	(25)
		MCWB	5.5	7.1	8.7	10.6	12.9	15.7	17.9	18.3	16.4	13.2	9.2	6.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	11.2	12.3	14.7	17.4	20.2	21.3	21.5	20.4	19.4	13.9	10.6	(27)
		MCDB	17.6	19.6	23.6	25.8	29.7	29.1	30.2	28.5	26.1	24.7	19.7	18.0	(28)
	2%	WB	8.2	9.7	11.0	13.1	16.0	19.1	20.6	20.5	19.7	17.3	12.4	9.2	(29)
		MCDB	15.8	19.2	22.6	25.6	28.8	30.1	30.0	29.4	26.4	24.5	18.8	16.1	(30)
	5%	WB	7.1	8.7	10.1	12.2	15.1	18.4	20.1	20.0	19.0	15.8	11.1	8.0	(31)
		MCDB	14.7	18.7	22.1	24.7	28.1	30.0	29.3	29.5	26.5	24.4	18.9	14.7	(32)
	10%	WB	5.9	7.7	9.2	11.2	14.1	17.8	19.6	19.5	18.3	14.8	10.0	6.8	(33)
		MCDB	13.0	17.4	21.0	24.7	27.2	30.0	28.8	29.5	26.4	23.5	18.7	13.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.0	16.7	17.3	17.4	17.2	16.6	14.4	14.3	14.4	16.0	16.3	14.6	(35)
		MCDBR	18.6	19.7	19.7	19.3	19.3	18.5	16.4	16.0	16.5	17.8	18.9	17.2	(36)
	5% WB	MCWBR	10.6	10.3	9.3	8.8	8.2	7.0	5.0	4.7	5.8	7.6	9.8	9.6	(37)
		MCWBR	16.3	17.6	17.7	17.9	17.0	15.5	13.4	13.5	12.6	14.4	15.4	14.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.249	0.256	0.276	0.305	0.322	0.344	0.384	0.366	0.331	0.287	0.266	0.253	(40)
		taud	2.615	2.590	2.516	2.411	2.420	2.391	2.357	2.377	2.440	2.564	2.570	2.603	(41)
	Ebn at Noon		995	1015	1009	983	961	935	896	911	934	963	962	971	(42)
		Edh at Noon	75	86	100	117	117	120	124	119	107	87	78	72	(43)
(44) All-Sky Solar Radiation	RadAvg		3.54	4.54	5.86	7.18	7.83	7.81	6.97	6.46	5.81	4.82	3.79	3.17	(44)
	RadStd		0.25	0.36	0.32	0.32	0.31	0.39	0.36	0.26	0.28	0.39	0.25	0.18	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (15 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+102	N/A