

FT WORTH MEACHAM, TX, USA

WMO: 747390

Lat: 32.819N

Lon: 97.361W

Elev: 209

StdP: 98.83

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13961

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.2	-2.9	-13.2	1.2	-0.7	-11.0	1.5	1.7	11.7	9.4	10.8	11.6	4.2	0	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.1	38.7	23.4	37.5	23.7	36.3	23.6	26.0	33.4	25.4	32.9	25.0	32.3	4.5	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.0	19.4	28.8	23.5	18.8	28.3	23.0	18.2	27.8	81.5	33.3	78.9	33.0	76.8	32.3	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
10.7	9.2	8.4	-8.9	40.6	1.9	1.8	-10.2	41.9	-11.3	42.9	-12.3	44.0	-13.7	45.3		
			-9.9	27.0	1.8	1.3	-11.2	27.9	-12.2	28.7	-13.2	29.4	-14.5	30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	8.2	10.4	14.4	18.7	23.4	27.8	29.8	30.0	25.9	19.9	13.9	9.0
	DBStd	8.94	5.74	6.07	5.39	4.21	3.74	2.55	2.32	2.58	3.73	4.73	5.15	5.38
	HDD10.0	296	102	64	22	2	0	0	0	0	2	21	83	
	HDD18.3	1218	315	229	142	46	7	0	0	0	39	147	292	
	CDD10.0	3702	47	74	159	263	416	534	614	619	476	308	139	53
	CDD18.3	1584	2	6	20	57	164	284	356	361	228	88	15	3
	CDH23.3	18791	17	50	151	444	1571	3411	4833	4893	2529	776	98	19
	CDH26.7	9563	1	10	27	107	607	1726	2762	2822	1222	262	16	2
Wind	WSAvg	4.3	4.3	4.5	4.9	5.0	4.8	4.5	4.0	3.6	3.5	3.9	4.1	4.1
Precipitation	PrecAvg	897	54	54	73	95	113	85	55	58	74	102	74	61
	PrecMax	1443	144	179	157	197	343	314	127	184	266	275	242	252
	PrecMin	369	4	0	0	16	12	10	0	0	16	12	2	9
	PrecStd	243	34	46	44	45	68	71	39	45	55	72	61	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.6	27.9	29.4	32.0	35.9	38.1	40.1	40.7	38.4	33.9	28.8	25.7
		MCWB	14.3	15.8	17.8	20.6	23.1	24.2	23.3	22.4	23.2	22.0	19.3	17.1
	2%	DB	22.5	24.6	26.9	29.3	33.6	36.6	38.5	38.9	36.2	31.7	26.0	22.6
		MCWB	14.5	16.1	18.1	20.2	22.9	24.1	23.6	23.1	23.1	21.2	18.2	15.9
	5%	DB	20.0	22.3	24.9	27.6	31.9	35.2	37.3	37.6	34.4	29.5	23.9	20.4
		MCWB	13.9	15.3	17.1	19.6	22.4	23.8	23.8	23.4	22.6	20.2	17.8	14.8
	10%	DB	17.6	20.0	22.8	26.0	30.1	33.8	36.0	36.3	32.7	27.7	22.1	17.8
		MCWB	12.7	14.8	16.3	18.7	22.3	23.7	23.9	23.6	22.4	19.7	16.8	13.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.9	19.8	21.2	23.4	25.8	27.3	26.6	26.3	25.7	24.6	21.9	19.6
		MCDB	21.5	23.7	26.3	28.7	31.9	33.9	35.0	34.2	33.0	29.2	25.4	22.9
	2%	WB	17.2	18.6	19.8	22.1	24.7	26.0	25.8	25.5	24.8	23.3	20.2	18.1
		MCDB	19.8	21.6	24.0	26.9	30.3	32.8	33.9	33.3	31.8	28.0	23.6	21.4
	5%	WB	15.4	17.2	18.9	21.2	23.9	25.3	25.3	25.0	24.1	22.4	19.0	16.0
		MCDB	18.7	20.5	23.0	25.4	29.1	32.1	33.4	32.8	30.6	27.0	22.5	18.6
	10%	WB	12.9	15.3	17.7	20.4	23.1	24.7	24.9	24.5	23.6	21.5	17.7	14.0
		MCDB	16.8	19.3	21.6	24.2	28.3	31.1	32.6	32.2	29.8	25.9	21.2	17.2
Mean Daily Temperature Range	5% DB	MDBR	11.3	11.3	11.3	11.4	10.7	10.7	11.0	11.1	11.0	11.5	11.0	10.7
		MCDBR	14.8	14.2	13.4	12.9	12.2	12.1	12.4	12.5	12.5	13.1	12.7	13.6
		MCWBR	8.9	8.4	7.3	6.6	4.6	3.5	3.2	3.1	3.7	5.7	7.0	8.3
	5% WB	MCDBR	12.1	11.9	10.8	10.4	10.5	10.5	10.9	10.9	10.4	10.4	10.6	11.2
		MCWBR	8.9	8.9	7.1	6.6	5.1	4.0	3.4	3.3	3.7	5.4	7.5	8.8
Clear-Sky Solar Irradiance	taub		0.311	0.324	0.355	0.392	0.423	0.434	0.437	0.435	0.399	0.358	0.335	0.317
	taud		2.501	2.474	2.405	2.328	2.301	2.304	2.335	2.323	2.371	2.471	2.474	2.487
	Ebn at Noon		910	932	923	898	868	854	849	847	866	881	873	881
	Edh at Noon		86	97	113	127	132	131	127	126	115	97	88	83
All-Sky Solar Radiation	RadAvg		2.93	3.45	4.53	5.48	5.90	6.63	6.75	6.18	5.18	4.07	3.09	2.57
	RadStd		0.29	0.54	0.34	0.45	0.58	0.63	0.46	0.39	0.44	0.60	0.40	0.33

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (48 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page