

KIMBLE COUNTY AP, TX, USA

WMO: 747400

Lat: 30.511N

Lon: 99.766W

Elev: 533

StdP: 95.08

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13973

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.3	-3.4	-13.9	1.2	4.3	-11.6	1.5	4.9	9.9	15.4	8.8	14.4	1.7	290	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.9	38.0	21.3	36.9	21.3	35.8	21.4	24.1	30.9	23.7	30.4	23.2	29.9	4.2	170

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.6	18.4	26.0	22.1	17.9	25.9	21.5	17.3	25.8	75.5	30.6	73.4	30.2	71.8	29.7	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.7	7.8	7.1	DB	-8.8	39.8	1.9	1.5	-10.2	40.9	-11.3	41.8	-12.4	42.7	-13.8	43.8	(4)
(5)			WB	-9.7	25.0	1.8	0.8	-11.0	25.5	-12.1	26.0	-13.1	26.4	-14.4	26.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.3	8.8	11.3	15.2	19.8	23.9	27.4	28.5	28.6	24.9	19.6	13.8	9.4	(6)	
	DBStd	8.24	4.90	5.54	5.24	4.32	3.64	2.32	2.08	2.02	3.20	4.46	4.87	4.87	(7)	
	HDD10.0	237	81	46	16	1	0	0	0	0	0	2	19	72	(8)	
	HDD18.3	1129	296	201	123	34	4	0	0	0	2	40	149	279	(9)	
	CDD10.0	3637	44	83	178	295	432	522	574	578	446	299	133	53	(10)	
	CDD18.3	1487	1	5	26	78	178	272	316	320	198	79	13	1	(11)	
	CDH23.3	17527	38	102	296	867	1873	3202	3957	4044	2152	820	135	39	(12)	
(13) Wind	CDH26.7	8763	6	24	85	324	848	1662	2196	2286	1024	279	24	6	(13)	
	WSAvg	3.0	2.7	3.1	3.3	3.7	3.6	3.4	3.1	2.7	2.5	2.6	2.6	2.6	(14)	
	PrecAvg	611	29	38	46	55	70	72	50	53	66	59	41	30	(15)	
	PrecMax	910	73	125	121	102	166	184	160	121	151	177	224	149	(16)	
	PrecMin	415	5	1	0	8	15	7	0	3	10	6	0	3	(17)	
	PrecStd	140	20	33	33	30	39	46	44	38	39	42	52	32	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.3	29.7	31.4	35.6	37.7	38.9	39.1	39.4	38.0	33.3	29.4	27.0	(19)	
		MCWB	13.6	14.9	16.4	17.5	20.0	21.8	21.3	21.3	20.5	20.0	17.8	14.2	(20)	
	2%	DB	23.8	26.3	29.1	32.5	35.2	36.9	37.6	37.9	35.3	31.4	26.7	23.9	(21)	
		MCWB	13.2	14.2	16.0	17.8	20.6	21.5	21.3	21.6	21.0	19.9	16.9	14.3	(22)	
	5%	DB	21.2	23.8	26.7	30.2	33.2	35.3	36.5	36.8	33.7	29.8	24.7	21.3	(23)	
		MCWB	13.1	14.0	15.7	17.9	20.6	21.6	21.4	21.6	20.8	19.1	16.1	14.1	(24)	
	10%	DB	18.7	21.3	24.2	28.1	31.3	33.9	35.2	35.5	32.2	28.0	22.7	19.0	(25)	
		MCWB	12.0	13.6	15.4	17.2	20.3	21.7	21.6	21.5	20.7	18.7	15.6	13.1	(26)	
	0.4%	WB	17.9	18.9	19.8	21.8	24.1	25.1	24.5	24.7	24.1	23.4	20.9	18.6	(27)	
		MCDB	21.3	22.8	25.5	28.4	30.9	32.4	31.7	31.6	29.5	28.3	26.0	22.0	(28)	
(29) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	16.3	17.7	18.9	20.9	23.2	24.1	23.8	23.9	23.4	22.4	19.6	17.3	(29)	
		MCDB	20.5	21.6	24.1	26.9	29.9	31.0	30.9	30.8	29.0	27.2	23.1	20.7	(30)	
	5%	WB	14.7	16.5	18.1	20.2	22.5	23.6	23.3	23.3	22.9	21.6	18.4	15.6	(31)	
		MCDB	19.0	20.7	23.0	26.0	29.1	30.4	30.2	30.4	28.6	26.5	22.1	19.3	(32)	
	10%	WB	12.7	15.1	17.2	19.6	21.9	23.0	22.9	22.9	22.4	20.7	17.2	13.9	(33)	
		MCDB	17.7	19.8	22.1	25.1	28.3	29.9	29.7	30.2	28.1	25.6	21.2	17.9	(34)	
	5% DB	MDBR	15.1	14.5	14.2	14.3	12.6	12.2	12.4	12.9	12.8	13.8	14.3	14.7	(35)	
		MCDBR	20.0	18.7	17.1	16.9	15.3	14.3	14.2	14.7	15.0	15.7	16.8	18.6	(36)	
		MCWBR	11.2	10.0	8.2	7.3	5.1	3.7	3.4	3.5	4.6	6.7	8.8	10.6	(37)	
		MCWBR	14.4	13.3	12.7	12.1	11.9	11.4	11.9	12.4	11.2	11.0	11.8	13.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.303	0.308	0.332	0.372	0.400	0.403	0.415	0.403	0.385	0.351	0.322	0.306	(40)	
		taud	2.534	2.524	2.468	2.375	2.354	2.395	2.408	2.428	2.414	2.498	2.511	2.530	(41)	
	Ebn at Noon		935	960	953	920	890	882	871	880	886	899	904	913	(42)	
		Edh at Noon	86	95	107	122	126	120	118	115	112	96	87	82	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.26	3.95	4.95	5.89	6.14	6.93	6.80	6.37	5.26	4.34	3.40	2.93	(44)	
	RadStd		0.35	0.54	0.43	0.50	0.64	0.54	0.57	0.35	0.47	0.62	0.45	0.39	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.51	N/A	N/A	N/A	+0.49	+0.67	N/A	N/A	N/A	N/A
(47) Regional (28 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page