

AUSTIN 33 NW, TX, USA

WMO: 747440

Lat: 30.6222N

Lon: 98.0846W

Elev: 1361

StdP: 13.99

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 23907

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 24.6	(c) 29.1	(d) 10.2	(e) 9.7	(f) 35.1	(g) 14.2	(h) 11.9	(i) 38.5	(j) 14.6	(k) 44.9	(l) 13.2	(m) 46.3	(n) 6.0	(o) N/A	(p) 0.341

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 21.1	(c) 98.4	(d) 71.1	(e) 96.5	(f) 71.4	(g) 94.8	(h) 71.7	(i) 75.9	(j) 86.7	(k) 75.3	(l) 86.1	(m) 74.6	(n) 85.2	(o) 4.8	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.5	131.3	77.7	73.0	128.7	77.6	72.2	125.4	77.5	40.2	87.3	39.6	85.9	39.0	85.2	79.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years				
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.6	10.9	9.7	18.5	102.6	4.1	2.8	15.6	104.6	13.2	106.2	11.0	107.8	8.0	109.9
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	67.8	49.7	53.9	60.9	67.5	73.9	81.1	83.3	84.2	78.5	69.2	59.0	51.2	(6)
	DBStd	14.26	9.96	11.09	8.92	6.73	5.88	3.54	2.91	3.51	5.12	7.89	9.20	9.69	(7)
	HDD50	368	129	80	22	0	0	0	0	0	0	3	29	105	(8)
	HDD65	1753	479	327	181	52	9	0	0	0	1	52	216	436	(9)
	CDD50	6856	119	190	359	526	742	933	1033	1059	855	598	300	142	(10)
	CDD65	2765	4	18	53	127	286	483	568	594	406	182	36	8	(11)
	CDH74	27547	29	100	319	871	2256	5108	6569	7159	3704	1257	151	24	(12)
	CDH80	12930	1	18	48	215	802	2454	3466	3910	1652	347	17	0	(13)
(14) Wind	WSAvg	4.7	4.7	5.2	5.8	5.8	5.1	4.4	4.1	3.8	3.6	4.2	4.6	4.7	(14)
(15) Precipitation	PrecAvg	33.1	2.0	2.1	2.8	2.8	3.1	3.6	2.2	2.0	3.3	3.3	2.8	2.2	(15)
	PrecMax	47.4	5.3	6.3	8.6	7.2	7.0	11.3	9.2	6.1	8.5	11.4	10.7	9.7	(16)
	PrecMin	21.4	0.0	0.1	0.6	0.3	0.6	0.2	0.0	0.0	0.0	0.0	0.0	0.1	(17)
	PrecStd	8.0	1.6	1.7	1.7	1.8	1.9	2.7	2.2	1.7	2.1	2.8	2.8	2.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.9	82.9	84.7	89.9	93.5	99.6	100.4	101.3	97.5	90.8	82.5	77.3	(19)
		MCWB	57.8	58.2	62.8	66.5	70.8	71.1	70.4	71.0	68.1	69.5	66.0	62.7	(20)
	2%	DB	72.9	76.8	80.6	85.5	90.3	95.7	97.8	98.8	94.3	86.6	78.3	72.9	(21)
		MCWB	57.3	58.1	62.0	66.6	70.4	72.0	70.8	71.9	69.8	70.6	64.8	61.2	(22)
	5%	DB	68.3	72.6	77.6	82.1	87.4	93.3	95.8	97.1	91.6	83.9	75.0	69.3	(23)
		MCWB	57.0	60.6	62.0	65.4	69.8	71.7	71.3	72.1	70.3	68.4	63.7	59.0	(24)
	10%	DB	64.4	69.1	74.5	79.3	84.7	91.1	93.9	95.2	89.0	81.2	71.8	66.2	(25)
		MCWB	54.5	60.0	60.8	64.5	69.4	72.1	72.1	72.1	70.2	66.0	63.3	59.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.3	67.4	68.2	73.0	75.4	76.9	76.5	76.4	76.0	74.2	71.1	67.1	(27)
		MCDB	68.8	72.5	76.1	81.3	82.9	87.1	86.7	89.5	85.2	82.2	77.1	72.3	(28)
	2%	WB	63.4	65.9	66.7	70.9	73.9	75.6	75.8	75.4	75.1	72.8	69.3	65.3	(29)
		MCDB	69.1	70.1	73.5	78.8	82.0	86.3	86.3	88.4	83.9	80.3	74.4	69.5	(30)
	5%	WB	59.8	64.2	65.7	69.4	72.9	74.9	75.1	74.8	74.3	71.6	67.2	63.5	(31)
		MCDB	65.0	68.0	72.2	77.0	81.1	85.4	85.6	87.5	82.7	78.1	72.5	67.4	(32)
	10%	WB	56.2	62.2	64.5	68.2	71.8	74.1	74.3	74.2	73.5	70.5	65.5	60.1	(33)
		MCDB	63.3	66.9	70.9	75.6	80.0	84.4	84.7	86.5	81.5	77.6	70.0	64.2	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	19.4	19.4	20.1	19.7	18.3	19.1	20.6	21.1	18.6	18.9	18.0	17.7	(35)
		MCDBR	23.3	21.8	22.2	22.3	21.6	21.9	23.3	23.4	21.8	19.8	19.0	20.6	(36)
	5% WB	MCWBR	13.3	12.0	10.4	10.1	7.7	4.9	4.7	4.6	6.0	7.4	10.0	12.5	(37)
		MCWBR	19.5	15.9	17.9	17.8	16.8	17.9	18.8	20.6	16.8	17.1	16.0	17.7	(38)
(40) Clear-Sky Solar Irradiance	taub		0.310	0.319	0.345	0.384	0.419	0.410	0.422	0.413	0.389	0.361	0.339	0.311	(40)
	taud		2.533	2.514	2.452	2.363	2.315	2.384	2.392	2.396	2.413	2.478	2.478	2.538	(41)
	Ebn at Noon		294	300	298	288	277	278	274	276	280	282	280	288	(42)
	Edh at Noon		27	30	35	39	42	39	38	37	36	31	29	26	(43)
(44) All-Sky Solar Radiation	RadAvg		974	1142	1462	1753	1849	2122	2132	2007	1653	1349	1024	862	(44)
	RadStd		104	187	134	160	180	153	172	110	152	196	125	115	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (39 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144

Nomenclature: See separate page