

GULFPORT-BILOXI, MS, USA

WMO: 747570

Lat: 30.412N

Lon: 89.081W

Elev: 13

StdP: 101.17

Time Zone: -6.00 (NAC)

Period: 98-19

WBAN: 93874

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.5	0.4	-9.8	1.6	3.1	-7.3	2.0	4.6	10.2	11.3	9.2	11.7	2.1	350	0.394

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.3	34.4	25.5	33.4	25.4	32.6	25.3	27.2	31.6	26.8	31.1	26.4	30.6	3.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.6	29.0	25.7	21.0	28.9	25.1	20.3	28.7	85.4	31.6	83.4	30.6	81.8	30.5	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.0	8.0	7.2	DB	-4.9	36.8	1.8	1.2	-6.2	37.6	-7.3	38.3	-8.3	38.9	-9.7	39.8	(4)
			WB	-6.3	28.3	1.9	0.9	-7.6	28.9	-8.7	29.5	-9.7	30.0	-11.1	30.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.3	10.9	13.0	16.1	20.0	24.0	27.3	28.1	28.1	26.2	21.2	15.6	12.4
	DBStd	7.25	5.34	4.92	4.32	3.45	2.85	1.74	1.46	1.49	2.36	4.07	4.51	5.06
	HDD10.0	124	55	24	6	0	0	0	0	0	0	0	7	32
	HDD18.3	832	236	159	93	23	2	0	0	0	0	21	105	194
	CDD10.0	3871	82	107	196	301	434	518	562	560	486	347	174	106
	CDD18.3	1538	4	9	25	73	177	268	304	302	236	109	22	9
	CDH23.3	14966	2	11	71	391	1620	2926	3391	3311	2279	870	87	8
	CDH26.7	5605	0	0	4	36	423	1194	1480	1414	848	201	5	0
Wind	WSAvg	2.9	3.3	3.4	3.5	3.6	3.2	2.5	2.1	2.2	2.7	2.8	2.8	3.2
Precipitation	PrecAvg	1617	138	114	152	136	128	156	175	156	158	77	101	127
	PrecMax	2189	528	319	297	329	361	425	326	368	660	221	319	424
	PrecMin	1048	0	10	3	2	11	19	48	38	21	0	0	33
	PrecStd	306	109	72	82	93	88	93	77	71	130	62	75	76
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	24.9	27.2	28.9	33.0	35.2	36.0	36.0	34.5	31.8	27.4	24.3
		MCWB	19.0	20.1	19.6	21.1	23.4	25.2	26.1	25.5	24.7	24.1	21.6	20.8
	2%	DB	21.7	22.9	25.2	27.7	31.2	33.6	34.2	34.1	32.8	30.1	25.8	22.8
		MCWB	18.5	19.8	19.8	21.2	23.2	25.1	25.7	26.0	24.8	23.5	20.8	20.1
	5%	DB	20.3	21.7	23.7	26.7	30.0	32.5	33.1	33.0	32.0	28.8	24.0	21.5
		MCWB	18.1	19.1	19.3	20.9	23.1	24.9	25.6	25.7	24.6	22.8	19.8	19.4
	10%	DB	19.0	20.2	22.5	25.8	28.9	31.5	32.3	32.3	30.9	27.6	22.8	20.3
		MCWB	17.3	17.9	18.9	20.8	22.9	24.7	25.5	25.7	24.5	22.4	19.3	18.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.6	22.3	22.3	24.5	25.8	27.3	27.8	28.0	27.1	26.6	24.0	22.2
		MCDB	21.8	23.7	24.5	26.7	29.2	31.6	32.5	32.5	30.4	29.1	25.7	23.6
	2%	WB	19.6	20.8	21.5	23.6	25.2	26.7	26.9	27.3	26.4	25.5	22.5	21.1
		MCDB	20.7	22.0	23.5	26.0	28.6	31.0	31.7	31.8	30.1	28.4	24.3	22.2
	5%	WB	18.8	19.6	20.7	22.9	24.6	26.2	26.6	26.8	25.9	24.7	21.3	20.0
		MCDB	19.8	21.0	22.7	25.3	28.1	30.5	31.3	31.1	29.6	27.6	23.2	21.1
	10%	WB	17.7	18.6	19.9	22.2	24.1	25.7	26.1	26.3	25.5	23.8	20.3	18.8
		MCDB	18.7	19.6	21.9	24.5	27.7	29.9	30.7	30.5	29.2	26.6	22.4	20.0
Mean Daily Temperature Range	5% DB	MDBR	10.1	9.7	9.9	9.4	8.9	8.2	8.3	8.4	8.8	10.6	11.3	9.9
		MCDBR	8.8	8.3	9.3	9.4	9.4	9.4	9.5	9.3	9.5	10.1	10.4	8.5
		MCWBR	6.3	5.7	5.3	5.0	4.0	3.5	3.5	3.5	3.7	4.8	6.5	6.4
	5% WB	MCDBR	7.1	7.3	7.3	6.8	7.1	7.7	8.4	8.3	7.7	7.3	8.1	7.7
		MCWBR	5.8	5.9	5.2	4.7	3.7	3.5	3.6	3.7	3.6	4.4	6.2	6.5
Clear-Sky Solar Irradiance	taub	0.334	0.350	0.373	0.405	0.438	0.466	0.516	0.505	0.454	0.385	0.354	0.341	
	taud	2.539	2.500	2.428	2.342	2.283	2.249	2.136	2.165	2.269	2.452	2.483	2.531	
	Ebn at Noon	900	914	911	889	857	829	786	791	821	864	867	872	
	Edh at Noon	86	98	112	127	135	139	155	149	130	101	91	83	
All-Sky Solar Radiation	RadAvg	3.02	3.57	4.80	5.86	6.46	6.26	5.90	5.59	5.21	4.54	3.47	2.68	
	RadStd	0.25	0.50	0.40	0.48	0.36	0.47	0.42	0.42	0.36	0.48	0.30	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.71	N/A	N/A	+0.77	N/A	N/A	N/A	N/A	+228	+144
Regional (28 neighbors)		+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+140	+93

Nomenclature: See separate page