

MONROE 26 N, LA, USA

WMO: 747610

Lat: 32.8833N

Lon: 92.1165W

Elev: 88

StdP: 14.65

Time Zone: -6.00 (NAC)

Period: 03-19

WBAN: 53961

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.0	25.0	12.3	10.3	28.4	17.6	13.4	32.2	6.9	66.9	6.6	65.2	0.4	N/A	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.2	97.8	76.6	95.4	76.7	93.2	77.0	82.0	88.3	80.8	88.2	79.8	87.7	3.3	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.5	158.6	84.1	79.1	151.5	83.4	77.9	145.4	82.8	45.6	88.5	44.4	88.3	43.2	87.7	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.7	5.7	4.9	16.5	100.9	3.9	3.2	13.7	103.2	11.4	105.1	9.2	106.9	6.3	109.3		
			15.1	83.9	4.3	1.9	12.0	85.2	9.5	86.3	7.1	87.3	3.9	88.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.6	44.8	47.7	56.1	63.3	71.2	78.4	80.7	80.8	75.1	63.8	53.4	46.9		
	DBStd	15.15	10.29	10.17	9.12	7.29	6.40	3.86	3.78	4.22	5.84	8.34	9.35	9.63		
	HDD50	688	230	154	44	4	0	0	0	0	0	5	70	181		
	HDD65	2615	629	491	298	114	24	0	0	0	4	127	363	565		
	CDD50	5658	69	90	233	404	658	853	953	954	752	433	172	87		
	CDD65	2109	3	7	23	63	218	403	488	489	306	89	15	5		
	CDH74	21649	5	39	209	670	2043	4168	5149	5158	3074	993	120	21		
	CDH80	10022	0	2	24	119	721	2016	2627	2717	1448	331	17	0		
(14) Wind	WSAvg	1.7	1.8	2.1	2.2	2.2	1.8	1.6	1.4	1.3	1.3	1.3	1.4	1.6		
(15) Precipitation	PrecAvg	55.7	5.3	4.4	5.7	5.8	4.6	4.3	4.4	3.4	3.7	4.0	4.4	5.3		
	PrecMax	75.7	14.8	8.1	20.2	20.1	12.2	12.2	10.8	8.2	11.4	21.3	11.8	9.7		
	PrecMin	34.4	0.6	0.9	0.9	3.1	0.2	0.9	1.6	0.6	0.4	0.0	1.3	0.7		
	PrecStd	10.5	3.1	2.3	3.8	3.4	2.8	2.5	2.1	2.1	2.5	4.3	2.4	2.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.2	78.7	82.9	86.2	91.2	98.8	100.0	101.2	97.9	90.8	82.6	76.9		
		MCWB	63.9	67.3	67.2	71.6	74.6	75.2	77.0	78.4	74.6	70.7	69.8	70.4		
	2%	DB	70.8	73.9	79.5	83.3	89.0	95.2	97.2	97.9	94.9	87.2	77.6	72.4		
		MCWB	62.1	65.9	66.4	69.7	73.7	76.4	77.3	77.8	74.7	71.8	67.4	68.0		
	5%	DB	67.1	70.1	76.1	80.9	86.9	92.4	94.5	95.3	91.8	84.0	73.3	68.4		
		MCWB	59.4	63.7	64.6	68.0	73.1	77.0	77.8	77.9	75.0	69.1	65.7	64.2		
	10%	DB	63.4	66.0	72.5	78.2	84.6	90.3	92.0	92.7	88.7	80.1	69.7	64.6		
		MCWB	57.3	60.6	62.9	66.5	72.5	76.9	78.0	77.5	74.8	68.4	64.4	60.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.7	70.7	71.2	75.3	79.1	82.2	83.1	84.1	81.0	78.2	73.4	73.8		
		MCDB	71.3	74.6	74.9	78.6	84.6	87.6	87.3	88.3	86.5	84.7	78.1	73.9		
	2%	WB	64.5	68.5	68.7	72.8	77.0	80.4	81.5	82.3	79.3	76.2	70.4	68.6		
		MCDB	68.4	72.7	75.6	79.4	84.0	87.3	87.9	89.0	86.9	82.9	73.9	71.6		
	5%	WB	61.4	66.1	67.2	71.1	75.5	79.3	80.4	81.0	78.1	73.9	67.8	66.0		
		MCDB	64.1	69.8	73.1	77.9	83.2	86.8	88.0	89.1	86.3	79.3	71.6	68.5		
	10%	WB	57.7	62.5	65.2	69.5	74.6	78.3	79.5	79.8	76.9	71.2	64.5	61.6		
		MCDB	59.8	66.8	70.3	75.7	82.2	86.5	88.0	88.1	85.2	75.8	68.1	63.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	21.7	21.5	24.0	24.6	22.3	21.9	21.2	22.5	24.5	26.7	24.8	21.8		
		MCDBR	25.9	25.9	26.6	26.4	24.2	25.2	25.2	26.1	28.3	29.7	27.6	24.2		
	5% WB	MCWBR	18.0	15.9	14.4	13.0	10.2	9.1	8.3	8.5	10.7	15.1	16.3	17.8		
		MCWBR	20.1	20.7	21.9	21.5	20.3	20.6	20.3	19.9	22.0	23.1	20.4	21.2		
(40) Clear-Sky Solar Irradiance	taub	taub	0.327	0.339	0.368	0.405	0.439	0.482	0.493	0.491	0.431	0.368	0.347	0.327		
		taud	2.518	2.482	2.410	2.297	2.260	2.178	2.173	2.173	2.321	2.469	2.479	2.523		
	Ebn at Noon	Ebn at Noon	283	291	289	281	271	258	254	253	265	276	272	276		
		Edh at Noon	27	31	36	42	43	47	47	47	39	31	28	25		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	836	964	1364	1702	1883	2030	1978	1837	1585	1293	939	734		
	RadStd	RadStd	78	164	113	118	128	147	123	152	141	176	102	86		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page