

MONROE 26 N, LA, USA

WMO: 747610

Lat: 32.8833N

Lon: 92.1165W

Elev: 27

StdP: 101.00

Time Zone: -6.00 (NAC)

Period: 03-19

WBAN: 53961

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.5	-3.9	-10.9	1.5	-2.0	-8.0	1.9	0.1	3.1	19.4	2.9	18.4	0.2	N/A	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.8	36.5	24.8	35.2	24.8	34.0	25.0	27.8	31.3	27.1	31.2	26.5	31.0	1.5	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.9	22.7	28.9	26.2	21.6	28.5	25.5	20.8	28.2	88.1	31.4	85.3	31.3	82.7	31.0	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
3.0	2.6	2.2	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
			-8.6	38.3	2.2	1.8	-10.2	39.6	-11.5	40.6	-12.7	41.6	-14.3	42.9		
			-9.4	28.8	2.4	1.0	-11.1	29.6	-12.5	30.2	-13.9	30.7	-15.6	31.5		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	7.1	8.7	13.4	17.4	21.8	25.8	27.1	27.1	23.9	17.7	11.9	8.3
	DBStd	8.42	5.72	5.65	5.07	4.05	3.56	2.14	2.10	2.34	3.24	4.63	5.20	5.35
	HDD10.0	382	128	86	24	2	0	0	0	0	0	3	39	101
	HDD18.3	1453	349	273	166	63	13	0	0	0	2	71	202	314
	CDD10.0	3143	38	50	129	224	366	474	529	530	418	241	96	48
	CDD18.3	1172	2	4	13	35	121	224	271	272	170	49	8	3
	CDH23.3	12027	3	22	116	372	1135	2316	2861	2866	1708	552	67	12
	CDH26.7	5568	0	1	13	66	401	1120	1459	1509	804	184	9	0
Wind	WSAvg	0.7	0.8	0.9	1.0	1.0	0.8	0.7	0.6	0.6	0.6	0.6	0.6	0.7
Precipitation	PrecAvg	1414	134	113	145	147	116	108	113	87	95	101	111	135
	PrecMax	1922	376	206	513	511	310	309	275	209	289	541	300	246
	PrecMin	875	14	22	22	80	6	24	41	15	10	0	33	19
	PrecStd	266	80	58	96	87	71	63	53	54	63	110	61	54
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.4	26.0	28.3	30.1	32.9	37.1	37.8	38.4	36.6	32.7	28.1	24.9
		MCWB	17.7	19.6	19.5	22.0	23.7	24.0	25.0	25.8	23.6	21.5	21.0	21.3
	2%	DB	21.5	23.3	26.4	28.5	31.7	35.1	36.2	36.6	35.0	30.7	25.4	22.5
		MCWB	16.7	18.8	19.1	20.9	23.2	24.7	25.2	25.4	23.7	22.1	19.7	20.0
	5%	DB	19.5	21.1	24.5	27.2	30.5	33.6	34.7	35.2	33.2	28.9	22.9	20.2
		MCWB	15.2	17.6	18.1	20.0	22.9	25.0	25.4	25.5	23.9	20.6	18.7	17.9
	10%	DB	17.4	18.9	22.5	25.7	29.2	32.4	33.3	33.7	31.5	26.7	20.9	18.1
		MCWB	14.0	15.9	17.2	19.2	22.5	24.9	25.6	25.3	23.8	20.2	18.0	15.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.8	21.5	21.8	24.1	26.1	27.9	28.4	28.9	27.2	25.6	23.0	23.2
		MCDB	21.8	23.7	23.8	25.9	29.2	30.9	30.7	31.3	30.3	29.3	25.6	23.3
	2%	WB	18.0	20.3	20.4	22.7	25.0	26.9	27.5	27.9	26.3	24.5	21.4	20.3
		MCDB	20.2	22.6	24.2	26.3	28.9	30.7	31.0	31.7	30.5	28.3	23.3	22.0
	5%	WB	16.3	18.9	19.5	21.7	24.2	26.3	26.9	27.2	25.6	23.3	19.9	18.9
		MCDB	17.8	21.0	22.9	25.5	28.4	30.5	31.1	31.7	30.2	26.3	22.0	20.3
	10%	WB	14.3	16.9	18.4	20.8	23.6	25.7	26.4	26.5	24.9	21.8	18.0	16.4
		MCDB	15.4	19.3	21.3	24.3	27.9	30.3	31.1	31.2	29.5	24.3	20.1	17.7
Mean Daily Temperature Range	5% DB	MDBR	12.1	11.9	13.3	13.6	12.4	12.2	11.8	12.5	13.6	14.9	13.8	12.1
		MCDBR	14.4	14.4	14.8	14.6	13.5	14.0	14.0	14.5	15.7	16.5	15.3	13.4
		MCWBR	10.0	8.8	8.0	7.2	5.7	5.1	4.6	4.7	5.9	8.4	9.1	9.9
	5% WB	MCDBR	11.2	11.5	12.2	11.9	11.3	11.4	11.3	11.1	12.2	12.8	11.3	11.8
	MCWBR	9.0	8.3	7.9	7.2	5.4	5.2	4.8	5.3	5.5	7.8	8.2	9.9	
Clear-Sky Solar Irradiance	taub	0.327	0.339	0.368	0.405	0.439	0.482	0.493	0.491	0.431	0.368	0.347	0.327	
	taud	2.518	2.482	2.410	2.297	2.260	2.178	2.173	2.173	2.321	2.469	2.479	2.523	
	Ebn at Noon	892	916	910	885	854	814	802	798	835	871	859	871	
	Edh at Noon	85	97	112	131	137	149	149	147	122	97	88	80	
All-Sky Solar Radiation	RadAvg	2.64	3.04	4.30	5.37	5.94	6.40	6.24	5.79	5.00	4.08	2.96	2.31	
	RadStd	0.25	0.52	0.35	0.37	0.40	0.46	0.39	0.48	0.45	0.56	0.32	0.27	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page