

SEBRING 23 SSE, FL, USA

WMO: 747650

Lat: 27.1526N

Lon: 81.3689W

Elev: 46

StdP: 100.78

Time Zone: -5.00 (NAE)

Period: 08-19

WBAN: 92827

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.8	4.4	-3.6	2.8	8.7	-1.2	3.4	9.9	6.2	18.2	5.6	17.2	0.7	N/A	0.284

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.5	34.0	24.5	33.3	24.4	32.7	24.4	26.2	30.6	25.8	30.3	25.6	30.1	2.2	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.4	27.7	24.8	20.0	27.5	24.4	19.5	27.3	81.3	30.6	80.0	30.5	78.7	30.2	29.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.2	4.5	3.9	DB	-2.1	35.2	2.5	0.7	-3.8	35.8	-5.3	36.2	-6.7	36.6	-8.5	37.1	
			WB	-2.5	26.9	2.3	0.3	-4.2	27.1	-5.6	27.3	-6.9	27.5	-8.6	27.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.7	16.1	18.3	19.2	22.4	24.7	26.8	27.3	27.6	26.9	24.1	20.4	18.6	
	DBStd	4.95	4.61	4.40	3.77	2.56	1.88	1.19	1.03	0.89	1.09	2.90	3.77	4.51	
	HDD10.0	17	10	3	1	0	0	0	0	0	0	0	0	3	
	HDD18.3	267	94	49	37	4	0	0	0	0	0	4	24	54	
	CDD10.0	4662	200	237	287	372	456	503	536	546	506	438	311	271	
	CDD18.3	1871	26	50	65	126	197	253	278	288	256	184	85	63	
	CDH23.3	15901	189	409	592	1211	1885	2228	2469	2527	2072	1398	554	367	
	CDH26.7	6144	17	77	136	409	811	1011	1104	1086	841	477	118	58	
Wind	WSAvg	1.7	1.9	1.9	2.1	2.0	1.9	1.5	1.3	1.4	1.4	1.6	1.7	1.7	
Precipitation	PrecAvg	1355	51	66	68	70	82	237	192	215	187	91	47	47	
	PrecMax	1713	138	201	146	178	181	459	363	411	310	234	132	180	
	PrecMin	819	6	2	5	9	25	50	109	87	56	13	7	6	
	PrecStd	222	40	46	46	36	43	103	63	86	70	56	43	47	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.5	29.9	30.6	32.9	34.4	35.0	34.6	34.5	33.5	32.6	31.0	29.7	
		MCWB	21.2	21.2	21.0	22.2	22.6	24.1	24.8	25.1	24.8	24.3	23.5	22.4	
	2%	DB	26.9	28.7	29.5	31.4	32.9	34.0	33.6	33.7	32.6	31.7	29.5	28.3	
		MCWB	20.1	20.7	20.4	21.8	22.5	24.2	24.8	25.1	24.7	24.0	23.0	22.0	
	5%	DB	25.7	27.7	28.4	30.3	32.0	32.9	32.9	32.9	31.9	30.6	28.0	27.0	
		MCWB	19.3	20.3	19.8	21.2	22.3	24.2	24.8	25.1	24.5	23.5	22.1	21.2	
	10%	DB	24.0	26.3	26.9	29.2	31.0	31.8	32.0	32.0	31.1	29.6	26.7	25.6	
		MCWB	18.3	19.6	19.4	20.6	22.1	24.2	24.9	25.1	24.5	22.5	20.9	20.2	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.5	22.8	23.0	24.3	24.7	26.2	26.5	26.8	26.3	25.8	24.7	23.8
			MCDB	26.0	27.1	27.7	29.3	29.5	31.1	30.9	30.8	30.2	29.1	28.5	27.0
2%		WB	21.3	21.9	22.0	23.4	24.2	25.7	26.0	26.3	25.8	25.1	23.9	22.9	
		MCDB	24.9	26.7	26.2	28.6	29.1	30.5	30.5	30.7	29.9	28.5	28.0	26.5	
5%		WB	20.4	21.2	21.2	22.8	23.7	25.2	25.7	25.9	25.5	24.5	23.1	22.0	
		MCDB	23.6	25.7	25.8	27.9	28.9	30.0	30.3	30.5	29.7	28.2	26.8	25.3	
10%		WB	19.6	20.5	20.4	22.0	23.2	24.9	25.4	25.6	25.1	23.9	22.2	21.2	
		MCDB	22.4	24.7	25.0	27.0	28.5	29.6	30.0	30.3	29.3	27.5	25.5	24.4	
Mean Daily Temperature Range	5% DB	MDBR	12.9	13.4	13.9	13.7	12.9	10.8	10.0	9.5	9.3	10.4	11.7	11.9	
		MCDBR	13.1	13.3	14.1	14.1	14.2	12.4	11.1	10.6	10.1	10.5	10.9	11.3	
		MCWBR	6.6	6.0	5.9	5.6	4.9	4.2	3.8	3.7	3.7	3.8	4.8	5.4	
	5% WB	MCDBR	10.8	11.8	12.0	12.2	11.7	10.3	9.8	9.6	9.2	8.6	10.0	10.1	
		MCWBR	6.5	5.9	6.2	5.3	4.6	3.9	3.8	3.7	3.8	3.7	4.9	5.5	
Clear-Sky Solar Irradiance	taub	0.344	0.358	0.374	0.386	0.415	0.447	0.463	0.451	0.422	0.399	0.360	0.349		
	taud	2.507	2.478	2.423	2.372	2.338	2.324	2.273	2.336	2.406	2.428	2.487	2.515		
	Ebn at Noon	904	917	919	911	879	845	831	842	860	862	879	881		
	Edh at Noon	93	103	115	124	128	129	136	127	115	107	94	89		
All-Sky Solar Radiation	RadAvg	3.61	4.37	5.32	6.17	6.30	5.65	5.59	5.43	4.94	4.59	3.83	3.31		
	RadStd	0.25	0.23	0.33	0.26	0.45	0.48	0.39	0.32	0.26	0.28	0.18	0.23		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (46 neighbors)	+0.42	+0.81	N/A	N/A	N/A	N/A	-1	-30	+154	+116	

Nomenclature: See separate page