

TITUSVILLE 7 E, FL, USA

WMO: 747660

Lat: 28.6159N

Lon: 80.6929W

Elev: 3

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 92821

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.3	41.6	24.8	18.9	47.2	29.8	23.8	47.8	15.7	60.2	14.5	58.9	3.8	N/A	0.294

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.1	90.9	77.7	89.5	77.9	88.3	77.6	80.1	87.5	79.4	86.8	78.8	85.9	5.8	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.1	145.7	83.8	77.4	142.4	83.3	76.9	140.0	83.0	43.4	87.8	42.8	87.0	42.2	86.2	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.1	11.9	10.6	DB	32.0	93.7	3.4	1.2	29.6	94.6	27.6	95.3	25.8	96.0	23.3	96.9	(4)
			WB	29.4	81.7	3.9	0.7	26.6	82.2	24.3	82.6	22.2	83.0	19.4	83.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	71.7	59.8	62.1	65.1	70.6	75.0	79.3	81.0	81.4	78.8	74.9	67.5	64.6
	DBStd	9.28	8.20	8.12	6.73	4.77	3.61	2.60	2.22	1.76	4.65	5.03	6.45	7.69
	HDD50	36	21	9	1	0	0	0	0	0	0	0	0	5
	HDD65	596	197	137	83	11	0	0	0	0	9	6	50	103
	CDD50	7966	325	347	468	618	776	880	960	974	865	771	525	457
	CDD65	3049	36	55	84	179	311	430	495	509	423	312	125	90
	CDH74	24689	117	251	423	1105	2269	3843	4810	5093	3707	2244	513	314
	CDH80	7178	3	24	51	179	520	1249	1714	1827	1095	449	46	21
Wind	WSAvg	4.6	5.2	5.3	5.6	5.5	5.1	4.3	3.7	3.9	3.6	4.3	4.7	4.4
Precipitation	PrecAvg	50.8	2.6	2.4	3.5	2.4	3.3	7.0	6.3	7.0	6.8	4.5	2.4	2.3
	PrecMax	71.5	6.1	8.3	14.6	6.8	16.2	12.9	10.6	13.8	13.1	14.8	9.3	10.3
	PrecMin	36.1	0.5	0.5	0.0	0.1	0.3	1.0	1.4	1.5	3.6	0.7	0.2	0.6
	PrecStd	9.6	1.5	1.6	3.2	1.5	3.1	2.7	2.6	2.5	2.6	2.9	2.2	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.1	82.9	84.5	86.7	90.0	92.0	92.5	92.2	90.8	88.1	84.3	82.4
		MCWB	70.5	70.7	69.2	72.6	74.2	77.0	78.1	78.4	77.6	77.2	74.9	73.4
	2%	DB	77.4	80.0	81.3	84.3	86.9	89.7	90.6	90.5	88.2	86.1	81.2	79.9
		MCWB	68.3	69.9	69.1	72.0	74.0	77.7	78.0	78.2	77.4	76.5	72.6	71.8
	5%	DB	74.8	77.3	78.4	82.1	84.7	88.1	89.1	89.2	86.7	84.4	78.9	77.5
		MCWB	66.5	68.6	67.9	71.0	73.6	77.4	78.1	78.3	77.2	75.5	71.1	70.1
	10%	DB	72.0	74.3	76.1	79.9	83.0	86.4	87.6	87.9	85.6	82.6	77.0	75.3
		MCWB	65.5	67.1	66.7	69.6	72.9	76.9	77.8	78.0	76.8	74.0	69.5	69.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.1	73.3	73.2	75.8	77.4	80.5	80.8	80.7	80.4	79.1	76.6	74.9
		MCDB	77.4	79.5	79.4	83.5	84.7	87.8	88.7	88.6	86.5	84.2	81.5	80.6
	2%	WB	70.1	71.6	71.4	74.4	76.1	79.4	80.0	79.9	79.4	77.9	75.2	73.4
		MCDB	74.7	77.3	77.6	81.3	83.1	86.9	87.8	87.7	85.8	83.5	79.9	78.5
	5%	WB	68.4	70.2	70.0	73.3	75.2	78.4	79.3	79.2	78.5	76.9	73.8	72.1
		MCDB	72.7	75.6	76.5	79.6	81.8	85.8	86.8	86.7	84.7	82.3	78.1	76.5
	10%	WB	66.7	68.7	68.5	72.0	74.3	77.7	78.5	78.5	77.8	75.6	72.0	70.7
		MCDB	71.0	73.9	74.7	77.9	80.6	84.9	85.7	85.6	84.0	80.4	76.1	74.6
Mean Daily Temperature Range	5% DB	MDBR	17.9	18.3	18.2	17.4	15.7	14.7	14.3	14.1	13.2	14.2	15.4	16.3
		MCDBR	18.8	19.1	19.0	18.6	17.3	16.1	15.5	15.5	14.2	14.1	14.9	16.1
		MCWBR	11.5	9.8	9.1	8.1	7.0	7.1	6.4	6.6	6.4	6.8	8.4	9.7
	5% WB	MCDBR	16.8	16.4	16.9	16.1	14.9	14.9	14.7	14.6	13.5	13.0	13.5	15.3
		MCWBR	11.0	9.1	8.8	8.0	7.1	7.3	6.5	6.5	6.5	6.4	8.0	9.4
Clear-Sky Solar Irradiance	taub	0.346	0.359	0.375	0.397	0.429	0.457	0.476	0.467	0.426	0.402	0.365	0.354	
	taud	2.545	2.520	2.467	2.383	2.337	2.330	2.277	2.317	2.421	2.460	2.512	2.547	
	Ebn at Noon	284	289	290	285	275	266	260	262	271	271	275	276	
	Edh at Noon	28	31	35	39	41	41	43	41	36	32	29	27	
All-Sky Solar Radiation	RadAvg	1054	1276	1622	1938	2006	1892	1898	1795	1566	1381	1116	960	
	RadStd	78	84	112	82	137	180	94	108	103	92	62	67	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (32 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	-9	-85	+270	+194

Nomenclature: See separate page