

TITUSVILLE 7 E, FL, USA

WMO: 747660

Lat: 28.6159N

Lon: 80.6929W

Elev: 1

StdP: 101.31

Time Zone: -5.00 (NAE)

Period: 05-19

WBAN: 92821

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 2.9	(c) 5.4	(d) -4.0	(e) 2.7	(f) 8.4	(g) -1.2	(h) 3.4	(i) 8.8	(j) 7.0	(k) 15.7	(l) 6.5	(m) 15.0	(n) 1.7	(o) N/A	(p) 0.294

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 7.8	(c) 32.7	(d) 25.4	(e) 31.9	(f) 25.5	(g) 31.3	(h) 25.3	(i) 26.7	(j) 30.9	(k) 26.3	(l) 30.4	(m) 26.0	(n) 30.0	(o) 2.6	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	20.8	28.8	25.2	20.3	28.5	24.9	20.0	28.3	83.2	31.0	81.6	30.6	80.3	30.1	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min		Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
5.8	5.3	4.7	DB	0.0	34.3	1.9	0.7	-1.3	34.8	-2.4	35.2	-3.5	35.6	-4.8	36.1	
			WB	-1.5	27.6	2.1	0.4	-3.0	27.9	-4.3	28.1	-5.5	28.3	-7.0	28.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.1	15.5	16.7	18.4	21.5	23.9	26.3	27.2	27.5	26.0	23.8	19.7	18.1
	DBStd	5.15	4.55	4.51	3.74	2.65	2.01	1.44	1.23	0.98	2.58	2.79	3.59	4.27
	HDD10.0	20	12	5	1	0	0	0	0	0	0	0	0	3
	HDD18.3	331	109	76	46	6	0	0	0	0	5	3	28	57
	CDD10.0	4426	181	193	260	343	431	489	533	541	481	428	292	254
	CDD18.3	1694	20	31	47	99	173	239	275	283	235	173	69	50
	CDH23.3	13716	65	139	235	614	1261	2135	2672	2829	2059	1247	285	174
CDH26.7	3988	2	13	28	99	289	694	952	1015	608	249	26	12	
Wind	WSAvg	2.1	2.3	2.4	2.5	2.5	2.3	1.9	1.7	1.8	1.6	1.9	2.1	1.9
Precipitation	PrecAvg	1290	67	61	88	62	83	177	161	179	173	114	62	59
	PrecMax	1817	154	210	370	173	411	328	268	351	332	377	237	262
	PrecMin	917	12	13	0	2	7	25	35	38	92	18	5	14
	PrecStd	244	38	41	82	38	79	68	65	64	67	74	56	61
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.7	28.3	29.2	30.4	32.2	33.3	33.6	33.4	32.7	31.2	29.1	28.0
		MCWB	21.4	21.5	20.7	22.6	23.4	25.0	25.6	25.8	25.3	25.1	23.9	23.0
	2%	DB	25.2	26.7	27.4	29.1	30.5	32.1	32.6	32.5	31.2	30.1	27.3	26.6
		MCWB	20.2	21.0	20.6	22.2	23.3	25.4	25.5	25.7	25.2	24.7	22.6	22.1
	5%	DB	23.8	25.2	25.8	27.8	29.3	31.1	31.7	31.8	30.4	29.1	26.0	25.3
		MCWB	19.2	20.3	19.9	21.7	23.1	25.2	25.6	25.7	25.1	24.2	21.7	21.2
	10%	DB	22.2	23.5	24.5	26.6	28.3	30.2	30.9	31.0	29.8	28.1	25.0	24.1
		MCWB	18.6	19.5	19.3	20.9	22.7	25.0	25.4	25.6	24.9	23.3	20.9	20.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.3	23.0	22.9	24.3	25.2	26.9	27.1	27.0	26.9	26.2	24.8	23.8
		MCDB	25.2	26.4	26.3	28.6	29.3	31.0	31.5	31.4	30.3	29.0	27.5	27.0
	2%	WB	21.2	22.0	21.9	23.5	24.5	26.3	26.6	26.6	26.3	25.5	24.0	23.0
		MCDB	23.7	25.1	25.4	27.4	28.4	30.5	31.0	30.9	29.9	28.6	26.6	25.8
	5%	WB	20.2	21.2	21.1	23.0	24.0	25.8	26.3	26.2	25.8	24.9	23.2	22.3
		MCDB	22.6	24.2	24.7	26.5	27.7	29.9	30.5	30.4	29.3	28.0	25.6	24.7
	10%	WB	19.3	20.4	20.3	22.2	23.5	25.4	25.9	25.8	25.5	24.2	22.2	21.5
		MCDB	21.6	23.3	23.7	25.5	27.0	29.4	29.9	29.8	28.9	26.9	24.5	23.7
Mean Daily Temperature Range	5% DB	MDBR	9.9	10.2	10.1	9.6	8.7	8.1	7.9	7.8	7.3	7.9	8.5	9.1
		MCDBR	10.4	10.6	10.6	10.3	9.6	9.0	8.6	8.6	7.9	7.9	8.3	8.9
	5% WB	MCWBR	6.4	5.5	5.1	4.5	3.9	4.0	3.5	3.7	3.5	3.8	4.7	5.4
		MCDBR	9.4	9.1	9.4	8.9	8.3	8.3	8.2	8.1	7.5	7.2	7.5	8.5
Clear-Sky Solar Irradiance	taub	taub	0.346	0.359	0.375	0.397	0.429	0.457	0.476	0.467	0.426	0.402	0.365	0.354
		taud	2.545	2.520	2.467	2.383	2.337	2.330	2.277	2.317	2.421	2.460	2.512	2.547
	Ebn at Noon	Ebn at Noon	896	912	915	899	867	837	820	826	853	855	866	869
		Edh at Noon	88	98	109	122	128	128	135	129	113	102	90	85
All-Sky Solar Radiation	RadAvg	3.32	4.02	5.11	6.11	6.32	5.96	5.98	5.66	4.94	4.35	3.52	3.02	
	RadStd	0.24	0.26	0.35	0.26	0.43	0.57	0.30	0.34	0.32	0.29	0.20	0.21	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-5	-47	+150	+108

Nomenclature: See separate page