

GREENVILLE, MS, USA

WMO: 747680

Lat: 33.483N

Lon: 90.985W

Elev: 128

StdP: 14.63

Time Zone: -6.00 (NAC)

Period: 01-19

WBAN: 13939

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.9	26.6	11.1	9.7	27.9	16.1	12.5	30.1	26.1	53.1	24.0	51.0	8.6	10	0.446

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	97.0	77.2	94.9	76.8	92.9	76.5	80.2	91.5	79.2	90.4	78.3	89.0	6.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.3	142.6	85.1	76.2	137.3	84.2	75.3	133.1	83.5	43.6	91.1	42.7	90.3	41.8	89.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	20.0	18.0	DB	16.4	99.8	4.3	3.3	13.3	102.2	10.7	104.1	8.3	105.9	5.1	108.3
			WB	14.8	82.0	4.1	1.2	11.8	82.9	9.4	83.6	7.1	84.3	4.1	85.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.4	44.3	47.0	56.3	64.5	72.6	79.9	81.8	81.8	76.5	65.3	54.3	47.1
	DBStd	15.70	10.61	10.13	9.53	7.48	6.30	3.81	3.59	4.18	5.65	8.39	9.13	9.64
	HDD50	698	243	164	49	4	0	0	0	0	0	2	59	177
	HDD65	2566	646	509	296	97	16	0	0	0	3	103	337	559
	CDD50	5947	65	80	243	440	701	897	986	986	796	478	188	87
	CDD65	2343	3	5	26	83	253	447	521	521	349	114	17	4
	CDH74	23587	3	20	155	612	2158	4697	5667	5636	3432	1084	110	13
	CDH80	10577	0	0	13	92	736	2209	2734	2852	1563	366	12	0
Wind	WSAvg	7.9	9.4	9.7	9.7	9.8	8.1	6.3	5.6	5.4	6.4	7.3	8.1	8.7
Precipitation	PrecAvg	50.1	5.0	4.5	5.2	5.1	4.5	3.3	3.9	2.8	3.5	4.0	4.2	5.1
	PrecMax	64.3	13.5	11.9	17.1	10.0	11.9	10.8	10.1	7.6	10.8	14.8	10.7	8.9
	PrecMin	29.3	0.8	1.1	0.5	2.0	1.7	0.4	1.1	0.6	0.0	0.0	1.9	1.0
	PrecStd	9.2	2.9	2.4	3.0	2.2	2.1	2.2	2.2	1.9	2.5	3.1	2.3	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.1	77.0	81.8	85.2	91.2	97.3	98.9	101.8	97.0	91.2	81.6	76.0
		MCWB	65.3	65.9	65.9	70.0	72.9	76.9	77.7	77.8	74.5	71.5	67.7	68.2
	2%	DB	69.6	72.5	78.4	82.4	89.0	94.7	95.9	97.4	94.4	87.9	77.3	71.2
		MCWB	63.5	63.1	65.6	68.5	72.5	76.5	78.1	77.5	74.3	71.4	65.3	65.3
	5%	DB	65.5	68.0	75.0	80.6	87.0	92.6	93.6	95.1	91.6	84.1	73.1	67.1
		MCWB	60.8	61.0	63.7	67.3	72.2	75.9	78.0	77.3	74.0	68.8	63.1	62.4
	10%	DB	61.5	63.8	71.8	77.8	84.4	90.7	91.4	92.6	88.9	80.7	69.9	63.3
		MCWB	56.3	57.7	62.1	65.7	71.4	75.4	77.5	76.8	73.0	67.2	62.0	59.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.3	68.0	69.4	73.9	77.0	80.3	81.9	81.3	78.7	76.0	71.1	69.1
		MCDB	70.7	74.1	77.9	81.3	85.7	92.5	92.5	93.1	89.8	85.1	77.7	74.0
	2%	WB	64.3	65.0	67.5	71.4	75.4	78.9	80.3	80.1	77.4	74.1	68.5	66.3
		MCDB	67.9	70.4	75.1	79.2	84.3	90.4	91.1	91.9	88.2	82.8	74.2	70.6
	5%	WB	61.6	62.2	65.6	69.7	74.4	77.9	79.3	79.1	76.3	72.4	66.0	63.5
		MCDB	64.8	67.4	73.0	77.2	83.0	88.9	90.0	90.7	86.4	80.4	71.6	66.4
	10%	WB	57.3	58.9	63.6	68.1	73.1	77.0	78.4	78.2	75.1	70.2	63.1	59.6
		MCDB	60.9	63.7	70.1	75.1	81.5	87.3	88.6	89.1	84.4	77.3	67.8	62.9
Mean Daily Temperature Range	5% DB	MDBR	17.5	18.0	19.6	19.9	18.9	19.4	18.7	20.2	22.0	22.5	21.0	17.2
		MCDBR	21.1	22.7	22.2	21.5	21.0	22.0	20.9	22.8	24.5	25.9	24.6	20.1
		MCWBR	15.9	15.2	12.6	10.4	8.3	7.7	7.1	7.1	8.5	11.6	14.4	15.5
	5% WB	MCDBR	18.4	19.6	19.9	18.0	17.8	19.3	18.9	20.2	19.8	20.2	19.8	18.1
		MCWBR	15.7	14.6	12.9	10.5	8.2	7.8	7.5	7.3	7.6	10.8	13.8	15.3
Clear-Sky Solar Irradiance	taub	0.322	0.331	0.362	0.418	0.449	0.488	0.503	0.501	0.438	0.362	0.339	0.322	
	taud	2.511	2.481	2.407	2.241	2.213	2.123	2.113	2.113	2.276	2.466	2.485	2.521	
	Ebn at Noon	284	292	290	277	268	256	252	250	262	277	274	277	
	Edh at Noon	27	30	36	44	46	50	50	49	40	31	27	25	
All-Sky Solar Radiation	RadAvg	817	967	1370	1710	1902	2074	1990	1839	1590	1293	932	720	
	RadStd	72	163	117	113	121	135	112	144	128	167	102	74	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page