

GREENVILLE, MS, USA

WMO: 747680

Lat: 33.483N

Lon: 90.985W

Elev: 39

StdP: 100.86

Time Zone: -6.00 (NAC)

Period: 01-19

WBAN: 13939

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.0	(c) -3.0	(d) -11.6	(e) 1.4	(f) -2.3	(g) -8.8	(h) 1.8	(i) -1.1	(j) 11.7	(k) 11.7	(l) 10.7	(m) 10.6	(n) 3.9	(o) 10	(p) 0.446

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	36.1	25.1	35.0	24.9	33.8	24.7	26.8	33.1	26.2	32.5	25.7	31.7	3.0	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.4	29.5	24.5	19.6	29.0	24.0	19.0	28.6	83.6	32.8	81.4	32.4	79.4	31.9	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.3	8.9	8.0	-8.7	37.7	2.4	1.8	-10.4	39.0	-11.8	40.0	-13.2	41.1	-14.9	42.4
			-9.5	27.8	2.3	0.7	-11.2	28.3	-12.5	28.7	-13.8	29.0	-15.5	29.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.0	6.8	8.3	13.5	18.1	22.6	26.6	27.7	27.7	24.7	18.5	12.4	8.4
	DBStd	8.72	5.90	5.63	5.29	4.15	3.50	2.12	2.00	2.32	3.14	4.66	5.07	5.35
	HDD10.0	388	135	91	27	2	0	0	0	0	0	1	33	98
	HDD18.3	1426	359	283	164	54	9	0	0	0	2	57	187	311
	CDD10.0	3304	36	44	135	244	389	498	548	548	442	266	104	48
	CDD18.3	1302	2	3	14	46	141	248	289	289	194	63	9	2
	CDH23.3	13104	2	11	86	340	1199	2609	3148	3131	1907	602	61	7
	CDH26.7	5876	0	0	7	51	409	1227	1519	1584	868	203	7	0
Wind	WSAvg	3.5	4.2	4.4	4.4	4.4	3.6	2.8	2.5	2.4	2.9	3.3	3.6	3.9
Precipitation	PrecAvg	1272	128	115	131	129	115	85	99	72	89	101	106	129
	PrecMax	1634	343	302	435	255	301	275	256	192	275	375	272	226
	PrecMin	745	21	28	12	52	43	11	27	16	0	0	48	25
	PrecStd	234	73	60	75	55	54	57	55	47	63	80	59	45
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.9	25.0	27.7	29.5	32.9	36.3	37.2	38.8	36.1	32.9	27.6	24.4
		MCWB	18.5	18.8	18.8	21.1	22.7	25.0	25.4	25.4	23.6	21.9	19.9	20.1
	2%	DB	20.9	22.5	25.8	28.0	31.7	34.8	35.5	36.3	34.7	31.1	25.2	21.8
		MCWB	17.5	17.3	18.7	20.3	22.5	24.7	25.6	25.3	23.5	21.9	18.5	18.5
	5%	DB	18.6	20.0	23.9	27.0	30.6	33.7	34.2	35.1	33.1	28.9	22.8	19.5
		MCWB	16.0	16.1	17.6	19.6	22.3	24.4	25.6	25.2	23.3	20.5	17.3	16.9
	10%	DB	16.4	17.7	22.1	25.4	29.1	32.6	33.0	33.7	31.6	27.1	21.1	17.4
		MCWB	13.5	14.3	16.7	18.7	21.9	24.1	25.3	24.9	22.8	19.6	16.7	15.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.6	20.0	20.8	23.3	25.0	26.8	27.7	27.4	25.9	24.5	21.7	20.6
		MCDB	21.5	23.4	25.5	27.4	29.8	33.6	33.6	33.9	32.1	29.5	25.4	23.3
	2%	WB	18.0	18.3	19.7	21.9	24.1	26.1	26.8	26.7	25.2	23.4	20.3	19.1
		MCDB	19.9	21.4	23.9	26.2	29.0	32.5	32.8	33.3	31.2	28.2	23.4	21.4
	5%	WB	16.5	16.8	18.7	21.0	23.5	25.5	26.3	26.2	24.6	22.4	18.9	17.5
		MCDB	18.2	19.7	22.8	25.1	28.4	31.6	32.2	32.6	30.2	26.9	22.0	19.1
	10%	WB	14.1	14.9	17.5	20.0	22.8	25.0	25.8	25.6	24.0	21.2	17.3	15.3
		MCDB	16.1	17.6	21.2	24.0	27.5	30.7	31.5	31.7	29.1	25.1	19.9	17.2
Mean Daily Temperature Range	5% DB	MDBR	9.7	10.0	10.9	11.0	10.5	10.8	10.4	11.2	12.2	12.5	11.7	9.6
		MCDBR	11.7	12.6	12.3	11.9	11.7	12.2	11.6	12.6	13.6	14.4	13.7	11.2
		MCWBR	8.8	8.5	7.0	5.8	4.6	4.3	4.0	4.0	4.7	6.5	8.0	8.6
	5% WB	MCDBR	10.2	10.9	11.1	10.0	9.9	10.7	10.5	11.2	11.0	11.2	11.0	10.1
		MCWBR	8.7	8.1	7.2	5.8	4.6	4.3	4.2	4.1	4.2	6.0	7.7	8.5
Clear-Sky Solar Irradiance	taub		0.322	0.331	0.362	0.418	0.449	0.488	0.503	0.501	0.438	0.362	0.339	0.322
	taud		2.511	2.481	2.407	2.241	2.213	2.123	2.113	2.113	2.276	2.466	2.485	2.521
	Ebn at Noon		894	921	913	872	844	808	793	788	826	874	865	872
	Edh at Noon		85	96	112	138	144	157	158	156	127	97	86	80
All-Sky Solar Radiation	RadAvg		2.58	3.05	4.32	5.39	6.00	6.54	6.27	5.80	5.01	4.08	2.94	2.27
	RadStd		0.23	0.51	0.37	0.36	0.38	0.43	0.35	0.46	0.40	0.53	0.32	0.23

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (20 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page