

KEESLER AFB, MS, USA

WMO: 747686

Lat: 30.417N

Lon: 88.917W

Elev: 10

StdP: 101.20

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13820

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.0	(c) 1.2	(d) -9.9	(e) 1.6	(f) 2.0	(g) -7.0	(h) 2.1	(i) 5.0	(j) 9.4	(k) 9.1	(l) 8.8	(m) 9.0	(n) 4.0	(o) 20	(p) 0.403

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.5	(c) 34.6	(d) 26.7	(e) 33.6	(f) 26.4	(g) 32.6	(h) 26.1	(i) 28.6	(j) 32.3	(k) 27.8	(l) 31.4	(m) 27.3	(n) 30.8	(o) 4.1	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.6	23.5	30.6	27.1	22.9	30.2	26.2	21.7	29.3	91.9	32.3	88.4	31.6	85.6	30.8	31.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.4	(b) 7.5	(c) 6.9	(e) -5.1	(f) 36.5	(g) 3.6	(h) 1.6	(i) -7.7	(j) 37.6	(k) -9.8	(l) 38.6	(m) -11.8	(n) 39.5	(o) -14.4	(p) 40.7		
(4) 8.4	(5) 7.5	(6) 6.9	(7) -5.1	(8) 36.5	(9) 3.6	(10) 1.6	(11) -7.7	(12) 37.6	(13) -9.8	(14) 38.6	(15) -11.8	(16) 39.5	(17) -14.4	(18) 40.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.6	10.8	13.4	16.4	20.3	24.5	27.6	28.4	28.4	26.4	21.5	16.0	13.1
	DBStd	7.22	5.19	4.98	4.44	3.42	2.69	1.83	1.59	1.75	2.28	3.91	4.37	4.92
	HDD10.0	114	54	23	6	0	0	0	0	0	0	0	6	25
	HDD18.3	779	237	147	89	21	1	0	0	0	0	17	94	172
	CDD10.0	3981	78	118	204	308	448	527	571	492	356	186	122	122
	CDD18.3	1606	3	9	29	78	191	277	312	313	242	115	25	11
	CDH23.3	15839	1	8	63	347	1660	3142	3644	3633	2401	847	82	10
	CDH26.7	6008	0	0	2	25	436	1273	1593	1597	892	186	4	0
Wind	WSAvg	3.3	3.6	3.6	3.8	3.8	3.5	3.2	2.8	2.7	3.0	3.2	3.1	3.4
Precipitation	PrecAvg	1660	142	107	149	122	131	175	190	162	167	91	112	122
	PrecMax	2299	470	223	310	403	319	461	370	330	752	223	337	414
	PrecMin	1073	1	8	4	15	16	40	61	78	38	0	0	39
	PrecStd	305	108	64	84	89	87	100	82	58	154	68	82	76
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.5	24.6	26.5	28.8	32.8	34.7	36.2	36.3	34.5	31.5	27.4	24.6
		MCWB	18.9	21.0	20.9	21.7	25.4	25.8	28.0	27.4	25.2	24.8	23.2	21.6
	2%	DB	21.0	22.6	25.1	27.3	31.3	33.4	34.3	34.8	32.8	30.0	25.4	23.0
		MCWB	18.8	19.9	20.6	22.4	24.5	26.0	26.9	27.0	25.3	24.1	21.4	20.9
	5%	DB	19.9	21.3	23.7	26.3	30.1	32.5	33.1	33.5	32.1	28.7	24.1	21.7
		MCWB	18.4	19.0	20.3	21.7	23.9	25.9	26.5	26.8	25.1	23.2	20.1	19.9
	10%	DB	18.6	20.1	22.5	25.3	29.1	31.6	32.3	32.4	31.0	27.5	22.8	20.4
		MCWB	17.2	18.2	19.7	21.2	23.6	25.7	26.2	26.4	24.9	23.0	19.6	19.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.7	22.2	23.0	25.2	27.4	28.6	29.8	29.7	28.6	27.0	24.9	23.1
		MCDB	21.1	23.6	24.3	27.1	30.9	31.3	34.2	33.6	31.5	28.6	26.0	23.6
	2%	WB	19.8	21.0	22.1	24.2	25.9	27.8	28.4	28.7	27.4	25.8	22.8	21.5
		MCDB	20.3	22.0	23.7	25.9	29.1	30.9	32.5	32.8	29.6	28.1	24.4	22.2
	5%	WB	18.8	20.0	21.3	23.5	25.2	27.1	27.5	27.9	26.3	25.0	21.7	20.4
		MCDB	19.6	20.8	22.9	25.2	28.5	30.6	31.3	31.7	29.8	27.7	23.3	21.3
	10%	WB	17.4	18.9	20.5	22.7	24.6	26.5	26.9	27.2	25.8	24.0	20.6	19.4
		MCDB	18.1	19.7	21.9	24.5	27.8	30.2	30.7	30.9	29.3	26.6	22.1	20.2
Mean Daily Temperature Range	5% DB	MDBR	9.2	8.8	8.7	8.3	7.9	7.5	7.5	7.7	8.6	9.7	10.1	8.8
		MCDBR	8.0	7.7	8.0	7.8	8.5	8.2	8.4	8.7	9.4	9.2	9.5	8.4
		MCWBR	6.1	5.7	5.0	4.5	3.8	3.4	3.7	3.6	3.9	4.6	5.9	6.5
	5% WB	MCDBR	6.9	6.4	6.8	6.5	7.0	7.3	7.9	8.0	7.8	7.6	7.8	7.6
		MCWBR	6.0	5.4	4.8	4.6	3.7	3.7	3.9	4.0	3.9	4.6	6.1	6.6
Clear-Sky Solar Irradiance	taub	0.334	0.350	0.374	0.405	0.438	0.465	0.515	0.505	0.453	0.385	0.354	0.342	
	taud	2.542	2.502	2.428	2.344	2.286	2.254	2.141	2.166	2.275	2.454	2.485	2.533	
	Ebn at Noon	900	914	911	890	857	829	787	791	822	863	867	871	
	Edh at Noon	86	98	112	126	135	138	154	149	129	101	90	83	
All-Sky Solar Radiation	RadAvg	3.03	3.58	4.82	5.89	6.50	6.28	5.91	5.60	5.23	4.55	3.48	2.68	
	RadStd	0.25	0.50	0.39	0.48	0.36	0.47	0.42	0.42	0.35	0.48	0.30	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+137	+90

Nomenclature: See separate page