

MOSS POINT TRENT LOTT, MS, USA

WMO: 747688

Lat: 30.464N

Lon: 88.532W

Elev: 6

StdP: 101.26

Time Zone: -6.00 (NAC)

Period: 99-19

WBAN: 53858

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.6	-1.1	-10.1	1.6	2.8	-7.4	2.0	4.5	8.8	7.7	8.2	8.8	1.4	0	0.353

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.6	34.4	25.5	33.3	25.5	32.5	25.3	27.3	31.5	26.8	31.0	26.4	30.6	2.4	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	29.1	25.7	21.0	28.9	25.2	20.3	28.6	85.8	31.5	83.5	31.0	81.7	30.4	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
7.9	7.0	5.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-5.7	36.4	1.8	1.2	-7.0	37.2	-8.0	37.9	-9.0	38.6	-10.3	39.5
			-6.6	28.2	1.8	0.7	-7.9	28.7	-9.0	29.1	-10.0	29.5	-11.3	29.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	10.6	12.7	15.9	19.2	23.0	26.6	27.5	27.6	25.5	20.4	14.9	12.1
	DBStd	7.16	5.46	5.04	4.35	3.45	2.76	1.57	1.34	1.36	2.45	4.18	4.62	5.23
	HDD10.0	141	60	26	6	1	0	0	0	0	0	10	38	
	HDD18.3	899	244	167	98	30	3	0	0	1	28	123	204	
	CDD10.0	3681	79	102	190	277	402	498	541	544	466	322	156	102
	CDD18.3	1396	5	9	24	57	147	248	283	286	217	92	18	9
	CDH23.3	12766	9	25	106	411	1400	2468	2790	2738	1895	788	115	22
	CDH26.7	4928	2	1	6	43	413	1068	1236	1189	756	207	8	0
Wind	WSAvg	2.2	2.6	2.8	2.7	2.6	2.1	1.6	1.4	1.4	1.8	2.1	2.2	2.5
Precipitation	PrecAvg	1692	149	138	142	124	134	143	184	180	154	99	115	129
	PrecMax	2287	434	323	355	481	364	366	493	418	666	333	288	281
	PrecMin	912	28	5	8	5	4	15	11	38	10	0	0	42
	PrecStd	320	94	77	75	112	86	89	105	101	122	86	71	57
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	25.9	27.5	29.1	33.0	35.4	35.5	35.6	35.0	31.9	27.7	25.3
		MCWB	19.9	20.9	19.4	21.2	23.6	24.4	26.1	26.1	25.1	24.1	21.8	20.9
	2%	DB	22.6	23.9	25.9	27.8	31.2	33.7	34.0	34.1	32.9	30.3	26.2	23.8
		MCWB	19.1	19.5	19.7	21.1	23.0	24.9	25.9	25.9	24.6	23.3	21.0	20.5
	5%	DB	21.2	22.3	24.4	27.0	30.0	32.5	32.9	33.0	31.9	28.9	24.7	22.6
		MCWB	18.4	18.7	19.1	20.9	22.9	24.9	25.7	26.0	24.4	22.5	19.9	20.0
	10%	DB	19.8	21.0	22.9	25.9	28.9	31.6	32.1	32.2	30.8	27.6	23.2	21.0
		MCWB	17.7	18.0	18.4	20.2	22.6	24.7	25.6	25.8	24.3	22.0	19.1	18.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	21.9	22.4	24.2	25.7	27.2	27.8	28.4	26.9	26.0	24.1	23.0
		MCDB	23.0	24.0	25.2	26.9	29.5	32.0	32.5	32.7	30.8	28.9	26.3	24.1
	2%	WB	20.2	20.9	21.4	23.4	25.0	26.5	27.0	27.5	26.3	25.1	22.7	21.6
		MCDB	21.7	22.8	23.7	26.1	28.8	31.3	31.6	31.5	30.2	28.5	24.6	22.9
	5%	WB	19.2	19.9	20.7	22.7	24.4	26.0	26.6	26.9	25.7	24.4	21.3	20.5
		MCDB	20.7	21.6	22.9	25.3	28.2	30.5	31.2	30.9	29.6	27.6	23.7	21.9
	10%	WB	17.9	18.6	19.8	21.9	23.9	25.5	26.2	26.5	25.3	23.4	20.2	19.1
		MCDB	19.6	20.2	22.1	24.2	27.5	29.9	30.6	30.4	29.2	26.2	22.6	20.7
Mean Daily Temperature Range	5% DB	MDBR	12.1	11.7	12.2	12.1	11.6	10.2	9.6	9.5	10.6	12.7	13.7	11.9
		MCDBR	11.1	11.1	11.8	11.9	12.5	11.7	10.9	10.8	11.3	12.3	13.1	10.9
		MCWBR	7.9	7.1	6.7	6.3	5.8	4.7	4.3	4.3	4.6	6.1	8.1	7.9
	5% WB	MCDBR	9.0	8.6	9.4	8.8	9.6	9.7	9.7	9.5	9.3	9.2	10.5	9.3
	MCWBR	7.3	6.6	6.3	5.7	4.9	4.5	4.3	4.3	4.3	5.3	7.7	7.7	
Clear-Sky Solar Irradiance	taub	0.334	0.350	0.374	0.404	0.438	0.464	0.512	0.503	0.449	0.385	0.355	0.341	
	taud	2.546	2.503	2.429	2.345	2.287	2.260	2.151	2.171	2.288	2.457	2.484	2.535	
	Ebn at Noon	900	914	911	890	857	830	789	793	825	864	866	871	
	Edh at Noon	86	97	112	126	134	138	153	148	128	101	90	83	
All-Sky Solar Radiation	RadAvg	3.06	3.61	4.88	5.96	6.58	6.32	5.94	5.61	5.26	4.58	3.50	2.69	
	RadStd	0.24	0.50	0.39	0.48	0.35	0.47	0.41	0.40	0.33	0.47	0.30	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.78	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (34 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+154	+100

Nomenclature: See separate page