

HOLLY SPRINGS 4 N, MS, USA

WMO: 747700

Lat: 34.8223N

Lon: 89.4348W

Elev: 484

StdP: 14.44

Time Zone: -6.00 (NAC)

Period: 08-19

WBAN: 23803

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	19.2	3.7	6.8	20.5	9.2	9.0	23.8	10.9	53.4	10.0	51.7	1.6	N/A	0.351

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.6	93.2	75.8	91.2	75.9	89.5	75.5	79.4	89.0	78.3	87.6	77.4	86.4	3.7	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.8	142.2	84.7	75.5	135.8	83.5	74.6	132.0	82.7	43.2	89.1	42.1	88.0	41.1	86.7	83.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.0	8.5	7.4	7.0	96.0	5.7	2.9	2.9	98.2	-0.4	99.9	-3.6	101.5	-7.7	103.7
			5.8	81.0	5.9	1.3	1.5	81.9	-1.9	82.6	-5.3	83.3	-9.6	84.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	59.8	38.8	43.6	51.1	60.1	68.3	75.8	78.1	77.3	71.9	60.0	48.7	43.0
	DBStd	16.18	11.68	11.34	10.17	8.40	7.18	4.35	4.18	4.32	6.26	8.63	9.44	9.96
	HDD50	1168	382	243	112	15	0	0	0	0	15	134	267	
	HDD65	3497	813	600	440	190	57	2	0	0	17	202	492	684
	CDD50	4751	35	65	145	318	568	773	870	846	658	327	95	51
	CDD65	1604	1	2	8	43	159	325	405	381	225	49	4	2
	CDH74	15373	0	4	84	432	1360	3193	3989	3619	2124	541	25	2
	CDH80	6057	0	0	7	65	387	1275	1751	1571	866	134	1	0
	WSAvg	2.9	3.5	3.9	3.9	3.6	2.9	2.4	2.1	2.1	2.1	2.4	2.8	3.4
	PrecAvg	56.4	4.6	4.7	5.7	5.3	5.5	4.3	4.4	3.7	3.7	3.8	5.2	5.7
(15) Precipitation	PrecMax	83.0	10.7	11.2	13.6	18.1	13.0	11.6	11.1	8.1	9.3	10.1	12.4	15.9
	PrecMin	37.5	0.7	0.7	2.0	1.3	0.8	0.3	0.7	0.3	0.4	0.0	1.4	0.9
	PrecStd	8.9	2.6	2.4	2.8	3.0	3.0	2.7	2.6	1.9	2.2	2.4	2.7	3.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.6	74.3	80.9	84.9	88.7	93.7	95.5	96.4	94.0	87.5	77.5	73.4
		MCWB	60.8	63.6	64.0	67.9	72.2	74.6	76.6	78.1	71.9	68.7	63.6	64.5
	2%	DB	65.5	70.9	76.2	82.0	86.4	91.2	92.5	93.2	91.2	83.7	72.7	68.3
		MCWB	59.8	62.9	62.2	65.5	71.6	76.3	77.5	76.6	73.1	68.7	62.3	62.5
	5%	DB	61.2	67.3	72.2	79.2	84.4	89.1	90.7	90.8	88.7	80.2	69.2	64.4
		MCWB	55.4	59.7	59.6	64.5	70.4	75.8	77.2	75.9	73.4	66.6	59.7	60.0
	10%	DB	57.4	63.2	68.3	76.1	82.1	87.1	88.8	88.4	85.6	76.4	65.4	60.1
		MCWB	51.7	56.1	57.7	62.7	69.3	74.7	76.6	75.2	72.2	65.4	58.1	55.4
	0.4%	WB	64.0	66.2	66.4	71.1	75.6	79.8	80.4	81.4	77.3	74.7	68.5	67.5
		MCDB	68.5	71.2	76.2	81.0	84.3	88.6	88.6	92.3	87.6	83.5	72.9	71.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	60.6	64.5	64.3	69.0	74.0	78.3	79.3	79.6	75.7	72.7	65.3	63.7
		MCDB	64.1	69.6	73.2	77.8	82.7	87.6	88.7	90.0	85.8	80.3	70.4	67.4
	5%	WB	56.9	61.6	62.3	67.3	72.7	77.2	78.3	78.1	74.8	70.0	62.5	60.7
		MCDB	60.6	67.7	70.0	75.0	81.4	86.6	87.6	87.4	84.6	76.5	67.1	63.9
	10%	WB	53.1	57.7	60.3	65.6	71.2	76.1	77.5	76.9	73.6	67.1	59.3	56.5
		MCDB	56.1	62.1	66.6	73.3	79.7	84.7	86.7	85.3	83.0	74.2	64.2	59.3
(35) Mean Daily Temperature Range	5% DB	MDBR	20.6	21.3	23.5	24.5	21.3	20.5	19.6	20.4	23.0	25.1	24.1	19.4
		MCDBR	23.5	23.2	27.2	26.6	23.5	22.7	21.7	23.4	26.0	28.2	27.5	21.4
		MCWBR	17.1	16.3	15.9	13.0	10.9	10.6	9.1	9.4	10.8	14.2	16.8	15.8
	5% WB	MCDBR	18.2	20.2	22.6	19.8	19.4	20.0	19.4	19.5	20.9	22.3	19.4	18.8
		MCWBR	15.5	14.7	14.6	11.5	10.0	10.1	8.9	8.8	9.6	13.6	14.9	15.7
(40) Clear-Sky Solar Irradiance	taub		0.314	0.321	0.357	0.391	0.427	0.450	0.493	0.493	0.424	0.365	0.332	0.313
	taud		2.512	2.488	2.413	2.310	2.262	2.208	2.128	2.111	2.300	2.442	2.481	2.527
	Ebn at Noon		284	294	290	284	273	266	254	251	265	274	274	277
	Edh at Noon		26	30	35	41	43	46	49	49	39	31	27	24
(44) All-Sky Solar Radiation	RadAvg		777	937	1302	1661	1868	2042	1956	1801	1553	1224	878	665
	RadStd		65	124	117	107	109	121	105	111	118	151	89	66

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page