

TYNDALL AFB, FL, USA

WMO: 747750

Lat: 30.067N

Lon: 85.583W

Elev: 5

StdP: 101.26

Time Zone: -6.00 (NAC)

Period: 94-19

WBAN: 13846

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.3	1.9	-8.8	1.8	2.7	-6.2	2.2	4.7	11.1	16.4	10.2	15.0	3.5	0	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	32.9	25.8	32.3	25.9	31.7	25.8	27.9	30.7	27.3	30.4	26.8	30.1	4.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	29.4	26.4	21.9	29.2	25.9	21.2	28.9	88.4	30.7	86.0	30.4	83.8	30.2	30.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	8.3	7.4	-3.8	35.1	2.4	1.8	-5.5	36.4	-6.9	37.4	-8.3	38.4	-10.0	39.7	
			DB												
			WB	-5.4	28.6	2.3	0.8	-7.1	29.1	-8.4	29.6	-9.7	30.0	-11.4	30.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.5	11.6	13.8	16.4	19.8	23.8	26.8	27.8	27.7	26.2	21.8	16.5	13.6
	DBStd	6.66	5.02	4.56	3.96	3.03	2.39	1.60	1.36	1.29	1.92	3.43	4.09	4.85
	HDD10.0	86	41	16	4	0	0	0	0	0	0	0	3	21
	HDD18.3	702	214	134	82	21	1	0	0	0	0	11	81	158
	CDD10.0	3928	91	123	203	295	428	504	551	550	486	367	199	132
	CDD18.3	1504	5	8	23	66	171	254	292	292	236	120	27	12
	CDH23.3	13787	5	13	55	287	1331	2599	3289	3144	2101	812	126	24
	CDH26.7	4692	0	0	1	21	306	906	1303	1228	733	184	10	0
Wind	WSAvg	3.6	3.9	3.9	4.1	4.0	3.7	3.5	3.2	3.0	3.1	3.3	3.3	3.7
Precipitation	PrecAvg	1352	113	112	131	94	58	118	145	172	142	83	89	94
	PrecMax	1862	439	270	269	252	200	237	254	326	590	222	243	233
	PrecMin	931	36	21	1	20	0	15	46	72	2	15	13	21
	PrecStd	256	88	69	72	68	50	59	57	70	117	54	50	43
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	25.1	26.2	28.6	31.5	33.8	34.3	33.9	33.5	31.5	27.9	25.4
		MCWB	20.4	20.2	20.4	21.6	23.3	25.8	26.3	25.9	24.6	24.2	22.5	21.7
	2%	DB	22.4	23.2	24.9	27.2	30.2	32.3	32.7	32.8	32.3	30.0	26.2	23.9
		MCWB	20.0	19.3	20.0	21.6	23.7	25.9	26.1	26.2	24.8	24.0	21.7	20.9
	5%	DB	21.0	22.1	23.8	26.2	29.3	31.3	32.1	32.3	31.3	28.8	24.9	22.5
		MCWB	19.0	18.7	19.2	21.2	23.7	25.7	26.2	26.2	24.9	23.1	20.7	20.3
	10%	DB	19.4	20.4	22.5	25.1	28.5	30.6	31.3	31.4	30.4	27.5	23.4	21.2
		MCWB	17.6	18.0	18.8	20.9	23.4	25.4	26.0	26.1	24.9	22.5	19.6	19.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.0	21.6	22.7	24.8	26.4	27.8	28.5	28.7	27.7	26.8	24.7	22.9
		MCDB	22.9	23.4	24.6	26.3	28.9	31.0	31.2	31.3	29.6	28.8	26.8	24.2
	2%	WB	20.6	20.7	21.6	23.6	25.5	27.1	27.7	28.0	26.8	25.8	23.0	21.8
		MCDB	21.6	22.2	23.4	25.7	28.4	30.5	30.9	30.8	29.7	28.0	24.9	23.2
	5%	WB	19.3	19.8	20.8	22.8	25.0	26.6	27.2	27.4	26.1	24.8	21.9	20.8
		MCDB	20.4	21.1	22.3	24.9	27.9	30.0	30.5	30.4	29.5	27.3	23.8	22.0
	10%	WB	17.9	18.8	19.8	22.0	24.3	26.1	26.7	26.8	25.6	23.7	20.7	19.7
		MCDB	19.0	20.0	21.5	24.0	27.2	29.4	30.1	30.0	29.0	26.3	22.8	20.8
Mean Daily Temperature Range	5% DB	MDBR	10.1	9.7	9.5	9.3	8.7	7.4	7.2	7.4	8.2	9.9	10.8	9.7
		MCDBR	9.4	9.5	9.6	9.5	9.2	8.2	8.0	8.3	8.9	9.8	10.5	9.4
		MCWBR	7.0	6.6	5.8	5.4	4.6	3.8	3.7	3.8	3.7	5.0	6.5	7.0
	5% WB	MCDBR	8.0	7.8	7.6	7.7	7.8	7.2	7.2	7.2	7.6	7.8	8.9	8.6
		MCWBR	6.6	6.3	5.6	5.4	4.5	3.8	3.8	3.9	3.8	5.1	6.8	7.3
Clear-Sky Solar Irradiance	taub	0.339	0.352	0.368	0.395	0.437	0.467	0.495	0.490	0.436	0.385	0.356	0.344	
	taud	2.531	2.499	2.456	2.380	2.296	2.268	2.204	2.219	2.347	2.470	2.487	2.530	
	Ebn at Noon	895	914	918	899	858	828	803	804	839	865	867	870	
	Edh at Noon	87	98	109	122	133	137	145	142	121	100	91	84	
All-Sky Solar Radiation	RadAvg	3.14	3.80	5.06	6.08	6.72	6.20	5.84	5.44	5.07	4.53	3.54	2.79	
	RadStd	0.24	0.47	0.39	0.50	0.43	0.45	0.38	0.39	0.33	0.38	0.28	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	+0.34	N/A	N/A	N/A	N/A
(47)	Regional (31 neighbors)	+0.45	N/A	N/A	N/A	N/A	N/A	N/A	-95	+159	+101

Nomenclature: See separate page