

HUNTER AAF, GA, USA

WMO: 747804

Lat: 32.017N

Lon: 81.133W

Elev: 13

StdP: 101.17

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13824

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.3	(c) -0.2	(d) -11.3	(e) 1.4	(f) 4.0	(g) -8.8	(h) 1.8	(i) 4.3	(j) 10.5	(k) 10.3	(l) 9.2	(m) 10.8	(n) 2.5	(o) 270	(p) 0.387

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.5	35.2	25.3	34.0	25.2	32.8	25.0	27.6	31.4	26.9	30.9	26.4	30.5	3.8	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.4	29.1	26.0	21.4	28.7	25.2	20.4	28.2	87.2	31.7	84.4	31.0	81.9	30.4	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.6	7.5	6.6	-5.5	37.6	1.8	1.3	-6.8	38.6	-7.9	39.4	-8.9	40.1	-10.2	41.1
			-6.8	28.5	1.8	0.8	-8.1	29.1	-9.1	29.6	-10.1	30.1	-11.4	30.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.9	10.4	12.7	15.7	19.4	23.6	26.8	28.2	27.6	25.4	20.6	15.4	12.3
	DBStd	7.23	5.26	4.90	4.54	3.74	2.94	2.09	1.51	1.59	2.28	3.76	4.57	5.03
	HDD10.0	136	61	26	9	0	0	0	0	0	0	0	8	32
	HDD18.3	882	251	166	104	32	2	0	0	0	0	22	111	194
	CDD10.0	3744	72	101	187	283	423	503	563	546	463	329	169	105
	CDD18.3	1448	3	8	23	64	167	253	305	288	213	93	22	9
	CDH23.3	13099	13	46	163	466	1397	2417	3236	2883	1749	593	106	31
	CDH26.7	5003	0	4	27	106	484	1012	1454	1191	588	126	10	1
Wind	WSAvg	3.0	3.2	3.3	3.5	3.4	3.1	2.9	2.8	2.6	2.8	2.7	2.8	2.9
Precipitation	PrecAvg	1177	78	79	90	74	84	152	142	139	118	95	53	72
	PrecMax	1741	226	255	189	175	223	328	292	331	205	480	127	263
	PrecMin	814	6	8	2	8	22	29	38	59	15	0	0	8
	PrecStd	214	56	50	52	50	59	66	64	55	49	101	43	56
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.1	27.2	29.3	31.9	35.0	36.4	37.0	36.6	34.0	31.2	27.9	26.1
		MCWB	19.3	19.2	19.4	20.9	22.5	25.3	25.2	26.0	24.5	24.3	22.0	21.0
	2%	DB	22.6	24.8	27.2	29.3	32.8	34.8	35.2	34.6	32.4	29.3	26.2	24.0
		MCWB	17.8	18.9	18.8	20.8	22.7	25.2	25.9	25.7	24.4	22.9	20.5	19.7
	5%	DB	20.4	22.6	25.1	27.7	31.0	33.1	34.0	33.0	31.2	28.0	24.3	22.0
		MCWB	16.5	17.2	17.8	20.1	22.6	24.8	25.7	25.6	24.1	21.9	19.4	19.1
	10%	DB	18.7	20.4	23.0	26.2	29.3	31.7	32.7	32.1	30.1	26.9	22.6	20.1
		MCWB	15.9	15.9	17.0	19.2	22.1	24.7	25.6	25.3	24.0	21.4	18.9	17.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.1	22.3	21.9	24.1	25.5	27.9	28.4	28.5	27.2	25.7	24.3	23.0
		MCDB	22.8	24.1	25.6	27.1	30.1	32.0	32.8	31.8	29.8	28.4	25.8	23.6
	2%	WB	19.1	20.1	20.7	22.8	24.6	26.8	27.6	27.5	26.3	24.6	22.3	21.0
		MCDB	21.3	23.3	24.5	26.7	28.9	31.2	31.6	31.2	29.2	27.3	24.1	22.6
	5%	WB	17.9	18.6	19.7	21.7	23.9	26.1	26.9	26.9	25.7	23.9	21.2	19.6
		MCDB	19.6	21.0	22.8	25.6	28.1	30.4	31.3	30.7	28.8	26.4	23.2	21.4
	10%	WB	16.3	17.2	18.6	20.8	23.3	25.5	26.3	26.3	25.2	22.9	19.8	18.1
		MCDB	18.0	19.4	21.7	24.2	27.3	29.8	30.9	30.2	28.4	25.4	22.0	19.9
Mean Daily Temperature Range	5% DB	MDBR	11.5	11.5	11.6	11.5	10.7	9.6	9.5	8.9	8.7	10.4	11.4	10.9
		MCDBR	12.7	12.9	13.3	12.3	12.6	11.6	11.1	10.4	10.1	10.8	11.7	11.3
		MCWBR	8.3	7.8	6.5	5.5	4.8	4.4	4.2	4.1	4.2	5.3	6.8	7.7
	5% WB	MCDBR	10.9	11.2	10.8	10.6	10.1	10.0	10.0	9.4	8.3	8.6	9.2	10.3
		MCWBR	8.4	8.1	6.3	5.6	4.4	4.5	4.3	4.1	4.1	5.2	6.4	7.8
Clear-Sky Solar Irradiance	taub		0.331	0.337	0.370	0.402	0.451	0.494	0.525	0.509	0.429	0.396	0.357	0.346
	taud		2.528	2.512	2.439	2.340	2.238	2.171	2.095	2.142	2.364	2.423	2.487	2.511
	Ebn at Noon		893	923	911	889	844	804	777	785	840	845	854	854
	Edh at Noon		85	95	110	126	141	150	161	152	117	103	88	83
All-Sky Solar Radiation	RadAvg		2.97	3.60	4.74	5.97	6.42	6.36	6.26	5.66	4.79	4.18	3.29	2.62
	RadStd		0.17	0.37	0.43	0.39	0.38	0.48	0.38	0.36	0.41	0.44	0.22	0.21

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.35	N/A	N/A	N/A	N/A	+0.16	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)		+0.57	+0.78	N/A	N/A	N/A	N/A	N/A	-85	+192	+132

Nomenclature: See separate page