

THOMASTON, GA, USA

WMO: 747806

Lat: 32.955N

Lon: 84.264W

Elev: 796

StdP: 14.28

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 63809

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	25.4	28.3	0.2	5.7	38.8	7.1	8.2	42.1	22.3	51.1	19.8	50.0	6.0	320	0.367

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.7	95.3	77.2	93.0	76.5	91.0	75.4	82.0	90.3	80.2	88.0	78.9	86.6	6.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.5	163.2	86.5	78.8	154.2	84.5	76.9	144.5	83.0	46.4	91.9	44.5	89.2	43.1	85.9	97.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	15.5	12.7	18.4	97.4	4.3	3.9	15.3	100.2	12.8	102.5	10.4	104.7	7.3	107.5
			16.1	80.9	4.2	3.2	13.1	83.2	10.7	85.0	8.3	86.8	5.3	89.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.9	46.8	50.1	57.2	63.9	71.9	79.0	81.0	80.4	75.8	65.8	55.5	49.8
	DBStd	14.02	9.64	8.60	8.36	6.77	5.93	4.10	3.08	3.59	4.90	7.23	7.89	8.68
	HDD50	460	179	97	31	4	0	0	0	0	0	2	34	113
	HDD65	2219	565	420	263	97	17	0	0	0	2	80	300	475
	CDD50	5885	80	101	255	422	678	871	962	943	775	492	198	108
	CDD65	2169	1	4	22	65	230	421	497	478	327	105	14	5
	CDH74	20035	1	16	196	648	2040	4055	4980	4581	2669	756	83	10
	CDH80	8335	0	0	28	132	722	1846	2306	2056	1064	176	5	0
Wind	WSAvg	5.2	6.3	6.2	6.3	5.9	5.1	4.3	3.9	3.8	4.7	4.7	5.2	5.8
Precipitation	PrecAvg	49.2	4.4	4.3	5.7	3.3	2.7	4.3	6.1	3.9	3.8	2.6	3.6	3.8
	PrecMax	63.5	9.3	8.1	12.5	6.6	7.0	8.6	18.7	6.7	12.2	6.6	10.5	8.5
	PrecMin	39.1	2.1	0.8	0.5	1.0	0.5	1.3	2.3	1.9	1.0	0.1	0.8	1.9
	PrecStd	7.9	1.7	1.8	2.9	1.6	1.5	2.0	4.0	1.4	2.5	1.7	2.5	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.5	77.0	83.6	88.0	92.5	98.7	97.4	99.1	94.7	88.3	80.9	75.0
		MCWB	61.8	62.6	65.1	71.5	72.0	79.7	80.0	74.6	71.0	70.8	66.8	65.5
	2%	DB	69.8	72.3	79.3	82.5	89.9	95.0	94.8	94.8	91.0	84.2	76.6	71.8
		MCWB	60.7	60.7	63.3	66.6	72.0	77.9	78.6	77.1	72.6	68.5	65.1	63.7
	5%	DB	64.4	68.2	75.1	81.2	87.7	91.4	92.5	91.4	89.7	81.4	72.6	68.1
		MCWB	59.0	58.2	62.0	64.6	71.4	75.3	77.7	76.6	72.7	66.8	63.3	63.0
	10%	DB	62.8	64.1	72.1	78.7	84.0	90.0	90.5	90.1	86.4	78.9	69.9	64.0
		MCWB	57.4	56.8	60.5	63.0	69.8	74.5	76.2	75.9	71.9	65.9	62.1	58.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.9	67.4	69.9	75.1	78.6	90.4	87.5	83.9	79.0	75.5	73.3	71.2
		MCDB	69.7	71.5	75.5	83.2	86.7	92.7	89.8	91.2	85.4	81.4	75.7	72.0
	2%	WB	63.9	63.9	67.8	71.0	76.0	81.1	81.7	81.7	77.6	73.4	69.9	66.4
		MCDB	65.2	66.9	75.4	79.2	84.1	88.3	90.7	89.5	85.3	78.0	72.1	68.9
	5%	WB	61.1	61.4	65.6	68.9	74.1	78.9	80.0	80.1	76.4	71.7	66.1	63.5
		MCDB	63.8	66.3	71.8	76.5	82.6	87.2	88.7	86.8	83.6	76.8	71.0	66.1
	10%	WB	57.5	58.9	63.2	66.8	72.3	77.2	78.6	78.7	74.9	69.4	63.3	59.8
		MCDB	61.1	64.2	68.5	74.2	80.5	85.8	87.0	85.3	81.3	74.7	66.9	63.8
Mean Daily Temperature Range	5% DB	MDBR	19.4	19.8	21.7	22.7	21.1	19.2	18.7	17.8	18.8	20.5	21.5	18.9
		MCDBR	22.1	23.0	25.2	25.9	23.9	22.1	21.0	20.3	22.5	22.9	24.0	20.9
		MCWBR	15.5	14.0	12.5	12.6	9.8	9.2	7.9	8.4	8.1	11.1	14.2	14.4
	5% WB	MCDBR	18.1	18.8	21.7	21.4	19.9	18.8	19.3	17.7	17.1	16.9	19.6	18.1
		MCWBR	15.4	14.3	13.5	13.8	10.9	10.4	9.1	9.2	9.0	11.3	14.9	15.4
Clear-Sky Solar Irradiance	taub	0.316	0.320	0.348	0.384	0.430	0.470	0.509	0.513	0.418	0.368	0.341	0.318	
	taud	2.528	2.510	2.455	2.339	2.252	2.197	2.098	2.074	2.327	2.452	2.472	2.538	
	Ebn at Noon	287	297	295	287	273	261	250	247	269	276	274	280	
	Edh at Noon	27	30	34	40	44	46	51	51	38	31	28	25	
All-Sky Solar Radiation	RadAvg	889	1072	1418	1774	1962	1950	1900	1727	1514	1295	988	759	
	RadStd	47	126	117	121	156	156	117	98	146	159	89	79	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)		+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+281	+193

Nomenclature: See separate page