

LAGRANGE CALLAWAY, GA, USA

WMO: 747807

Lat: 33.017N

Lon: 85.067W

Elev: 682

StdP: 14.34

Time Zone: -5.00 (NAE)

Period: 02-19

WBAN: 03821

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.4	26.0	8.5	8.7	30.2	12.1	10.4	35.3	20.1	45.9	18.3	44.8	2.7	340	0.359

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	20.3	95.1	76.9	93.0	76.1	91.1	76.0	81.4	87.2	80.3	86.5	79.1	85.8	6.0	260

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.2	160.5	83.5	78.9	153.9	83.1	77.4	146.0	82.3	45.6	88.3	44.3	87.1	43.2	85.2	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	13.8	11.7	16.1	98.1	4.4	3.5	12.9	100.6	10.4	102.6	7.9	104.6	4.7	107.1
			15.4	81.8	4.9	1.8	11.8	83.1	8.9	84.1	6.2	85.1	2.6	86.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.1	44.5	48.4	55.7	62.1	70.0	77.5	79.7	79.6	74.4	63.8	52.9	47.5	(6)
	DBStd	14.45	9.75	9.09	8.36	6.76	6.21	3.81	3.18	3.53	5.33	8.06	7.97	8.92	(7)
	HDD50	625	229	127	42	5	0	0	0	0	0	6	55	161	(8)
	HDD65	2610	637	468	303	132	30	0	0	0	4	120	372	544	(9)
	CDD50	5405	58	84	218	367	619	826	922	919	733	433	142	84	(10)
	CDD65	1915	1	5	14	44	183	376	457	454	287	82	9	3	(11)
	CDH74	18275	3	24	178	590	1848	3672	4443	4278	2455	713	64	7	(12)
	CDH80	7854	0	1	21	107	652	1707	2118	2041	1011	189	7	0	(13)
(14) Wind	WSAvg	3.8	4.6	4.9	5.0	4.6	3.7	3.1	2.9	2.7	2.9	3.3	3.6	4.1	(14)
(15) Precipitation	PrecAvg	52.9	5.1	5.0	6.1	4.1	3.9	4.2	5.0	3.8	3.7	3.3	4.6	4.4	(15)
	PrecMax	66.7	9.7	8.5	10.9	7.3	12.2	8.8	13.8	6.9	7.3	10.0	12.0	10.0	(16)
	PrecMin	31.8	2.4	1.7	1.3	1.9	0.7	1.4	1.7	1.6	0.8	0.5	1.5	1.3	(17)
	PrecStd	8.6	1.8	1.8	2.5	1.4	2.5	2.3	2.8	1.4	1.9	2.6	2.4	1.8	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.3	78.0	82.2	86.0	91.8	96.9	97.3	98.8	95.0	89.3	80.6	75.1	(19)
		MCWB	64.6	66.7	64.7	70.1	73.2	76.6	78.4	77.0	73.9	73.6	66.7	67.7	(20)
	2%	DB	68.8	72.2	79.0	82.5	89.4	93.3	94.6	95.0	92.1	84.5	75.1	71.2	(21)
		MCWB	62.2	63.5	64.7	67.1	72.7	75.8	77.9	77.0	74.4	70.8	65.9	66.0	(22)
	5%	DB	64.6	68.4	75.1	81.0	86.5	91.3	92.3	92.6	89.6	81.5	72.1	67.1	(23)
		MCWB	60.3	61.9	62.6	66.0	71.8	75.5	77.3	76.5	74.3	68.8	63.7	63.2	(24)
	10%	DB	61.4	64.7	72.0	77.7	83.9	89.7	90.3	90.4	86.4	78.3	68.6	63.7	(25)
		MCWB	56.3	57.9	61.0	64.3	71.1	75.3	77.0	76.6	74.1	67.4	61.6	60.0	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.6	69.4	70.6	75.5	78.2	82.3	83.3	82.4	80.5	77.1	73.8	71.4	(27)
		MCDB	70.5	72.7	75.2	81.7	84.2	89.5	92.1	87.8	86.7	80.9	74.9	72.5	(28)
	2%	WB	64.8	67.0	68.4	71.7	76.1	80.3	81.5	81.1	78.7	74.7	70.1	67.7	(29)
		MCDB	67.3	70.3	73.9	76.9	82.9	87.1	87.8	86.5	85.4	80.0	72.4	70.2	(30)
	5%	WB	62.6	64.3	66.0	69.5	74.7	78.8	80.2	79.9	77.1	72.8	66.7	64.5	(31)
		MCDB	64.6	67.3	72.3	76.2	81.8	86.1	86.6	86.2	83.2	78.2	70.5	66.1	(32)
	10%	WB	57.7	60.8	63.5	67.3	73.3	77.5	79.0	78.8	75.5	70.8	63.4	61.1	(33)
		MCDB	59.8	63.6	69.2	74.5	80.6	85.4	85.7	85.8	81.9	75.9	66.8	63.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	21.8	22.5	24.5	26.0	23.7	21.7	20.3	20.2	21.1	23.6	24.9	21.2	(35)
		MCDBR	24.7	25.0	28.2	29.2	26.8	25.5	23.3	24.1	24.8	26.9	27.3	22.9	(36)
		MCWBR	17.6	16.5	15.0	14.4	11.5	9.7	8.7	8.7	9.1	12.8	16.7	17.4	(37)
	5% WB	MCDBR	20.1	19.5	23.0	22.0	21.1	21.0	20.5	20.1	19.4	19.0	20.0	19.4	(38)
		MCWBR	16.8	15.7	14.7	13.0	10.4	9.4	9.1	8.6	8.6	10.5	14.9	16.9	(39)
(40) Clear-Sky Solar Irradiance	taub		0.319	0.322	0.354	0.387	0.447	0.480	0.522	0.524	0.423	0.371	0.344	0.323	(40)
	taud		2.524	2.509	2.443	2.333	2.207	2.169	2.062	2.045	2.319	2.450	2.465	2.527	(41)
	Ebn at Noon		286	296	293	286	269	259	247	244	267	275	273	278	(42)
	Edh at Noon		27	30	35	40	46	48	53	53	39	31	28	25	(43)
(44) All-Sky Solar Radiation	RadAvg		874	1052	1403	1768	1950	1944	1893	1731	1517	1292	977	746	(44)
	RadStd		51	128	121	120	158	156	127	102	141	165	94	79	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (47 neighbors)	+0.83	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+281	+191

Nomenclature: See separate page