

MOODY AFB, GA, USA

WMO: 747810

Lat: 30.967N

Lon: 83.200W

Elev: 71

StdP: 100.47

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 13857

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.0	(c) 0.1	(d) -11.1	(e) 1.5	(f) 2.8	(g) -8.2	(h) 1.9	(i) 4.4	(j) 9.6	(k) 14.5	(l) 8.6	(m) 12.7	(n) 2.4	(o) 310	(p) 0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.4	35.4	24.7	34.4	24.6	33.6	24.4	26.9	32.0	26.2	31.6	25.7	30.8	3.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	21.0	28.9	24.9	20.2	28.2	24.3	19.4	27.6	84.4	32.1	81.4	31.6	79.1	31.0	30.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
8.1	7.1	5.8	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			-5.6	36.9	3.1	1.2	-7.8	37.8	-9.6	38.5	-11.3	39.2	-13.5	40.1
			-7.0	27.9	2.8	1.2	-9.0	28.8	-10.6	29.5	-12.2	30.2	-14.3	31.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.2	11.0	13.5	16.2	19.8	24.0	27.0	27.9	27.7	25.5	20.9	15.3	13.1		
	DBStd	7.01	5.23	5.10	4.44	3.40	2.78	1.98	1.53	1.56	2.22	3.76	4.36	5.08		
	HDD10.0	116	52	23	8	0	0	0	0	0	0	0	7	27		
	HDD18.3	802	233	146	92	24	2	0	0	0	0	21	111	174		
	CDD10.0	3834	82	121	199	294	436	509	556	547	465	337	166	123		
	CDD18.3	1477	4	11	26	68	179	259	297	289	215	98	19	12		
	CDH23.3	13827	23	74	228	661	1751	2551	3030	2804	1792	732	128	53		
	CDH26.7	5878	0	6	34	183	742	1222	1451	1289	737	197	16	2		
(14) Wind	WSAvg	2.6	2.9	2.9	3.0	2.9	2.6	2.4	2.3	2.2	2.2	2.5	2.5	2.6		
(15) Precipitation	PrecAvg	1198	99	101	106	93	76	139	142	137	100	71	60	82		
	PrecMax	1734	466	210	278	243	147	288	219	234	375	271	146	155		
	PrecMin	916	10	20	0	17	14	30	77	41	21	1	4	30		
	PrecStd	216	88	47	65	56	33	70	35	46	81	63	40	31		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.8	27.6	29.2	31.7	35.2	36.9	36.3	36.3	34.9	31.9	28.6	26.7		
		MCWB	19.2	19.4	19.1	20.8	22.2	23.6	24.9	25.5	24.0	24.1	20.9	20.0		
	2%	DB	23.6	25.6	27.7	30.2	33.4	35.2	35.1	34.8	33.2	30.2	26.5	25.0		
		MCWB	17.7	18.7	18.8	20.0	22.1	24.3	25.1	25.4	23.8	22.6	19.8	19.1		
	5%	DB	21.5	23.9	26.0	28.9	32.1	34.0	34.1	33.8	32.2	28.9	24.8	22.9		
		MCWB	17.0	17.5	17.8	19.6	21.8	24.4	24.9	25.1	23.7	21.7	18.6	18.7		
	10%	DB	19.3	21.9	24.2	27.4	30.8	32.7	33.0	32.6	31.0	27.5	22.8	21.1		
		MCWB	15.6	16.8	16.9	18.8	21.5	24.2	24.9	24.9	23.5	20.8	18.2	18.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.8	21.3	21.8	23.0	25.0	27.3	28.0	28.1	26.3	25.5	23.3	22.1		
		MCDB	22.6	24.4	25.8	27.5	30.4	32.4	32.1	33.3	30.7	29.0	26.1	24.1		
	2%	WB	19.3	20.1	20.5	22.0	24.1	26.3	26.7	26.9	25.6	24.5	21.9	20.9		
		MCDB	22.0	23.3	24.3	26.7	29.4	32.3	32.0	32.0	30.2	27.8	24.0	22.6		
	5%	WB	18.0	19.1	19.6	21.2	23.5	25.5	26.1	26.2	25.1	23.6	20.5	19.8		
		MCDB	20.3	22.3	23.4	25.8	28.6	31.2	31.6	31.3	29.6	26.6	23.1	21.8		
	10%	WB	16.7	18.0	18.6	20.5	22.8	25.0	25.6	25.6	24.5	22.7	19.0	18.6		
		MCDB	19.1	20.8	22.7	24.9	27.9	30.3	30.9	30.4	28.7	25.6	22.0	21.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.8	12.0	12.6	12.7	12.2	10.9	10.4	10.0	10.1	11.5	12.3	11.1		
		MCDBR	13.3	13.0	14.0	14.3	13.5	12.5	11.5	11.2	11.6	11.7	13.2	11.9		
	5% WB	MCWBR	8.2	7.0	6.5	5.7	4.4	4.0	3.7	3.8	4.0	5.1	7.0	7.0		
		MCWBR	11.2	10.8	11.3	11.7	11.2	10.9	10.4	10.1	9.7	9.5	10.1	9.8		
(40) Clear-Sky Solar Irradiance	taub		0.327	0.334	0.360	0.387	0.426	0.472	0.509	0.495	0.430	0.377	0.347	0.331		
	taud		2.518	2.497	2.445	2.355	2.287	2.219	2.119	2.159	2.333	2.453	2.485	2.530		
	Ebn at Noon		904	929	924	905	867	823	791	798	842	869	872	879		
	Edh at Noon		87	97	110	125	134	143	158	150	121	101	90	83		
(44) All-Sky Solar Radiation	RadAvg		3.08	3.68	4.84	5.89	6.45	6.02	6.02	5.46	4.89	4.30	3.43	2.71		
	RadStd		0.20	0.43	0.41	0.45	0.40	0.41	0.36	0.36	0.40	0.39	0.24	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	+0.21	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)		+0.50	N/A	N/A	N/A	N/A	N/A	-22	-79	+168	+115

Nomenclature: See separate page