

JACKSONVILLE CRAIG, FL, USA

WMO: 747820

Lat: 30.336N

Lon: 81.515W

Elev: 13

StdP: 101.17

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 53860

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 0.5	(c) 2.4	(d) -8.6	(e) 1.8	(f) 5.3	(g) -6.0	(h) 2.3	(i) 6.4	(j) 10.1	(k) 14.6	(l) 9.1	(m) 12.9	(n) 2.5	(o) 340	(p) 0.383

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.1	(c) 34.7	(d) 24.9	(e) 33.5	(f) 24.8	(g) 32.5	(h) 24.7	(i) 26.7	(j) 31.2	(k) 26.2	(l) 30.7	(m) 25.8	(n) 30.1	(o) 3.9	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.7	21.0	28.3	25.1	20.2	28.0	24.6	19.6	27.8	82.7	31.0	81.1	30.7	79.3	30.3	30.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 8.6	(b) 7.8	(c) 7.1	(e) -2.7	(f) 36.4	(g) 1.6	(h) 1.1	(i) -3.9	(j) 37.2	(k) -4.8	(l) 37.8	(m) -5.7	(n) 38.4	(o) -6.9	(p) 39.2		
(4) 8.6	(5) 7.8	(6) 7.1	(7) -2.7	(8) 36.4	(9) 1.6	(10) 1.1	(11) -3.9	(12) 37.2	(13) -4.8	(14) 37.8	(15) -5.7	(16) 38.4	(17) -6.9	(18) 39.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.0	12.6	14.5	16.9	20.4	23.9	26.9	27.9	27.7	26.2	22.4	17.5	14.6		
	DBStd	6.42	5.04	4.78	4.21	3.35	2.61	1.88	1.49	1.43	1.77	3.39	4.18	4.93		
	HDD10.0	65	32	13	4	0	0	0	0	0	0	0	2	14		
	HDD18.3	609	185	122	76	18	1	0	0	0	0	8	63	136		
	CDD10.0	4079	113	139	218	312	431	506	554	549	484	386	228	157		
	CDD18.3	1582	9	15	32	81	173	256	296	291	234	136	39	19		
	CDH23.3	14008	38	86	212	573	1453	2405	3069	2944	2050	914	184	79		
	CDH26.7	4942	2	8	33	133	486	951	1302	1157	652	193	21	5		
(14) Wind	WSAvg	3.1	3.3	3.3	3.5	3.4	3.2	2.9	2.7	2.6	2.9	3.0	3.0	3.1		
(15) Precipitation	PrecAvg	1278	78	69	83	67	73	173	154	168	184	115	50	63		
	PrecMax	1835	205	240	225	187	317	515	356	392	356	278	121	221		
	PrecMin	742	8	16	11	15	12	50	52	60	73	6	1	10		
	PrecStd	259	51	48	51	42	67	96	63	82	82	82	32	52		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.7	27.9	29.4	31.8	34.1	36.3	36.1	35.7	33.7	31.4	28.8	27.4		
		MCWB	19.9	20.0	19.9	21.0	22.5	24.9	25.2	25.2	24.1	24.1	22.4	21.6		
	2%	DB	24.2	26.1	27.5	29.8	32.5	34.2	34.3	33.9	32.3	29.8	27.1	25.8		
		MCWB	18.9	19.4	19.7	20.8	22.3	24.7	25.3	25.5	24.1	23.6	21.3	20.6		
	5%	DB	22.5	23.9	25.9	28.0	31.1	32.7	33.1	32.7	31.1	28.7	25.6	23.7		
		MCWB	18.2	18.4	18.7	20.3	22.3	24.6	25.1	25.4	24.2	23.0	20.5	19.9		
	10%	DB	20.9	22.1	24.0	26.8	29.3	31.3	32.3	31.8	30.1	27.6	23.9	22.1		
		MCWB	17.3	17.7	17.8	19.7	22.1	24.4	25.2	25.4	24.1	22.4	19.7	19.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.3	21.6	22.5	23.4	25.1	26.8	27.3	27.4	26.4	25.7	24.1	22.7		
		MCDB	24.0	25.2	26.4	28.0	29.6	32.1	31.5	31.5	29.7	28.8	27.0	25.5		
	2%	WB	20.2	20.6	20.9	22.6	24.2	26.0	26.6	26.7	25.7	25.0	22.8	21.7		
		MCDB	23.1	24.2	25.3	26.9	28.6	31.2	31.2	31.1	29.3	28.0	25.2	24.3		
	5%	WB	19.0	19.6	20.0	21.8	23.7	25.5	26.1	26.2	25.4	24.4	21.8	20.6		
		MCDB	21.8	22.9	23.9	26.0	28.1	30.5	30.8	30.6	29.0	27.3	24.1	23.0		
	10%	WB	17.8	18.4	19.1	21.0	23.1	25.0	25.7	25.8	25.0	23.7	20.7	19.4		
		MCDB	20.0	21.3	22.6	25.2	27.4	29.7	30.3	30.0	28.6	26.5	23.3	21.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	10.7	10.9	10.8	10.3	9.1	9.1	8.3	7.5	8.7	10.1	10.0		
		MCDBR	11.9	12.1	12.6	12.0	12.0	10.8	10.1	9.5	9.2	9.0	10.4	10.4		
	5% WB	MCWBR	7.3	6.5	6.1	5.3	4.4	3.8	3.6	3.5	3.6	4.1	5.6	6.2		
		MCWBR	10.3	10.4	10.7	10.5	10.0	9.6	9.2	8.6	7.6	7.2	8.3	9.2		
(40) Clear-Sky Solar Irradiance	taub		0.338	0.349	0.372	0.396	0.437	0.480	0.505	0.489	0.428	0.401	0.361	0.346		
	taud		2.534	2.508	2.455	2.373	2.298	2.238	2.173	2.221	2.391	2.430	2.493	2.536		
	Ebn at Noon		895	916	914	898	858	817	795	804	846	847	860	866		
	Edh at Noon		87	97	109	123	133	141	150	141	115	104	90	83		
(44) All-Sky Solar Radiation	RadAvg		3.11	3.73	4.88	5.96	6.39	5.96	5.93	5.52	4.74	4.18	3.38	2.80		
	RadStd		0.22	0.42	0.45	0.36	0.38	0.40	0.38	0.35	0.39	0.36	0.19	0.24		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.54	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+171	+133
(47) Regional (33 neighbors)		+0.43	N/A	N/A	N/A	N/A	N/A	-11	-64	+160	+113

Nomenclature: See separate page