

GEORGETOWN, SC, USA

WMO: 747918

Lat: 33.317N

Lon: 79.317W

Elev: 12

StdP: 101.18

Time Zone: -5.00 (NAE)

Period: 09-19

WBAN: 00391

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.8	(c) -2.2	(d) -12.5	(e) 1.3	(f) 0.0	(g) -9.9	(h) 1.6	(i) 2.5	(j) 9.8	(k) 14.4	(l) 8.5	(m) 12.7	(n) 1.6	(o) 320	(p) 0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 9.3	(c) 33.0	(d) 25.3	(e) 32.5	(f) 25.3	(g) 31.4	(h) 25.0	(i) 27.4	(j) 30.1	(k) 27.0	(l) 29.6	(m) 26.3	(n) 28.8	(o) 3.7	(p) 250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.7	28.7	26.2	21.7	28.1	25.9	21.3	27.8	86.2	30.3	84.1	30.2	82.2	29.4	31.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.3	(b) 7.4	(c) 6.4	(e) -6.7	(f) 35.6	(g) 2.4	(h) 1.2	(i) -8.5	(j) 36.5	(k) -9.8	(l) 37.2	(m) -11.2	(n) 37.8	(o) -12.9	(p) 38.7		
			DB		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	7.4	10.1	12.7	17.5	21.7	25.3	26.7	26.1	24.1	18.8	12.5	10.4	(6)
(7)		DBStd	7.75	5.62	5.05	4.95	3.90	2.99	2.30	1.64	1.69	2.20	4.07	4.18	5.38	(7)
(8)		HDD10.0	291	121	58	30	1	0	0	0	0	0	1	19	62	(8)
(9)		HDD18.3	1302	339	234	183	62	8	0	0	0	0	45	180	251	(9)
(10)		CDD10.0	3144	41	59	114	226	363	459	517	501	422	273	95	76	(10)
(11)		CDD18.3	1114	1	2	9	36	113	210	258	242	172	59	6	6	(11)
(12)		CDH23.3	9152	7	18	74	253	846	1822	2418	2053	1238	385	27	11	(12)
(13)		CDH26.7	3038	0	0	8	32	229	668	947	719	374	59	1	0	(13)
(14)	Wind	WSAvg	2.6	2.6	3.0	3.2	3.3	2.8	2.5	2.4	2.0	2.3	2.4	2.4	2.5	(14)
(15)	Precipitation	PrecAvg	1410	106	89	108	68	102	149	178	178	150	109	70	91	(15)
(16)		PrecMax	1887	272	318	324	203	242	304	398	495	440	334	297	263	(16)
(17)		PrecMin	929	9	15	21	1	16	36	3	25	15	0	0	19	(17)
(18)		PrecStd	267	59	61	61	52	63	64	87	115	111	94	58	54	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	25.9	27.7	29.0	33.0	35.1	35.2	34.1	32.4	30.2	26.3	25.0	(19)
(20)			MCWB	19.0	18.5	18.2	19.9	22.4	26.2	25.0	26.4	24.5	24.3	20.8	20.9	(20)
(21)		2%	DB	21.3	22.9	25.3	27.5	31.0	32.9	33.0	32.5	31.2	27.8	23.7	22.5	(21)
(22)			MCWB	18.0	17.6	17.7	20.4	22.5	25.2	25.5	25.8	24.4	22.9	19.4	19.3	(22)
(23)		5%	DB	18.7	21.2	22.8	26.2	28.9	32.2	32.4	31.4	30.1	27.2	22.2	21.1	(23)
(24)			MCWB	16.3	17.0	16.8	19.9	22.7	24.9	25.6	25.5	24.3	22.2	18.8	19.0	(24)
(25)		10%	DB	17.1	18.7	21.2	24.9	27.5	30.9	31.3	30.8	28.9	25.9	20.5	19.1	(25)
(26)			MCWB	15.0	16.1	16.3	19.2	22.3	24.6	25.5	25.5	24.1	21.4	17.5	17.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.1	21.0	20.8	23.9	26.4	28.5	28.2	27.9	27.2	26.2	22.8	21.8	(27)
(28)			MCDWB	22.0	22.2	23.7	26.5	27.9	32.6	32.0	31.0	28.8	27.3	25.0	24.2	(28)
(29)		2%	WB	18.9	19.4	19.4	22.7	25.5	27.1	27.4	27.3	26.3	25.1	21.1	20.9	(29)
(30)			MCDWB	21.2	22.3	22.9	25.4	27.3	30.1	30.5	29.7	28.2	26.4	22.3	21.8	(30)
(31)		5%	WB	17.4	17.8	18.2	21.6	24.1	26.1	26.9	26.9	25.7	23.9	19.7	19.0	(31)
(32)			MCDWB	18.0	19.7	21.3	24.4	27.6	29.0	29.9	29.2	27.8	26.2	21.2	20.4	(32)
(33)		10%	WB	15.3	16.3	17.3	20.6	23.0	25.3	26.2	26.2	25.0	22.6	18.1	17.4	(33)
(34)			MCDWB	16.4	18.6	19.7	23.0	26.0	28.6	29.1	28.5	27.5	24.8	19.8	18.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.0	11.7	11.9	11.9	10.7	9.7	9.3	8.6	9.4	11.2	11.9	10.5	(35)
(36)			MCDBR	13.5	13.7	14.0	12.9	12.6	11.0	10.4	9.5	10.5	10.8	12.9	10.7	(36)
(37)			MCWBR	9.8	8.6	7.5	6.8	5.8	4.7	4.6	4.4	5.0	6.1	8.5	7.6	(37)
(38)		5% WB	MCDBR	11.1	12.0	11.6	10.1	10.3	9.7	9.3	8.5	8.6	8.4	9.8	9.7	(38)
(39)			MCWBR	9.4	9.2	7.1	6.3	6.4	5.1	5.0	4.7	5.0	5.3	7.5	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.329	0.336	0.366	0.402	0.469	0.487	0.533	0.509	0.433	0.393	0.349	0.330	(40)	
(41)		taud	2.525	2.503	2.441	2.319	2.187	2.184	2.069	2.133	2.339	2.427	2.504	2.551	(41)	
(42)		Ebn at Noon	888	917	911	887	828	809	769	783	832	842	855	866	(42)	
(43)		Edh at Noon	84	95	109	128	148	148	165	153	119	101	85	78	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.78	3.44	4.60	5.89	6.37	6.50	6.21	5.58	4.76	4.04	3.10	2.48	(44)	
(45)		RadStd	0.17	0.35	0.42	0.40	0.45	0.45	0.38	0.31	0.39	0.44	0.23	0.19	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (42 neighbors)		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+192	+136

Nomenclature: See separate page