

CAPE KENNEDY AFS SKID STRIP, FL, USA

WMO: 747940

Lat: 28.468N

Lon: 80.567W

Elev: 10

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 12868

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 39.4	(c) 44.3	(d) 21.6	(e) 16.3	(f) 47.4	(g) 28.4	(h) 22.4	(i) 50.4	(j) 24.5	(k) 60.3	(l) 21.7	(m) 58.1	(n) 7.3	(o) 320	(p) 0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 13.9	(c) 91.8	(d) 79.2	(e) 90.5	(f) 78.9	(g) 89.5	(h) 78.7	(i) 81.7	(j) 88.2	(k) 81.0	(l) 87.3	(m) 80.2	(n) 86.5	(o) 10.0	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.1	156.3	84.5	79.3	151.9	84.1	78.7	148.9	83.8	45.3	88.8	44.4	87.1	43.6	86.8	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 19.6	(b) 17.7	(c) 16.2	(e) 34.1	(f) 95.6	(g) 3.9	(h) 1.9	(i) 31.3	(j) 97.0	(k) 29.1	(l) 98.1	(m) 26.9	(n) 99.2	(o) 24.1	(p) 100.5		
(a) 19.6	(b) 17.7	(c) 16.2	(e) 29.9	(f) 83.0	(g) 2.9	(h) 1.6	(i) 27.8	(j) 84.2	(k) 26.1	(l) 85.1	(m) 24.5	(n) 86.0	(o) 22.3	(p) 87.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	73.3	61.8	64.0	66.7	72.1	76.4	80.5	81.8	82.3	80.9	76.6	69.4	66.1	(6)
(7)		DBStd	8.90	7.81	7.57	6.64	4.53	3.31	2.43	2.29	1.74	2.15	5.05	6.22	7.81	(7)
(8)		HDD50	22	12	5	0	0	0	0	0	0	0	0	0	5	(8)
(9)		HDD65	443	152	100	63	6	0	0	0	0	0	5	31	86	(9)
(10)		CDD50	8511	378	396	518	664	817	914	987	1002	926	823	583	503	(10)
(11)		CDD65	3458	53	72	115	220	352	464	522	537	476	363	165	119	(11)
(12)		CDH74	29539	176	302	539	1336	2701	4500	5469	5661	4707	2959	776	413	(12)
(13)		CDH80	9242	10	29	72	210	668	1610	2155	2135	1537	690	99	27	(13)
(14)	Wind	WSAvg	7.6	8.3	8.0	8.7	8.8	8.3	7.0	6.4	6.5	6.4	7.9	7.7	7.7	(14)
(15)	Precipitation	PrecAvg	52.1	2.3	2.1	3.0	2.4	3.5	7.1	6.7	7.5	6.9	5.1	2.1	2.3	(15)
(16)		PrecMax	71.0	5.6	7.1	12.2	5.6	11.9	14.3	11.0	20.5	13.6	12.2	8.1	9.3	(16)
(17)		PrecMin	37.8	0.0	0.1	0.0	0.6	0.8	0.6	2.6	1.9	3.7	0.9	0.2	0.5	(17)
(18)		PrecStd	9.1	1.3	1.5	2.9	1.3	2.4	2.9	2.5	3.5	2.6	2.9	1.8	2.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.4	83.4	86.1	87.2	90.7	92.9	93.5	93.6	92.8	89.2	86.8	82.5	(19)
(20)			MCWB	72.2	71.7	70.4	73.5	74.6	78.4	79.0	81.0	80.7	78.2	78.0	73.5	(20)
(21)		2%	DB	78.3	80.3	81.7	84.2	87.9	90.6	91.7	91.3	89.8	87.0	82.5	80.5	(21)
(22)			MCWB	69.7	71.3	70.7	72.4	74.3	77.8	78.8	80.4	79.3	77.2	73.7	72.5	(22)
(23)		5%	DB	75.5	77.8	79.2	82.2	85.5	89.0	90.3	90.2	88.2	85.7	80.6	78.6	(23)
(24)			MCWB	68.2	69.6	69.4	71.5	73.8	77.3	78.8	79.9	78.6	76.6	71.9	71.2	(24)
(25)		10%	DB	72.9	75.0	77.0	80.9	83.6	87.6	88.8	88.7	86.7	83.9	78.4	76.5	(25)
(26)			MCWB	67.2	67.5	67.8	70.6	73.2	76.3	78.7	79.4	78.0	75.4	70.4	70.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.8	75.6	74.2	77.0	79.0	81.5	82.4	83.1	82.6	80.3	79.2	75.9	(27)
(28)			MCDWB	78.6	79.6	79.7	83.5	84.0	88.6	89.5	90.0	88.8	85.1	85.5	80.3	(28)
(29)		2%	WB	71.7	72.7	72.4	75.3	77.2	80.3	81.2	81.9	81.2	79.1	76.2	74.3	(29)
(30)			MCDWB	76.0	77.8	78.5	80.9	83.0	87.5	87.7	88.6	86.6	84.1	80.6	78.3	(30)
(31)		5%	WB	70.1	71.0	71.2	73.9	76.0	79.4	80.4	81.1	80.0	78.1	74.1	73.0	(31)
(32)			MCDWB	73.8	75.9	77.5	79.3	82.3	86.6	86.9	87.6	85.4	83.1	78.2	76.4	(32)
(33)		10%	WB	68.6	69.5	69.7	72.7	75.1	78.4	79.6	80.3	79.0	77.1	72.6	71.5	(33)
(34)			MCDWB	72.1	73.7	75.1	78.3	81.4	85.2	86.2	86.5	84.5	82.1	76.8	75.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.5	17.5	17.3	16.0	14.8	14.7	14.5	13.9	12.8	13.4	14.8	15.7	(35)
(36)			MCDBR	17.5	17.9	18.1	16.5	16.9	16.1	15.6	15.6	14.2	13.6	14.6	15.3	(36)
(37)			MCWBR	11.4	11.4	9.5	8.1	7.5	6.9	6.7	7.4	6.7	6.7	8.6	9.6	(37)
(38)		5% WB	MCDWB	16.0	16.4	16.5	14.5	14.9	14.9	14.5	14.3	13.5	12.0	13.2	14.1	(38)
(39)			MCWBR	11.5	11.3	9.3	7.8	7.5	7.2	6.9	7.3	7.0	6.3	8.9	9.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.347	0.360	0.375	0.397	0.429	0.456	0.473	0.464	0.427	0.402	0.366	0.354	(40)	
(41)		taud	2.546	2.522	2.469	2.384	2.338	2.336	2.286	2.328	2.424	2.462	2.515	2.550	(41)	
(42)		Ebn at Noon	284	289	290	285	275	266	261	263	271	271	275	276	(42)	
(43)		Edh at Noon	28	31	35	39	41	41	43	40	36	32	29	27	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1058	1284	1623	1933	1992	1893	1899	1799	1567	1378	1116	961	(44)	
(45)		RadStd	77	79	106	76	137	180	91	106	102	89	61	63	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)		+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-83	+270	+200

Nomenclature: See separate page