

CAPE KENNEDY AFS SKID STRIP, FL, USA

WMO: 747940

Lat: 28.468N

Lon: 80.567W

Elev: 3

StdP: 101.29

Time Zone: -5.00 (NAE)

Period: 07-19

WBAN: 12868

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 4.1	(c) 6.8	(d) -5.8	(e) 2.3	(f) 8.6	(g) -2.0	(h) 3.2	(i) 10.2	(j) 11.0	(k) 15.7	(l) 9.7	(m) 14.5	(n) 3.2	(o) 320	(p) 0.369

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.7	33.2	26.2	32.5	26.1	32.0	25.9	27.6	31.2	27.2	30.7	26.8	30.3	4.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.7	22.3	29.2	26.3	21.7	28.9	25.9	21.3	28.8	87.4	31.6	85.3	30.6	83.5	30.5	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8.8	7.9	7.2	1.2	35.3	2.1	1.1	-0.4	36.1	-1.6	36.7	-2.8	37.3	-4.4	38.1
			-1.2	28.3	1.6	0.9	-2.3	29.0	-3.3	29.5	-4.2	30.0	-5.4	30.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.9	16.5	17.8	19.3	22.3	24.6	26.9	27.7	28.0	27.1	24.8	20.8	18.9	(6)
	DBStd	4.94	4.34	4.20	3.69	2.52	1.84	1.35	1.27	0.97	1.20	2.81	3.46	4.34	(7)
	HDD10.0	12	7	3	0	0	0	0	0	0	0	0	0	3	(8)
	HDD18.3	246	84	56	35	3	0	0	0	0	0	3	17	48	(9)
	CDD10.0	4728	210	220	288	369	454	508	548	557	514	457	324	279	(10)
	CDD18.3	1921	29	40	64	122	196	258	290	298	264	202	92	66	(11)
	CDH23.3	16411	98	168	299	742	1501	2500	3038	3145	2615	1644	431	229	(12)
	CDH26.7	5134	6	16	40	117	371	894	1197	1186	854	383	55	15	(13)
Wind	WSAvg	3.4	3.7	3.6	3.9	3.9	3.7	3.2	2.9	2.9	2.9	3.5	3.5	3.4	(14)
Precipitation	PrecAvg	1324	59	54	77	60	89	180	171	191	174	130	54	59	(15)
	PrecMax	1804	143	180	311	142	302	362	279	520	345	310	206	235	(16)
	PrecMin	961	0	3	0	15	21	14	67	47	94	22	6	12	(17)
	PrecStd	232	34	37	73	33	60	74	63	89	65	74	45	56	(18)
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.5	28.6	30.0	30.7	32.6	33.9	34.1	34.2	33.8	31.8	30.4	28.0	(19)
		MCWB	22.3	22.1	21.4	23.1	23.7	25.8	26.1	27.2	27.1	25.7	25.5	23.0	(20)
	2%	DB	25.7	26.8	27.6	29.0	31.0	32.5	33.1	33.0	32.1	30.6	28.1	26.9	(21)
		MCWB	21.0	21.8	21.5	22.5	23.5	25.5	26.0	26.9	26.3	25.1	23.1	22.5	(22)
	5%	DB	24.1	25.4	26.2	27.9	29.7	31.7	32.4	32.3	31.2	29.8	27.0	25.9	(23)
		MCWB	20.1	20.9	20.8	22.0	23.2	25.2	26.0	26.6	25.9	24.8	22.2	21.8	(24)
	10%	DB	22.7	23.9	25.0	27.1	28.7	30.9	31.6	31.5	30.4	28.8	25.8	24.7	(25)
		MCWB	19.6	19.7	19.9	21.4	22.9	24.6	25.9	26.3	25.6	24.1	21.3	21.2	(26)
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.2	24.2	23.4	25.0	26.1	27.5	28.0	28.4	28.1	26.8	26.2	24.4	(27)
		MCDB	25.9	26.4	26.5	28.6	28.9	31.5	31.9	32.2	31.6	29.5	29.7	26.8	(28)
	2%	WB	22.1	22.6	22.5	24.0	25.1	26.8	27.3	27.7	27.3	26.2	24.5	23.5	(29)
		MCDB	24.5	25.5	25.8	27.2	28.3	30.8	30.9	31.5	30.4	28.9	27.0	25.7	(30)
	5%	WB	21.2	21.7	21.8	23.3	24.5	26.4	26.9	27.3	26.7	25.6	23.4	22.8	(31)
		MCDB	23.2	24.4	25.3	26.3	27.9	30.3	30.5	30.9	29.7	28.4	25.7	24.7	(32)
	10%	WB	20.4	20.8	21.0	22.6	23.9	25.8	26.5	26.8	26.1	25.1	22.5	22.0	(33)
		MCDB	22.3	23.2	23.9	25.7	27.4	29.5	30.1	30.3	29.1	27.8	24.9	24.0	(34)
Mean Daily Temperature Range	5% DB	MDBR	9.2	9.7	9.6	8.9	8.2	8.1	8.1	7.7	7.1	7.5	8.2	8.7	(35)
		MCDBR	9.7	9.9	10.1	9.2	9.4	8.9	8.7	8.7	7.9	7.6	8.1	8.5	(36)
		MCWBR	6.4	6.3	5.3	4.5	4.2	3.8	3.7	4.1	3.7	3.7	4.8	5.3	(37)
	5% WB	MCDBR	8.9	9.1	9.2	8.0	8.3	8.3	8.1	8.0	7.5	6.7	7.4	7.8	(38)
		MCWBR	6.4	6.3	5.2	4.3	4.1	4.0	3.8	4.1	3.9	3.5	4.9	5.3	(39)
Clear-Sky Solar Irradiance	taub	0.347	0.360	0.375	0.397	0.429	0.456	0.473	0.464	0.427	0.402	0.366	0.354	(40)	
	taud	2.546	2.522	2.469	2.384	2.338	2.336	2.286	2.328	2.424	2.462	2.515	2.550	(41)	
	Ebn at Noon	895	912	915	899	867	838	822	829	853	855	866	870	(42)	
	Edh at Noon	88	98	109	122	128	128	134	127	113	102	90	85	(43)	
All-Sky Solar Radiation	RadAvg	3.34	4.05	5.12	6.09	6.28	5.97	5.99	5.67	4.94	4.34	3.52	3.03	(44)	
	RadStd	0.24	0.25	0.34	0.24	0.43	0.57	0.29	0.33	0.32	0.28	0.19	0.20	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
Regional (27 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-46	+150	+111	(47)

Nomenclature: See separate page