

KENNEDY SPACE CENTER, FL, USA

WMO: 747946

Lat: 28.617N

Lon: 80.683W

Elev: 10

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12886

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.3	43.1	26.9	20.9	46.8	31.6	25.9	49.4	22.2	62.6	20.1	64.1	6.5	310	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.1	91.9	78.0	90.5	78.0	89.6	77.9	81.1	87.5	80.1	86.6	79.3	85.7	8.3	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.4	152.4	83.7	78.7	149.1	83.3	77.4	142.6	82.6	44.5	87.5	43.4	86.2	42.7	85.7	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.7	16.7	14.8	DB	33.3	95.7	3.1	2.3	31.1	97.3	29.3	98.7	27.5	100.0	25.3	101.7
			WB	29.9	83.1	3.2	1.5	27.6	84.1	25.8	85.0	24.0	85.8	21.7	86.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	72.4	60.7	63.5	66.3	70.8	75.8	79.8	81.4	81.5	80.1	75.6	69.1	64.3	(6)
	DBStd	9.06	8.12	7.28	6.96	5.25	3.90	2.95	2.44	2.14	2.40	4.70	6.03	7.72	(7)
	HDD50	21	13	4	1	0	0	0	0	0	0	0	0	3	(8)
	HDD65	516	181	104	70	15	0	0	0	0	0	4	32	110	(9)
	CDD50	8215	343	381	507	625	800	895	974	976	902	794	572	446	(10)
	CDD65	3234	46	61	111	190	335	445	509	511	452	333	153	88	(11)
	CDH74	26364	199	283	546	1157	2677	3983	5026	4956	4044	2402	720	371	(12)
	CDH80	8107	16	28	83	203	728	1377	1934	1828	1263	519	93	35	(13)
(14) Wind	WSAvg	6.8	7.3	7.3	8.0	7.7	6.9	6.3	5.9	5.5	5.9	6.9	6.9	6.7	(14)
(15) Precipitation	PrecAvg	50.8	2.6	2.4	3.5	2.4	3.3	7.0	6.3	7.0	6.8	4.5	2.4	2.3	(15)
	PrecMax	71.5	6.1	8.3	14.6	6.8	16.2	12.9	10.6	13.8	13.1	14.8	9.3	10.3	(16)
	PrecMin	36.1	0.5	0.5	0.0	0.1	0.3	1.0	1.4	1.5	3.6	0.7	0.2	0.6	(17)
	PrecStd	9.6	1.5	1.6	3.2	1.5	3.1	2.7	2.6	2.5	2.6	2.9	2.2	2.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.0	83.2	85.6	88.1	91.2	95.0	94.0	93.1	91.4	88.8	85.6	83.0	(19)
		MCWB	71.4	70.8	71.3	73.3	75.4	78.5	78.1	79.2	78.2	78.0	75.1	73.4	(20)
	2%	DB	79.2	80.8	82.2	84.4	88.4	91.2	91.4	91.1	89.9	86.5	82.3	80.9	(21)
		MCWB	69.7	70.6	70.3	71.9	74.8	77.7	78.0	79.1	78.0	77.0	72.7	72.1	(22)
	5%	DB	75.8	78.2	79.6	82.1	86.1	89.3	90.3	90.0	88.1	84.4	80.8	78.6	(23)
		MCWB	67.8	69.4	69.1	71.0	74.2	77.4	77.9	79.0	77.7	75.7	71.7	71.0	(24)
	10%	DB	73.0	74.9	77.0	80.4	83.9	87.1	88.5	88.3	86.4	82.6	78.6	75.3	(25)
		MCWB	66.6	67.2	68.1	70.1	73.5	77.0	77.6	78.5	77.2	74.3	70.5	69.6	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.8	74.6	75.2	76.2	78.8	80.7	82.1	82.3	81.3	80.8	76.5	75.0	(27)
		MCDB	79.0	78.8	80.4	82.3	85.1	88.0	88.5	88.7	87.3	84.9	81.5	80.1	(28)
	2%	WB	71.5	72.6	73.0	74.6	77.3	79.4	80.5	81.1	80.2	78.7	75.2	73.5	(29)
		MCDB	76.0	77.3	78.6	80.9	84.2	86.9	87.5	87.7	85.9	83.7	79.9	78.5	(30)
	5%	WB	69.8	71.0	71.4	73.2	76.1	78.4	79.5	80.2	79.2	77.5	73.9	72.3	(31)
		MCDB	74.3	75.7	77.0	79.4	82.7	85.6	86.6	86.6	84.8	82.8	78.4	76.9	(32)
	10%	WB	67.9	69.3	70.0	72.0	75.2	77.7	78.6	79.3	78.3	76.3	72.5	70.7	(33)
		MCDB	72.3	73.8	75.1	77.7	81.4	84.7	85.4	85.5	84.0	81.2	76.7	74.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	18.3	18.1	17.8	17.1	16.4	14.9	15.1	14.6	13.1	13.7	15.8	16.7	(35)
		MCDBR	19.3	19.2	18.7	17.9	18.3	17.2	16.4	16.0	14.9	14.3	16.0	16.9	(36)
	5% WB	MCWBR	11.2	10.5	9.6	8.4	7.9	7.2	7.0	6.7	6.9	7.4	8.9	9.8	(37)
		MCDWR	17.5	16.7	16.2	15.8	16.1	15.5	15.2	14.7	13.7	12.5	13.8	15.7	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.346	0.359	0.375	0.397	0.428	0.457	0.475	0.466	0.426	0.401	0.365	0.354	(40)
		taud	2.546	2.520	2.468	2.383	2.337	2.331	2.278	2.318	2.422	2.461	2.513	2.547	(41)
	Ebn at Noon	Ebn at Noon	284	289	290	285	275	266	260	262	271	271	275	276	(42)
		Edh at Noon	28	31	35	39	41	41	43	41	36	32	29	27	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1054	1276	1622	1939	2006	1893	1899	1797	1567	1381	1116	959	(44)
	RadStd	RadStd	78	84	112	82	137	180	94	108	103	91	62	67	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
Regional (32 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	-9	-85	+270	+194

Nomenclature: See separate page