

KENNEDY SPACE CENTER, FL, USA

WMO: 747946

Lat: 28.617N

Lon: 80.683W

Elev: 3

StdP: 101.29

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 12886

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.0	6.2	-2.8	3.0	8.2	-0.2	3.7	9.7	9.9	17.0	9.0	17.9	2.9	310	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.4	33.3	25.6	32.5	25.6	32.0	25.5	27.3	30.8	26.7	30.3	26.3	29.8	3.7	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.8	28.7	26.0	21.3	28.5	25.2	20.4	28.1	85.6	30.8	83.1	30.1	81.4	29.8	29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.4	7.5	6.6	DB	0.7	35.4	1.7	1.3	-0.5	36.3	-1.5	37.0	-2.5	37.8	-3.7	38.7	(4)
			WB	-1.1	28.4	1.8	0.8	-2.4	29.0	-3.5	29.4	-4.4	29.9	-5.7	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	22.5	15.9	17.5	19.1	21.6	24.3	26.6	27.5	27.5	26.7	24.2	20.6	17.9	(6)
(7)		DBStd	5.04	4.51	4.04	3.87	2.92	2.17	1.64	1.35	1.19	1.33	2.61	3.35	4.29	(7)
(8)		HDD10.0	12	7	2	1	0	0	0	0	0	0	0	0	2	(8)
(9)		HDD18.3	287	101	58	39	8	0	0	0	0	0	2	18	61	(9)
(10)		CDD10.0	4564	191	212	282	347	444	497	541	542	501	441	318	248	(10)
(11)		CDD18.3	1797	26	34	62	106	186	247	283	284	251	185	85	49	(11)
(12)		CDH23.3	14647	111	157	303	643	1487	2213	2792	2753	2247	1334	400	206	(12)
(13)	CDH26.7	4504	9	16	46	113	404	765	1074	1016	702	288	52	19	(13)	
(14)	Wind	WSAvg	3.0	3.3	3.3	3.6	3.5	3.1	2.8	2.6	2.5	2.7	3.1	3.1	3.0	(14)
(15)	Precipitation	PrecAvg	1290	67	61	88	62	83	177	161	179	173	114	62	59	(15)
(16)		PrecMax	1817	154	210	370	173	411	328	268	351	332	377	237	262	(16)
(17)		PrecMin	917	12	13	0	2	7	25	35	38	92	18	5	14	(17)
(18)		PrecStd	244	38	41	82	38	79	68	65	64	67	74	56	61	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.8	28.5	29.8	31.2	32.9	35.0	34.4	33.9	33.0	31.6	29.8	28.3	(19)
(20)			MCWB	21.9	21.5	21.8	23.0	24.1	25.8	25.6	26.2	25.7	25.6	23.9	23.0	(20)
(21)		2%	DB	26.2	27.1	27.9	29.1	31.3	32.9	33.0	32.8	32.2	30.3	28.0	27.2	(21)
(22)			MCWB	20.9	21.4	21.3	22.1	23.8	25.4	25.6	26.2	25.6	25.0	22.6	22.3	(22)
(23)		5%	DB	24.4	25.7	26.4	27.8	30.1	31.8	32.4	32.2	31.2	29.1	27.1	25.9	(23)
(24)			MCWB	19.9	20.8	20.6	21.7	23.4	25.2	25.5	26.1	25.4	24.3	22.1	21.6	(24)
(25)			10%	DB	22.8	23.8	25.0	26.9	28.9	30.6	31.4	31.3	30.2	28.1	25.9	24.1
(26)	MCWB	19.2		19.6	20.1	21.2	23.0	25.0	25.3	25.8	25.1	23.5	21.4	20.9	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	23.2	23.6	24.0	24.6	26.0	27.0	27.8	28.0	27.4	27.1	24.7	23.9	(27)
(28)			MCDWB	26.1	26.0	26.9	27.9	29.5	31.1	31.4	31.5	30.7	29.4	27.5	26.7	(28)
(29)		2%	WB	22.0	22.6	22.8	23.7	25.2	26.3	26.9	27.3	26.8	26.0	24.0	23.1	(29)
(30)			MCDWB	24.4	25.2	25.9	27.2	29.0	30.5	30.8	31.0	29.9	28.7	26.6	25.9	(30)
(31)		5%	WB	21.0	21.6	21.9	22.9	24.5	25.8	26.4	26.8	26.2	25.3	23.3	22.4	(31)
(32)			MCDWB	23.5	24.3	25.0	26.4	28.1	29.8	30.3	30.3	29.3	28.2	25.8	24.9	(32)
(33)			10%	WB	19.9	20.7	21.1	22.2	24.0	25.4	25.9	26.3	25.7	24.6	22.5	21.5
(34)	MCDWB	22.4		23.2	24.0	25.4	27.4	29.3	29.7	29.7	28.9	27.4	24.8	23.8	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.2	10.1	9.9	9.5	9.1	8.3	8.4	8.1	7.3	7.6	8.8	9.3	(35)
(36)			MCDBR	10.7	10.7	10.4	10.0	10.2	9.6	9.1	8.9	8.3	8.0	8.9	9.4	(36)
(37)			MCWBR	6.2	5.8	5.3	4.7	4.4	4.0	3.9	3.7	3.8	4.1	5.0	5.5	(37)
(38)		5% WB	MCDBR	9.7	9.3	9.0	8.8	9.0	8.6	8.5	8.2	7.6	6.9	7.7	8.7	(38)
(39)			MCWBR	6.2	5.5	5.3	4.5	4.4	4.0	4.1	3.9	3.9	3.9	4.9	5.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.346	0.359	0.375	0.397	0.428	0.457	0.475	0.466	0.426	0.401	0.365	0.354	(40)	
(41)		taud	2.546	2.520	2.468	2.383	2.337	2.331	2.278	2.318	2.422	2.461	2.513	2.547	(41)	
(42)		Ebn at Noon	896	912	915	899	867	837	820	827	853	855	866	869	(42)	
(43)		Edh at Noon	88	98	109	122	128	128	135	129	113	102	90	85	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.32	4.02	5.11	6.11	6.32	5.97	5.99	5.67	4.94	4.35	3.52	3.02	(44)	
(45)		RadStd	0.24	0.26	0.35	0.26	0.43	0.57	0.30	0.34	0.33	0.29	0.20	0.21	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (32 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	-5	-47	+150	+108	(47)

Nomenclature: See separate page