

TEHACHAPI, CA, USA

WMO: 749171

Lat: 35.135N

Lon: 118.439W

Elev: 4001

StdP: 12.69

Time Zone: -8.00 (NAP)

Period: 10-19

WBAN: 00479

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	22.9	26.6	-4.1	5.1	44.5	0.0	6.3	44.7	30.4	39.7	27.2	37.6	3.1	120	0.615

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	27.8	91.4	60.5	90.3	60.2	88.1	59.8	64.4	85.7	63.1	84.4	61.9	83.1	13.7	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.6	79.1	72.4	54.5	73.3	71.3	53.6	71.0	70.6	31.6	86.8	30.6	83.7	29.6	83.7	69.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
25.9	23.2	20.3	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
			DB	15.6	96.2	4.2	2.0	12.6	97.6	10.2	98.8	7.8	100.0	4.8	101.4
			WB	13.6	66.9	3.7	1.7	11.0	68.1	8.8	69.2	6.8	70.1	4.1	71.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.8	42.8	42.2	46.2	50.4	55.6	66.8	72.4	71.5	65.5	55.6	47.0	40.9	(6)
	DBStd	12.81	5.96	7.01	6.07	6.85	7.02	6.77	4.42	4.12	6.35	5.98	7.27	6.47	(7)
	HDD50	1151	232	228	146	78	27	1	0	0	1	15	137	286	(8)
	HDD65	4363	689	638	582	437	299	59	4	3	70	296	539	747	(9)
	CDD50	2914	8	10	29	91	201	506	696	666	465	190	48	4	(10)
	CDD65	652	0	0	0	0	9	114	234	205	84	6	0	0	(11)
	CDH74	10083	0	0	7	46	245	1706	3222	2945	1654	246	12	0	(12)
	CDH80	4013	0	0	0	3	49	651	1403	1235	624	48	0	0	(13)
(14) Wind	WSAvg	9.9	9.8	9.6	10.6	11.8	11.7	11.5	9.3	8.8	8.0	8.7	9.4	10.0	(14)
(15) Precipitation	PrecAvg	12.5	2.5	2.6	1.7	0.9	0.4	0.1	0.1	0.1	0.2	0.6	1.1	2.2	(15)
	PrecMax	22.2	7.1	8.5	6.7	2.0	2.0	0.7	0.5	0.6	0.7	2.3	3.2	6.3	(16)
	PrecMin	7.3	0.4	0.5	0.2	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.6	0.6	(17)
	PrecStd	3.7	1.7	1.7	1.6	0.6	0.5	0.2	0.1	0.2	0.2	0.5	0.8	1.2	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.9	69.7	74.7	78.5	84.4	93.5	93.5	94.9	91.3	84.3	75.3	65.7	(19)
		MCWB	45.8	47.1	51.6	53.9	56.8	62.1	61.9	62.2	59.4	55.7	50.9	43.1	(20)
	2%	DB	63.2	65.9	68.5	74.8	81.1	90.7	91.2	91.2	89.7	81.0	72.4	62.5	(21)
		MCWB	44.1	46.7	49.7	52.4	55.8	60.8	60.9	60.1	59.0	54.0	48.7	43.3	(22)
	5%	DB	59.2	62.5	64.3	72.1	76.6	86.4	90.2	89.9	86.1	75.5	68.2	57.2	(23)
		MCWB	42.5	45.4	48.0	51.5	53.7	59.4	60.7	59.7	58.0	51.1	46.7	42.1	(24)
	10%	DB	55.2	56.6	61.0	66.1	72.6	83.6	87.9	86.2	83.9	72.5	63.3	54.0	(25)
		MCWB	40.9	43.9	45.5	49.6	53.0	58.6	60.2	59.4	57.6	50.2	44.9	40.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.1	52.4	54.7	59.0	59.5	66.5	65.9	65.1	64.1	59.6	52.9	50.4	(27)
		MCDB	57.7	58.2	67.0	72.5	79.5	89.3	86.7	87.7	83.2	74.6	70.4	55.3	(28)
	2%	WB	47.2	49.4	52.4	55.4	57.3	64.2	64.3	63.4	62.0	57.5	50.6	48.3	(29)
		MCDB	54.0	57.4	64.3	68.8	76.5	85.2	85.4	86.7	82.2	73.5	66.8	51.8	(30)
	5%	WB	45.5	47.4	50.2	53.2	55.7	62.2	63.2	62.1	60.3	55.2	48.7	46.3	(31)
		MCDB	51.6	56.9	61.2	66.2	73.0	82.1	84.3	84.8	81.0	68.5	62.5	49.7	(32)
	10%	WB	44.0	45.4	48.2	51.2	54.0	60.0	62.0	60.6	58.9	53.2	46.8	44.4	(33)
		MCDB	51.7	54.3	58.2	63.5	69.6	79.3	83.2	82.9	79.6	66.0	58.5	49.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	20.3	21.0	22.1	22.6	22.8	26.2	27.8	29.4	30.9	27.6	23.6	19.5	(35)
		MCDBR	28.2	30.9	31.6	33.1	31.3	32.5	31.3	33.0	35.8	34.9	34.0	28.1	(36)
	5% WB	MCWBR	15.2	17.0	17.1	15.6	13.8	12.4	12.1	12.4	14.2	16.2	17.3	15.7	(37)
		MCWBR	21.5	25.5	27.8	26.3	28.1	29.9	27.5	30.8	31.2	27.1	27.9	18.6	(38)
(40) Clear-Sky Solar Irradiance	taub		0.270	0.280	0.290	0.306	0.317	0.315	0.335	0.321	0.309	0.303	0.278	0.273	(40)
		taud	2.550	2.536	2.506	2.466	2.458	2.466	2.445	2.458	2.499	2.497	2.542	2.554	(41)
	Ebn at Noon		301	309	313	311	306	305	298	302	302	296	295	293	(42)
		Edh at Noon	25	28	32	35	36	35	36	35	31	29	25	23	(43)
(44) All-Sky Solar Radiation	RadAvg		929	1215	1676	2095	2404	2659	2526	2366	2000	1484	1084	846	(44)
	RadStd		75	139	107	108	127	106	102	61	47	84	45	73	(45)

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)		+1.15	N/A	-3.04	+1.15	N/A	N/A	N/A	-214	+401	+169

Nomenclature: See separate page