

TEHACHAPI, CA, USA

WMO: 749171

Lat: 35.135N

Lon: 118.439W

Elev: 1220

StdP: 87.51

Time Zone: -8.00 (NAP)

Period: 10-19

WBAN: 00479

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-5.0	-3.0	-20.0	0.7	7.0	-17.8	0.9	7.1	13.6	4.3	12.1	3.1	1.4	120	0.615

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.4	33.0	15.8	32.4	15.7	31.1	15.4	18.0	29.9	17.3	29.1	16.6	28.4	6.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.6	11.3	22.5	12.5	10.5	21.8	12.0	10.1	21.4	55.6	30.4	53.3	28.7	50.9	28.7	20.8

Extreme Annual Design Conditions

Extreme Annual WS							Extreme Annual Temperature												n-Year Return Period Values of Extreme Temperature											
1%		2.5%	5%			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years														
	Min	Max			Min	Max			Min	Max			Min	Max			Min	Max												
(a)	(b)	(c)			(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)														
11.6	10.4	9.1			-9.1	35.7	2.3	1.1	-10.8	36.5	-12.1	37.1	-13.4	37.8	-15.1	38.6														
			DB		-10.2	19.4	2.0	1.0	-11.7	20.1	-12.9	20.6	-14.0	21.2	-15.5	21.9														
			WB																											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.7	6.0	5.7	7.9	10.2	13.1	19.4	22.5	21.9	18.6	13.1	8.4	4.9
	DBStd	7.12	3.31	3.90	3.37	3.81	3.90	3.76	2.46	2.29	3.53	3.32	4.04	3.59
	HDD10.0	639	129	127	81	43	15	1	0	0	1	8	76	159
	HDD18.3	2424	383	354	323	243	166	33	2	2	39	164	299	415
	CDD10.0	1619	4	6	16	51	112	281	387	370	258	106	27	2
	CDD18.3	362	0	0	0	0	5	63	130	114	47	3	0	0
	CDH23.3	5602	0	0	4	26	136	948	1790	1636	919	137	7	0
	CDH26.7	2229	0	0	0	2	27	362	779	686	347	27	0	0
Wind	WSAvg	4.4	4.4	4.3	4.7	5.3	5.2	5.1	4.2	3.9	3.6	3.9	4.2	4.5
Precipitation	PrecAvg	318	63	65	43	24	10	3	2	3	4	14	27	57
	PrecMax	563	180	216	169	52	52	17	12	14	19	58	82	160
	PrecMin	185	9	12	4	4	1	0	0	0	0	1	3	14
	PrecStd	95	43	44	40	16	12	5	3	4	5	13	21	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	21.0	23.7	25.9	29.1	34.2	34.1	35.0	33.0	29.0	24.1	18.7
		MCWB	7.7	8.4	10.9	12.2	13.8	16.7	16.6	16.8	15.2	13.2	10.5	6.2
	2%	DB	17.3	18.8	20.3	23.8	27.3	32.6	32.9	32.9	32.1	27.2	22.5	17.0
		MCWB	6.7	8.1	9.8	11.3	13.2	16.0	16.0	15.6	15.0	12.2	9.3	6.3
	5%	DB	15.1	17.0	18.0	22.3	24.8	30.2	32.3	32.1	30.1	24.1	20.1	14.0
		MCWB	5.8	7.4	8.9	10.8	12.1	15.2	16.0	15.4	14.4	10.6	8.2	5.6
	10%	DB	12.9	13.7	16.1	19.0	22.5	28.7	31.0	30.1	28.8	22.5	17.4	12.2
		MCWB	5.0	6.6	7.5	9.8	11.7	14.8	15.7	15.2	14.2	10.1	7.2	4.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	9.5	11.3	12.6	15.0	15.3	19.1	18.8	18.4	17.8	15.3	11.6	10.2
		MCDB	14.3	14.5	19.5	22.5	26.4	31.8	30.4	30.9	28.4	23.6	21.3	12.9
	2%	WB	8.4	9.7	11.3	13.0	14.1	17.9	18.0	17.4	16.6	14.2	10.3	9.0
		MCDB	12.2	14.1	18.0	20.5	24.7	29.6	29.7	30.4	27.9	23.1	19.4	11.0
	5%	WB	7.5	8.5	10.1	11.8	13.2	16.8	17.3	16.7	15.7	12.9	9.3	7.9
		MCDB	10.9	13.8	16.2	19.0	22.8	27.8	29.1	29.3	27.2	20.3	17.0	9.8
	10%	WB	6.7	7.5	9.0	10.7	12.2	15.6	16.7	15.9	15.0	11.8	8.2	6.9
		MCDB	10.9	12.4	14.5	17.5	20.9	26.3	28.4	28.3	26.5	18.9	14.7	9.9
Mean Daily Temperature Range	5% DB	MDBR	11.3	11.7	12.3	12.6	12.7	14.6	15.4	16.3	17.2	15.3	13.1	10.9
		MCDBR	15.6	17.2	17.6	18.4	17.4	18.0	17.4	18.3	19.9	19.4	18.9	15.6
		MCWBR	8.5	9.5	9.5	8.7	7.7	6.9	6.7	6.9	7.9	9.0	9.6	8.7
	5% WB	MCDBR	11.9	14.2	15.4	14.6	15.6	16.6	15.3	17.1	17.4	15.1	15.5	10.3
		MCWBR	7.5	8.6	9.0	8.2	7.3	6.7	6.2	6.7	7.1	7.2	8.5	6.8
Clear-Sky Solar Irradiance	taub	0.270	0.280	0.290	0.306	0.317	0.315	0.335	0.321	0.309	0.303	0.278	0.273	
	taud	2.550	2.536	2.506	2.466	2.458	2.466	2.445	2.458	2.499	2.497	2.542	2.554	
	Ebn at Noon	950	975	987	979	964	962	940	951	952	932	931	924	
	Edh at Noon	78	89	100	109	112	111	113	109	99	91	78	73	
All-Sky Solar Radiation	RadAvg	2.93	3.83	5.28	6.60	7.58	8.38	7.96	7.46	6.31	4.68	3.42	2.67	
	RadStd	0.23	0.44	0.34	0.34	0.40	0.34	0.32	0.19	0.15	0.27	0.14	0.23	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (46 neighbors)	+0.64	N/A	-1.69	+0.64	N/A	N/A	N/A	-119	+223	+94

Nomenclature: See separate page