

CLANTON 2 NE, AL, USA

WMO: 750020

Lat: 32.8516N

Lon: 86.6115W

Elev: 584

StdP: 14.39

Time Zone: -6.00 (NAC)

Period: 07-19

WBAN: 63891

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.6	25.6	N/A	N/A	N/A	N/A	N/A	N/A	16.7	57.4	15.2	54.8	4.4	0	0.361

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.6	94.7	N/A	92.3	N/A	90.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	6.1	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
14.4	12.6	11.1	DB	15.6	96.7	5.6	2.9	11.6	98.8	8.3	100.4	5.2	102.0	1.2	104.1	
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.4	44.0	49.4	55.7	62.8	70.5	77.8	79.6	79.6	75.0	64.0	52.7	48.6
	DBStd	14.46	10.34	9.83	8.80	6.60	5.58	3.33	2.98	3.59	5.07	7.79	7.97	9.38
	HDD50	630	246	122	47	4	0	0	0	0	0	4	60	147
	HDD65	2543	651	442	305	117	23	0	0	0	3	113	377	512
	CDD50	5514	60	106	224	388	634	834	919	917	750	438	140	104
	CDD65	1952	1	6	16	51	192	384	454	452	303	83	6	4
	CDH74	17413	1	18	121	488	1655	3562	4161	4123	2514	729	35	6
	CDH80	7090	0	0	11	60	502	1580	1833	1895	1022	184	3	0
Wind	WSAvg	4.8	5.4	5.8	6.0	5.3	4.5	4.0	4.0	4.0	4.1	4.4	4.5	5.3
Precipitation	PrecAvg	53.7	5.4	5.4	5.8	4.1	3.9	4.6	4.9	3.8	3.7	3.1	4.6	4.7
	PrecMax	79.6	10.1	9.6	11.3	7.2	9.1	10.2	12.8	7.8	8.9	9.0	9.5	9.3
	PrecMin	30.7	2.8	1.9	1.2	1.2	0.5	1.3	1.4	0.9	0.4	0.5	1.5	2.6
	PrecStd	9.5	2.0	2.0	3.0	1.5	2.3	2.6	2.4	1.8	2.4	2.2	2.1	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.5	77.1	81.9	84.2	89.7	95.4	96.0	99.6	95.4	88.2	78.2	74.7
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	68.4	72.8	77.6	81.9	87.3	92.6	92.9	95.3	92.0	84.5	73.8	71.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	64.7	68.7	73.9	79.6	85.3	90.7	91.0	92.2	89.1	81.5	70.7	68.0
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	61.0	65.6	70.7	77.0	83.0	88.7	89.1	89.3	86.3	78.0	67.8	64.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mean Daily Temperature Range		MDBR	20.3	21.1	21.9	22.9	21.3	20.1	18.6	19.0	20.3	23.1	23.7	18.7
		MCDBR	21.8	22.4	24.1	25.3	25.0	23.5	21.1	23.4	24.4	25.7	25.5	20.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Clear-Sky Solar Irradiance	taub	0.318	0.325	0.356	0.387	0.443	0.472	0.526	0.521	0.427	0.367	0.341	0.321	
	taud	2.532	2.512	2.436	2.336	2.226	2.187	2.051	2.056	2.307	2.461	2.476	2.538	
	Ebn at Noon	287	296	292	286	270	261	246	245	266	276	275	279	
	Edh at Noon	27	30	35	40	45	47	53	52	39	31	28	25	
All-Sky Solar Radiation	RadAvg	863	1038	1403	1771	1943	1957	1896	1757	1550	1305	975	737	
	RadStd	63	129	128	125	143	146	129	99	135	164	97	79	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (43 neighbors)	+0.95	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+304	+209	

Nomenclature: See separate page