

GREENSBORO 2 WNW, AL, USA

WMO: 750040

Lat: 32.7169N

Lon: 87.6231W

Elev: 280

StdP: 14.55

Time Zone: -6.00 (NAC)

Period: 07-19

WBAN: 63893

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.9	26.0	N/A	N/A	N/A	N/A	N/A	N/A	12.8	53.6	12.1	51.4	5.0	10	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.5	95.2	N/A	93.0	N/A	91.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	3.8	50

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.3	9.8	8.6	15.3	96.8	5.0	2.9	11.8	98.9	8.8	100.6	6.0	102.2	2.4	104.4		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	64.4	44.5	50.5	56.6	63.8	71.3	79.0	80.3	80.3	76.0	65.1	54.2	49.9	
	DBStd	14.58	10.81	10.29	9.19	6.93	5.81	3.49	3.03	3.61	4.93	8.15	8.61	9.81	
	HDD50	585	239	112	44	3	0	0	0	0	0	3	54	130	
	HDD65	2379	637	415	284	103	21	0	0	0	2	102	338	477	
	CDD50	5830	69	127	249	417	662	870	940	941	779	472	178	126	
	CDD65	2148	2	10	24	66	218	420	475	476	331	106	13	7	
	CDH74	18930	2	35	155	526	1806	4000	4357	4396	2730	858	53	12	
	CDH80	7933	0	1	16	71	587	1854	1963	2072	1134	231	4	0	
Wind	WSAvg	4.1	4.8	5.1	5.1	4.5	3.5	3.7	3.1	3.3	3.3	4.0	3.8	4.4	
Precipitation	PrecAvg	55.7	5.6	5.5	6.0	5.4	4.2	4.0	4.9	3.7	3.9	3.2	4.3	5.0	
	PrecMax	78.8	11.7	18.3	14.6	14.4	10.3	11.7	11.0	8.9	9.1	10.0	14.7	13.5	
	PrecMin	43.7	1.3	1.3	1.9	0.6	0.6	0.6	0.7	0.5	0.6	0.0	0.7	0.4	
	PrecStd	7.8	2.5	3.2	3.1	3.1	2.5	2.5	2.8	2.1	2.0	2.3	2.4	2.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.5	78.5	82.2	84.8	90.9	97.0	96.2	99.5	94.4	88.5	79.4	75.8	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	DB	68.8	74.0	78.3	82.2	88.0	94.0	93.4	95.8	91.8	85.5	75.0	71.9	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	DB	64.8	70.0	74.8	79.8	85.9	91.8	91.6	92.9	89.4	82.5	71.8	68.9	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	DB	61.6	66.3	71.1	77.2	83.7	89.5	89.5	90.1	87.1	79.0	68.4	65.5	
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	20.0	20.5	21.4	22.0	20.8	20.0	18.5	19.0	20.1	22.2	22.2	18.2	
		MCDBR	21.1	21.2	23.0	23.2	23.3	23.0	20.9	23.2	22.8	24.7	23.1	18.9	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Clear-Sky Solar Irradiance	taub	0.322	0.332	0.360	0.399	0.446	0.481	0.537	0.532	0.443	0.371	0.344	0.322		
	taud	2.525	2.498	2.430	2.306	2.224	2.160	2.023	2.031	2.268	2.457	2.475	2.540		
	Ebn at Noon	285	293	291	283	269	258	243	242	261	275	274	279		
	Edh at Noon	27	30	35	41	45	48	55	54	41	31	28	25		
All-Sky Solar Radiation	RadAvg	861	1037	1399	1763	1947	1998	1917	1770	1572	1314	977	738		
	RadStd	66	137	129	135	135	155	122	108	127	159	99	75		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (32 neighbors)	+0.86	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+266	+180

Nomenclature: See separate page