

GREENSBORO 2 WNW, AL, USA

WMO: 750040

Lat: 32.7169N

Lon: 87.6231W

Elev: 85

StdP: 100.30

Time Zone: -6.00 (NAC)

Period: 07-19

WBAN: 63893

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.6	(c) -3.3	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 5.7	(k) 12.0	(l) 5.4	(m) 10.8	(n) 2.2	(o) 10	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.3	(c) 35.1	(d) N/A	(e) 33.9	(f) N/A	(g) 32.8	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 1.7	(p) 50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 5.0	(b) 4.4	(c) 3.9	(e) -9.3	(f) 36.0	(g) 2.8	(h) 1.6	(i) -11.2	(j) 37.2	(k) -12.9	(l) 38.1	(m) -14.4	(n) 39.0	(o) -16.4	(p) 40.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.0	7.0	10.3	13.7	17.7	21.9	26.1	26.8	26.9	24.4	18.4	12.3	9.9
	DBStd	8.10	6.01	5.72	5.11	3.85	3.23	1.94	1.68	2.00	2.74	4.53	4.78	5.45
	HDD10.0	325	133	62	24	2	0	0	0	0	0	2	30	72
	HDD18.3	1322	354	231	158	57	12	0	0	0	1	57	188	265
	CDD10.0	3239	38	71	138	232	368	483	522	523	433	262	99	70
	CDD18.3	1193	1	6	13	37	121	233	264	264	184	59	7	4
	CDH23.3	10517	1	19	86	292	1003	2222	2421	2442	1517	477	29	7
	CDH26.7	4407	0	1	9	39	326	1030	1091	1151	630	128	2	0
Wind	WSAvg	1.8	2.2	2.3	2.3	2.0	1.6	1.6	1.4	1.5	1.5	1.8	1.7	2.0
Precipitation	PrecAvg	1414	143	139	152	137	107	101	125	93	100	81	109	126
	PrecMax	2002	297	466	370	366	262	296	280	225	232	254	373	344
	PrecMin	1109	33	34	49	15	16	16	19	13	15	0	19	9
	PrecStd	199	63	82	80	80	64	64	70	53	51	59	62	67
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.0	25.8	27.9	29.3	32.7	36.1	35.7	37.5	34.7	31.4	26.3	24.3
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	20.4	23.3	25.7	27.9	31.1	34.4	34.1	35.4	33.2	29.7	23.9	22.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	18.2	21.1	23.8	26.6	30.0	33.2	33.1	33.8	31.9	28.0	22.1	20.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Mean Daily Temperature Range	5% DB	MDBR	11.1	11.4	11.9	12.2	11.6	11.1	10.3	10.6	11.2	12.3	12.3	10.1
		MCDBR	11.7	11.8	12.8	12.9	12.9	12.8	11.6	12.9	12.7	13.7	12.8	10.5
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		Clear-Sky Solar Irradiance	taub	0.322	0.332	0.360	0.399	0.446	0.481	0.537	0.532	0.443	0.371	0.344
taud	2.525		2.498	2.430	2.306	2.224	2.160	2.023	2.031	2.268	2.457	2.475	2.540	
Ebn at Noon	899		925	918	891	848	814	767	764	824	868	864	879	
Edh at Noon	84		96	110	130	143	152	173	169	128	99	88	79	
All-Sky Solar Radiation	RadAvg	2.71	3.27	4.41	5.56	6.14	6.30	6.04	5.58	4.96	4.14	3.08	2.33	
	RadStd	0.21	0.43	0.41	0.43	0.43	0.49	0.39	0.34	0.40	0.50	0.31	0.24	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only		N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47) Regional (32 neighbors)		+0.48	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+148	+100

Nomenclature: See separate page