

SCOTTSBORO 2 NE, AL, USA

WMO: 750070

Lat: 34.6941N

Lon: 85.9998W

Elev: 636

StdP: 14.36

Time Zone: -6.00 (NAC)

Period: 06-19

WBAN: 63896

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 16.9	(c) 20.9	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 19.3	(c) 93.3	(d) N/A	(e) 91.2	(f) N/A	(g) 89.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
N/A	N/A	N/A	11.1	96.0	4.5	3.3	7.8	98.4	5.2	100.4	2.7	102.2	-0.6	104.7
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.4	39.7	44.4	52.3	60.2	68.4	75.8	77.8	77.6	72.2	60.8	49.3	44.8
	DBStd	15.39	10.44	9.92	9.06	7.37	6.19	3.64	3.50	3.76	5.74	8.32	8.25	9.42
	HDD50	997	351	209	84	11	0	0	0	0	0	11	110	221
	HDD65	3282	786	579	401	176	43	0	0	0	12	182	475	628
	CDD50	4777	30	52	154	318	571	775	863	855	667	345	88	59
	CDD65	1589	0	2	6	33	149	326	398	390	229	52	3	1
	CDH74	13800	0	10	101	393	1349	2899	3336	3297	1911	484	19	1
	CDH80	5427	0	0	11	50	394	1226	1396	1469	757	121	3	0
(14) Wind	WSAvg	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(15) Precipitation	PrecAvg	58.5	5.6	5.2	6.6	4.7	4.6	4.3	4.5	3.5	4.8	3.1	4.7	5.7
	PrecMax	77.0	10.9	10.3	16.5	9.8	13.7	9.1	8.5	7.7	11.0	7.9	11.4	14.7
	PrecMin	43.7	0.8	0.8	2.3	1.2	1.3	0.6	1.2	0.0	1.0	0.1	1.4	1.1
	PrecStd	8.8	2.4	2.5	3.3	2.2	2.4	2.2	1.8	1.8	2.6	2.1	2.3	3.0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	69.3	75.3	81.5	84.3	89.2	94.0	95.2	97.7	94.5	88.3	76.4	71.9
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	DB	64.7	69.3	76.9	81.4	86.7	91.6	91.6	93.7	91.2	83.1	71.3	67.5
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	DB	61.0	66.0	72.8	79.0	84.4	89.6	89.8	90.7	88.1	79.5	68.3	64.2
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	DB	56.8	61.8	68.6	75.6	82.1	87.2	87.5	88.0	84.5	75.7	64.9	60.4
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(35) Mean Daily Temperature Range	5% DB	MDBR	19.9	21.5	23.2	24.8	22.7	21.8	19.3	20.7	22.5	24.4	24.7	19.3
		MCDBR	23.3	26.3	28.8	28.1	26.4	25.1	22.1	24.8	26.6	27.5	28.0	21.6
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(40) Clear-Sky Solar Irradiance	taub		0.320	0.326	0.366	0.403	0.454	0.492	0.540	0.540	0.434	0.381	0.342	0.318
	taud		2.492	2.472	2.383	2.270	2.169	2.099	1.981	1.968	2.258	2.388	2.446	2.516
	Ebn at Noon		282	292	287	280	266	255	242	239	262	268	270	275
	Edh at Noon		27	30	36	43	48	51	57	57	41	33	28	25
(44) All-Sky Solar Radiation	RadAvg		776	943	1306	1697	1864	1971	1872	1741	1501	1222	888	662
	RadStd		58	120	122	115	145	151	112	92	136	157	99	64

Historical Trends

	DBAvg	Heating		Cooling		Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (36 neighbors)	+0.85	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+265

Nomenclature: See separate page