

SELMA 6 SSE, AL, USA

WMO: 750100

Lat: 32.3355N

Lon: 86.9787W

Elev: 48

StdP: 100.75

Time Zone: -6.00 (NAC)

Period: 07-19

WBAN: 63897

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.3	(c) -3.3	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) 9.4	(k) 8.1	(l) 8.6	(m) 8.2	(n) 1.9	(o) 130	(p) 0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 10.7	(c) 35.4	(d) N/A	(e) 34.3	(f) N/A	(g) 33.2	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) 3.1	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) N/A	(b) N/A	(c) N/A	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.8	(b) 6.7	(c) 5.8	(e) -8.7	(f) 36.5	(g) 2.4	(h) 1.4	(i) -10.4	(j) 37.5	(k) -11.8	(l) 38.3	(m) -13.1	(n) 39.1	(o) -14.9	(p) 40.1		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	7.5	10.6	13.9	17.7	22.2	26.2	27.0	26.9	24.5	18.5	12.1	10.0		
	DBStd	8.00	5.84	5.57	4.84	3.76	3.14	1.92	1.60	1.98	2.69	4.45	4.65	5.41		
	HDD10.0	299	119	57	20	2	0	0	0	0	0	2	29	71		
	HDD18.3	1282	336	222	151	56	9	0	0	0	1	54	193	261		
	CDD10.0	3271	43	74	141	233	377	487	527	526	436	264	93	72		
	CDD18.3	1213	2	6	12	37	128	237	268	267	186	58	7	4		
	CDH23.3	11352	5	26	99	371	1216	2323	2568	2534	1617	538	42	13		
	CDH26.7	4911	0	1	10	69	457	1122	1188	1217	691	152	4	0		
(14) Wind	WSAvg	2.3	2.8	2.9	2.9	2.6	2.2	2.0	1.9	1.8	1.8	2.1	2.2	2.5		
(15) Precipitation	PrecAvg	1321	134	129	155	108	89	107	116	103	94	68	100	128		
	PrecMax	1853	311	355	330	345	241	264	291	241	278	235	265	518		
	PrecMin	868	27	39	27	6	2	2	12	18	9	2	14	33		
	PrecStd	230	60	63	83	69	60	65	56	52	63	51	60	80		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.1	26.0	28.0	29.9	33.6	36.6	35.8	38.2	35.2	32.2	26.9	25.3		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	DB	21.6	23.9	26.0	28.7	32.1	35.0	34.6	35.6	33.6	30.0	24.4	23.0		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	DB	19.4	21.7	24.2	27.3	30.7	33.8	33.5	34.1	32.3	28.4	22.7	21.1		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	DB	17.2	19.8	22.3	25.7	29.5	32.5	32.4	32.6	30.8	26.6	20.8	19.2		
		MCWB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	2%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	10%	WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCDB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(35) Mean Daily Temperature Range	MDBR		12.0	12.5	12.9	13.5	12.9	11.7	10.7	10.9	11.6	13.5	14.1	11.2		
	5% DB	MCDBR	12.8	12.9	13.7	14.6	14.8	13.6	12.2	13.2	13.5	14.6	14.7	12.0		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
	5% WB	MCDBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
		MCWBR	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(40) Clear-Sky Solar Irradiance	taub		0.324	0.334	0.361	0.395	0.445	0.478	0.541	0.530	0.441	0.375	0.347	0.326		
	taud		2.525	2.501	2.428	2.325	2.232	2.184	2.019	2.046	2.280	2.447	2.466	2.533		
	Ebn at Noon		900	924	918	896	849	817	764	767	827	866	862	877		
	Edh at Noon		85	96	111	128	141	148	174	167	127	100	89	80		
(44) All-Sky Solar Radiation	RadAvg		2.78	3.35	4.50	5.63	6.20	6.22	6.00	5.57	4.96	4.19	3.15	2.39		
	RadStd		0.20	0.42	0.41	0.42	0.42	0.48	0.40	0.33	0.40	0.51	0.30	0.25		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (40 neighbors)		+0.46	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+144	+93

Nomenclature: See separate page