

EDINBURG 17 NNE, TX, USA

WMO: 752550

Lat: 26.5258N

Lon: 98.0633W

Elev: 20

StdP: 101.09

Time Zone: -6.00 (NAC)

Period: 04-19

WBAN: 12987

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.6	3.8	-7.7	2.0	11.4	-5.0	2.5	11.7	8.1	24.9	7.3	24.1	2.1	N/A	0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.1	38.0	24.5	37.1	24.6	36.1	24.6	26.9	30.8	26.6	31.0	26.2	31.0	3.6	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.3	21.9	27.6	25.7	21.0	27.5	25.2	20.4	27.4	84.6	30.1	82.7	30.9	81.2	30.9	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.0	6.2	5.6	DB	-1.3	40.0	2.0	1.4	-2.7	41.0	-3.9	41.8	-5.0	42.6	-6.4	43.6	(4)
			WB	-2.5	27.7	1.6	1.1	-3.6	28.5	-4.5	29.1	-5.4	29.7	-6.5	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	23.8	15.5	18.3	21.3	24.2	27.0	29.3	29.8	30.3	28.1	24.6	19.8	16.4	(6)
		DBStd	6.43	5.32	5.67	4.46	3.53	2.74	1.56	1.53	1.49	2.12	3.76	4.96	5.34	(7)
		HDD10.0	34	14	7	1	0	0	0	0	0	0	2	9		(8)
		HDD18.3	367	120	67	24	4	0	0	0	0	4	43	104		(9)
		CDD10.0	5053	183	239	351	427	528	581	614	631	543	454	296	207	(10)
		CDD18.3	2345	31	66	116	181	270	331	356	372	293	200	87	43	(11)
		CDH23.3	24957	226	476	884	1635	2815	3919	4342	4644	2994	1990	722	308	(12)
		CDH26.7	12012	46	154	301	667	1290	2048	2333	2575	1438	865	231	66	(13)
(14)	Wind	WSAvg	2.6	2.5	2.9	3.1	3.1	3.1	2.8	2.7	2.4	1.9	2.1	2.3	2.3	(14)
(15)	Precipitation	PrecAvg	547	24	21	30	36	53	59	51	43	114	57	31	25	(15)
(16)		PrecMax	830	99	80	100	114	142	253	272	140	249	199	85	108	(16)
(17)		PrecMin	185	3	0	2	1	3	3	1	3	5	5	1	0	(17)
(18)		PrecStd	141	21	23	26	34	37	52	69	36	66	46	25	27	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	30.1	33.1	34.6	36.1	36.4	38.4	38.8	39.1	38.2	35.5	32.8	30.2		(19)
(20)		0.4% MCWB	19.6	19.6	20.3	22.3	24.4	24.6	24.4	24.4	23.4	23.6	22.7	21.7		(20)
(21)		2% DB	27.9	30.5	31.5	33.6	35.1	36.7	37.7	38.1	36.3	34.0	30.9	28.7		(21)
(22)		2% MCWB	18.9	20.5	21.6	22.9	24.6	24.8	24.6	24.6	24.2	23.5	22.3	20.8		(22)
(23)		5% DB	26.0	28.6	29.9	32.1	34.1	35.8	36.6	37.2	34.9	32.8	29.5	26.8		(23)
(24)		5% MCWB	17.9	20.4	21.2	22.5	24.3	24.8	24.7	24.8	24.3	23.4	21.6	20.0		(24)
(25)		10% DB	23.8	26.4	28.2	30.6	32.8	34.8	35.4	36.1	33.5	31.5	27.8	24.9		(25)
(26)		10% MCWB	17.7	19.5	20.3	22.3	23.9	24.8	24.7	24.9	24.5	23.0	21.2	20.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	21.8	22.8	23.5	27.3	26.9	27.5	27.3	27.2	27.0	26.8	25.6	25.5		(27)
(28)		0.4% MCDB	26.1	28.7	28.5	29.3	31.2	31.6	30.5	31.5	30.2	28.9	27.4	26.0		(28)
(29)		2% WB	21.0	22.0	22.9	25.4	26.2	26.8	26.7	26.6	26.4	25.7	24.4	22.8		(29)
(30)		2% MCDB	24.8	26.8	28.1	30.0	31.3	31.5	30.7	31.6	30.5	29.5	28.2	26.1		(30)
(31)		5% WB	20.2	21.6	22.3	24.4	25.7	26.3	26.2	26.2	26.0	25.1	23.4	21.8		(31)
(32)		5% MCDB	23.5	26.0	26.9	29.2	30.5	31.3	30.8	31.6	30.3	29.4	27.3	25.1		(32)
(33)		10% WB	19.2	21.0	21.7	23.5	25.2	25.9	25.8	25.8	25.6	24.5	22.4	20.9		(33)
(34)		10% MCDB	22.4	24.9	25.8	28.0	29.8	30.8	30.7	31.5	30.0	28.8	26.1	24.0		(34)
(35)	Mean Daily Temperature Range	MDBR	12.2	12.0	11.8	11.9	10.9	11.3	11.3	12.1	10.8	12.3	12.2	11.6		(35)
(36)		5% DB MCDBR	13.8	13.3	12.6	12.9	11.8	12.5	13.0	13.3	12.8	12.5	12.8	12.9		(36)
(37)		5% DB MCWBR	6.8	5.1	4.2	4.6	2.9	2.6	2.5	2.6	3.2	4.4	5.3	6.4		(37)
(38)		5% WB MCDBR	11.1	10.9	10.6	10.7	9.4	10.5	11.1	12.3	9.9	10.8	11.0	11.1		(38)
(39)		5% WB MCWBR	6.6	5.2	4.5	4.4	3.2	3.1	2.9	2.9	3.2	4.3	5.3	7.2		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.351	0.369	0.391	0.422	0.436	0.423	0.429	0.424	0.425	0.379	0.369	0.350		(40)
(41)		taud	2.475	2.413	2.356	2.280	2.280	2.374	2.362	2.385	2.350	2.473	2.447	2.480		(41)
(42)		Ebn at Noon	899	907	903	879	861	867	860	866	858	885	870	882		(42)
(43)		Edh at Noon	96	110	123	136	136	123	124	121	122	102	98	92		(43)
(44)	All-Sky Solar Radiation	RadAvg	3.12	3.78	4.63	5.48	5.97	6.66	6.62	6.33	5.24	4.56	3.51	2.81		(44)
(45)		RadStd	0.35	0.60	0.55	0.51	0.45	0.25	0.46	0.30	0.41	0.46	0.38	0.40		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (21 neighbors)		N/A	N/A	N/A	+0.33	N/A	N/A	N/A	N/A	+121	+114

Nomenclature: See separate page