

TIJUANA, Mexico

WMO: 760013

Lat: 32.541N

Lon: 116.970W

Elev: 149

StdP: 99.55

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	5.8	6.8	-15.0	1.0	18.4	-12.2	1.3	18.5	9.5	16.4	8.4	16.5	1.2	110	0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.2	32.8	17.5	30.8	17.3	29.0	17.3	21.5	27.9	20.9	27.0	20.2	25.6	4.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.2	14.2	22.8	19.0	14.0	22.7	18.2	13.3	22.4	63.1	28.2	61.1	27.2	59.0	25.9	25.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.6	6.7	6.1	DB	3.0	37.1	1.4	1.8	2.0	38.4	1.2	39.5	0.4	40.5	-0.7	41.8	(4)
(5)			WB	-0.7	22.8	1.4	1.0	-1.7	23.5	-2.5	24.1	-3.3	24.7	-4.3	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.8	14.3	14.2	15.2	16.1	17.7	19.5	21.8	22.6	22.1	19.7	16.8	13.9	(6)	
	DBStd	4.01	2.95	2.91	2.67	2.65	2.34	1.93	1.85	2.01	2.59	2.80	3.04	2.52	(7)	
	HDD10.0	4	2	1	0	0	0	0	0	0	0	0	0	1	(8)	
	HDD18.3	699	129	122	104	78	40	7	1	0	1	13	65	139	(9)	
	CDD10.0	2868	136	118	161	183	238	286	365	390	364	302	204	122	(10)	
	CDD18.3	519	5	5	7	11	19	42	107	132	115	57	19	2	(11)	
	CDH23.3	3393	68	66	88	137	152	198	536	745	728	437	208	31	(12)	
(13)	CDH26.7	1006	11	14	26	46	53	47	115	200	252	171	69	2	(13)	
(14)	Wind	WSAvg	2.3	2.0	2.3	2.3	2.5	2.6	2.6	2.5	2.2	2.1	2.0	2.1	(14)	
(15) Precipitation	PrecAvg	238	42	40	48	15	3	0	1	0	6	6	33	41	(15)	
	PrecMax	433	143	165	165	57	14	6	8	4	59	37	128	162	(16)	
	PrecMin	125	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	95	39	43	41	18	5	1	2	1	14	9	30	45	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.1	28.8	30.0	31.2	32.0	31.9	31.9	33.2	35.2	34.9	31.8	26.2	(19)	
		MCWB	12.1	12.7	14.0	13.4	14.2	17.7	19.2	20.9	19.1	15.8	14.4	11.2	(20)	
	2%	DB	25.2	25.2	25.8	27.1	27.2	27.1	29.2	30.9	31.9	31.0	28.8	23.8	(21)	
		MCWB	11.1	11.6	12.8	13.3	13.9	18.4	19.5	20.1	19.9	14.6	13.1	10.8	(22)	
	5%	DB	22.9	22.1	22.8	23.9	24.1	25.1	27.8	28.9	29.2	28.0	25.2	21.6	(23)	
		MCWB	10.9	11.6	13.2	13.0	14.8	17.8	19.4	20.0	19.1	15.1	12.1	10.9	(24)	
	10%	DB	20.2	19.2	20.1	21.1	22.1	23.9	26.1	27.1	27.2	25.1	22.8	19.1	(25)	
		MCWB	10.5	11.4	13.1	13.9	15.0	17.3	19.3	19.8	18.9	15.4	12.0	11.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	15.9	16.1	16.6	17.2	19.7	21.6	22.4	22.3	20.8	16.7	16.1	(27)	
		MCDB	18.8	19.3	22.5	23.4	25.4	27.1	27.6	29.1	30.8	26.0	21.3	18.7	(28)	
	2%	WB	14.4	14.3	15.2	15.7	16.5	18.9	20.9	21.5	21.5	19.2	15.9	15.1	(29)	
		MCDB	17.9	19.8	20.7	21.3	23.0	25.9	27.1	27.2	28.8	23.9	20.3	18.0	(30)	
	5%	WB	13.6	13.5	14.5	14.9	15.7	18.1	20.1	20.9	20.9	18.1	15.1	14.1	(31)	
		MCDB	17.3	19.0	19.7	20.4	21.3	24.1	25.6	26.5	27.4	23.4	19.9	17.1	(32)	
	10%	WB	12.8	12.9	13.9	14.3	15.1	17.4	19.6	20.2	20.1	17.4	14.4	13.3	(33)	
		MCDB	16.8	18.0	18.8	19.2	20.0	22.7	24.5	25.4	25.4	22.5	19.6	16.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	10.0	9.7	9.5	8.3	8.5	8.9	9.2	9.6	10.1	11.0	10.7	(35)	
		MCDBR	14.8	14.9	14.5	14.9	12.5	11.0	11.2	11.6	12.6	15.5	15.3	14.6	(36)	
	5% WB	MCWBR	6.7	6.8	6.7	6.5	5.1	4.2	3.6	3.8	4.3	6.4	7.1	7.3	(37)	
		MCWBR	9.8	11.9	10.8	10.4	9.3	10.2	9.2	9.5	10.1	10.2	11.4	8.7	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.310	0.321	0.333	0.344	0.363	0.366	0.394	0.396	0.359	0.364	0.320	0.322	(40)	
		taud	2.556	2.539	2.491	2.462	2.428	2.423	2.428	2.403	2.483	2.439	2.554	2.550	(41)	
	Ebn at Noon		917	938	948	945	923	915	887	883	907	875	896	881	(42)	
		Edh at Noon	82	92	104	111	116	116	115	117	103	100	81	79	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.35	4.21	5.53	6.67	7.04	7.37	7.08	6.81	5.93	4.67	3.64	3.04	(44)	
	RadStd		0.21	0.35	0.31	0.34	0.51	0.42	0.47	0.32	0.32	0.33	0.23	0.21	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	+2	N/A	N/A	N/A	(46)
(47)	Regional (33 neighbors)	+0.66	N/A	-1.61	+0.77	N/A	N/A	N/A	-106	+233	+126	(47)

Nomenclature: See separate page