

MEXICALI INTL, Mexico

WMO: 760053

Lat: 32.631N

Lon: 115.242W

Elev: 23

StdP: 101.05

Time Zone: -8.00 (NAP)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	3.8	5.0	-14.0	1.1	17.5	-11.2	1.4	17.8	11.2	16.4	10.2	15.8	1.7	330	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	14.2	44.0	24.8	42.8	24.8	41.2	24.1	29.2	40.2	28.2	39.2	27.3	37.8	3.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	37.0	25.2	20.4	35.0	24.2	19.2	33.7	96.1	40.0	91.0	38.8	86.4	37.8	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.4	9.8	8.2	0.7	46.3	1.3	1.1	-0.2	47.1	-0.9	47.7	-1.6	48.3	-2.5	49.0		
(5)			-1.7	30.0	1.5	2.1	-2.8	31.5	-3.7	32.7	-4.5	33.9	-5.6	35.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	13.9	14.8	19.3	22.0	25.8	30.5	33.8	33.9	30.6	24.4	18.4	13.3		
	DBStd	7.87	2.90	2.96	3.47	3.27	3.42	2.82	1.85	1.91	3.23	3.25	3.41	2.74		
	HDD10.0	9	5	1	0	0	0	0	0	0	0	0	0	3		
	HDD18.3	482	138	103	32	8	1	0	0	0	0	2	41	158		
	CDD10.0	4916	127	136	288	361	489	616	737	740	619	446	253	106		
	CDD18.3	2347	2	4	62	118	232	366	478	482	369	189	43	2		
	CDH23.3	35038	48	103	857	1573	3182	5549	7652	7703	5506	2289	542	35		
(13)	CDH26.7	22153	3	11	332	741	1877	3709	5258	5294	3549	1198	180	1		
(14)	Wind	WSAvg	3.1	2.5	2.9	3.3	3.9	3.7	3.4	3.7	3.3	2.7	2.3	2.3		
(15) Precipitation	PrecAvg	53	7	6	4	3	0	0	3	8	2	7	4	8		
	PrecMax	132	43	45	32	29	6	2	20	76	18	92	41	48		
	PrecMin	2	0	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	40	12	11	7	8	1	0	5	17	4	18	9	13		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.8	28.1	34.8	37.2	41.2	45.8	45.8	45.1	43.2	39.0	32.8	26.1		
		MCWB	14.3	15.2	18.5	20.1	22.3	23.0	25.8	26.2	25.7	23.1	18.1	14.8		
	2%	DB	24.8	26.1	32.2	35.2	39.0	43.1	43.9	43.8	41.9	36.2	30.9	24.1		
		MCWB	13.8	15.0	17.9	18.6	20.9	23.0	26.1	24.8	24.6	20.9	16.5	13.7		
	5%	DB	23.0	24.2	30.2	33.1	37.1	41.1	42.2	42.1	40.2	35.0	28.9	22.0		
		MCWB	12.9	14.0	17.1	17.5	21.1	22.5	24.9	25.2	23.6	19.7	16.1	12.9		
	10%	DB	21.1	22.1	28.2	31.0	35.2	39.8	41.0	40.9	39.0	33.1	26.5	19.9		
		MCWB	12.2	13.2	16.0	17.3	19.7	21.9	24.6	24.7	23.5	18.7	15.6	11.9		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.1	17.5	21.2	22.7	25.0	27.7	30.8	30.6	29.8	25.5	21.3	17.1		
		MCDB	23.8	25.9	32.7	35.2	38.1	41.6	42.5	41.1	39.4	35.1	30.4	23.0		
	2%	WB	15.3	16.2	19.8	21.0	23.8	26.2	29.2	29.2	28.0	23.8	19.2	15.6		
		MCDB	21.6	24.1	30.4	32.9	37.4	39.6	40.6	40.2	38.3	33.6	27.9	21.4		
	5%	WB	14.1	15.2	18.3	19.7	22.3	24.9	28.3	28.3	26.9	22.2	17.9	14.5		
		MCDB	20.1	22.1	28.3	30.6	35.5	37.9	39.4	39.2	36.8	31.9	25.9	19.9		
	10%	WB	13.1	14.0	16.9	18.0	21.0	23.8	27.3	27.3	25.6	21.0	16.3	13.3		
		MCDB	19.3	20.7	26.4	28.3	33.4	36.7	38.0	37.2	35.0	30.1	23.9	18.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.5	13.6	15.3	15.7	16.6	17.5	14.5	14.2	15.2	15.8	14.7	12.9		
		MCDBR	15.9	16.1	17.9	18.4	19.3	18.9	16.5	15.8	16.6	18.0	17.1	15.5		
		MCWBR	8.6	8.1	8.2	7.6	8.1	7.2	6.5	6.3	6.8	7.8	8.0	8.4		
	5% WB	MCDBR	14.0	14.6	17.2	17.5	18.7	18.0	14.4	14.4	14.5	15.9	15.4	13.6		
		MCWBR	8.8	8.4	9.6	9.7	9.2	8.8	7.1	6.9	6.9	8.3	8.8	8.3		
(40) Clear-Sky Solar Irradiance	taub		0.288	0.290	0.310	0.322	0.339	0.341	0.386	0.381	0.347	0.317	0.293	0.289		
	taud		2.519	2.532	2.456	2.427	2.397	2.396	2.384	2.388	2.444	2.494	2.529	2.538		
	Ebn at Noon		941	973	971	966	946	938	895	897	919	928	927	921		
	Edh at Noon		84	92	107	115	120	120	121	118	107	94	82	78		
(44) All-Sky Solar Radiation	RadAvg		3.55	4.52	5.97	7.30	8.12	8.43	7.63	7.10	6.27	5.08	3.86	3.20		
	RadStd		0.17	0.30	0.20	0.17	0.20	0.29	0.29	0.28	0.22	0.19	0.17	0.17		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB		1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (17 neighbors)		+0.53	N/A	-1.25	+0.61	N/A	N/A	N/A	-78	+187

Nomenclature: See separate page