

HERMOSILLO, Mexico

WMO: 761600

Lat: 29.0784N

Lon: 110.9310W

Elev: 211

StdP: 98.82

Time Zone: -7.00 (W07)

Period: 00-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	4.9	6.8	-11.9	1.4	22.9	-8.2	1.9	22.4	8.0	20.5	6.8	21.1	0.4	30	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.1	42.8	22.7	41.7	23.0	40.2	22.8	27.1	34.8	26.6	34.4	26.2	34.0	3.5	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	20.9	29.7	25.0	20.6	29.6	24.2	19.6	29.7	86.5	35.4	84.4	34.4	82.5	33.9	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	6.8	5.8	DB	1.9	46.2	1.9	1.6	0.6	47.4	-0.5	48.3	-1.6	49.2	-2.9	50.4	(4)
(5)			WB	-1.1	29.4	1.6	0.9	-2.3	30.0	-3.2	30.5	-4.1	31.0	-5.3	31.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.4	16.9	18.4	21.4	24.4	27.8	32.5	33.5	32.8	31.2	26.7	21.5	16.7		
	DBStd	6.68	3.06	3.30	3.20	2.81	2.74	2.27	2.24	2.18	2.23	3.13	3.33	2.88		
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	188	63	37	10	1	0	0	0	0	0	1	11	66		
	CDD10.0	5606	214	236	354	433	552	674	728	708	637	517	344	208		
	CDD18.3	2751	18	39	106	183	293	424	469	450	387	259	106	16		
	CDH23.3	39631	409	644	1560	2480	4067	6509	7172	6684	5357	3172	1270	305		
(13)	CDH26.7	24133	112	255	764	1395	2548	4398	4739	4277	3201	1780	585	78		
(14)	Wind	WSAvg	1.8	1.2	1.5	1.8	2.1	2.3	2.5	2.5	1.9	1.6	1.4	1.3	1.1	(14)
(15) Precipitation	PrecAvg	284	23	12	4	3	3	6	78	83	38	12	8	18		
	PrecMax	485	98	91	29	28	23	49	156	164	113	50	48	98		
	PrecMin	185	0	0	0	0	0	0	21	20	2	0	0	0		
	PrecStd	71	27	22	7	7	5	13	32	34	29	14	11	26		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.2	35.0	37.2	39.1	41.9	44.8	44.2	43.1	42.2	40.2	36.1	31.2		
		MCWB	15.2	15.8	16.9	17.6	19.1	21.3	24.2	24.4	23.5	20.6	17.9	15.4		
	2%	DB	29.5	32.2	35.0	37.2	39.9	42.9	42.2	41.8	40.8	38.2	34.1	28.9		
		MCWB	14.5	15.4	16.1	17.1	19.1	21.4	23.9	24.7	24.0	20.9	17.4	15.1		
	5%	DB	27.9	30.0	33.1	35.8	38.2	41.2	41.0	40.1	39.0	36.8	32.2	26.9		
		MCWB	14.1	14.8	15.4	16.7	18.6	21.7	24.1	24.9	23.8	20.6	17.2	14.3		
	10%	DB	25.8	27.8	31.1	33.9	36.9	40.1	39.8	38.9	37.7	34.9	30.2	24.8		
		MCWB	13.6	14.2	14.9	16.3	18.1	21.6	24.0	24.9	24.1	20.1	16.4	13.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.0	18.4	18.5	19.8	22.1	26.3	27.8	28.1	27.3	25.7	21.3	18.0		
		MCDB	25.2	25.9	31.6	34.4	36.7	38.0	37.8	34.9	34.4	31.9	27.3	23.9		
	2%	WB	16.4	17.2	17.3	18.7	20.9	25.2	26.7	27.2	26.7	24.4	19.8	16.7		
		MCDB	24.2	26.4	30.5	32.9	35.0	36.8	35.4	34.6	33.9	32.2	28.8	24.0		
	5%	WB	15.4	16.2	16.5	17.8	20.0	24.4	26.1	26.7	26.2	23.4	18.6	15.8		
		MCDB	24.0	25.7	30.3	32.0	34.4	35.6	34.4	34.3	33.4	31.3	27.7	23.5		
	10%	WB	14.5	15.2	15.7	16.9	19.0	23.7	25.6	26.3	25.8	22.3	17.5	14.8		
		MCDB	23.5	25.1	29.3	31.5	34.3	34.8	33.8	34.0	32.9	30.4	27.1	23.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.0	16.7	17.8	17.8	17.2	15.8	12.1	11.8	12.5	15.3	16.2	15.9		
		MCDBR	19.7	20.9	20.6	20.3	18.8	16.8	13.8	13.4	14.9	17.2	18.5	19.0		
		MCWBR	8.8	8.7	8.2	8.0	7.4	6.1	4.6	4.3	4.8	6.1	7.5	8.6		
	5% WB	MCDBR	16.0	16.1	18.3	17.6	16.8	14.1	11.7	11.8	11.7	12.5	15.4	15.3		
		MCWBR	8.1	7.5	7.8	7.9	7.3	5.5	4.2	4.2	4.3	5.6	7.4	7.9		
(40) Clear-Sky Solar Irradiance	taub		0.291	0.294	0.321	0.326	0.344	0.390	0.434	0.422	0.394	0.341	0.301	0.291		
	taud		2.537	2.530	2.432	2.416	2.385	2.315	2.311	2.348	2.387	2.474	2.532	2.545		
	Ebn at Noon		957	982	968	967	943	895	855	864	881	915	937	941		
	Edh at Noon		87	95	112	118	122	130	131	125	116	100	86	82		
(44) All-Sky Solar Radiation	RadAvg		4.03	4.93	6.37	7.49	8.24	8.05	7.04	6.67	5.98	5.30	4.31	3.71		
	RadStd		0.23	0.31	0.26	0.25	0.17	0.35	0.28	0.19	0.26	0.26	0.19	0.15		

Historical Trends

		DBAvg		Heating		Cooling			Degree-Days					
				99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)		
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)		

Nomenclature: See separate page