

TORREON, Mexico

WMO: 763820

Lat: 25.5200N

Lon: 103.4161W

Elev: 3684

StdP: 12.84

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 39.2	(c) 42.6	(d) 15.9	(e) 14.0	(f) 71.0	(g) 20.2	(h) 17.3	(i) 68.5	(j) 22.8	(k) 66.7	(l) 18.9	(m) 67.3	(n) 2.4	(o) 340	(p) 0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 23.1	(c) 100.4	(d) 68.6	(e) 98.5	(f) 68.3	(g) 96.8	(h) 68.1	(i) 75.9	(j) 92.5	(k) 74.4	(l) 91.2	(m) 73.0	(n) 89.5	(o) 5.9	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.3	132.7	85.7	69.6	125.0	83.1	68.2	119.0	80.9	42.3	92.2	40.6	91.2	39.3	89.6	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 19.4	(b) 15.0	(c) 12.3	(e) 32.9	(f) 103.7	(g) 4.0	(h) 1.5	(i) 30.0	(j) 104.8	(k) 27.6	(l) 105.7	(m) 25.4	(n) 106.6	(o) 22.4	(p) 107.7		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			28.4	78.3	3.3	2.9	26.0	80.4	24.1	82.1	22.2	83.7	19.8	85.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.9	59.6	65.3	70.1	77.3	82.6	84.7	83.8	83.2	79.4	74.2	66.4	59.9
	DBStd	10.42	6.56	6.69	6.45	5.36	4.51	3.52	2.96	3.26	3.84	5.15	6.00	7.19
	HDD50	21	7	1	0	0	0	0	0	0	0	0	1	12
	HDD65	542	191	74	30	2	0	0	0	0	0	6	54	185
	CDD50	8745	304	428	623	820	1010	1040	1047	1029	881	750	493	320
	CDD65	3792	23	81	188	372	545	590	582	564	431	291	97	28
	CDH74	45449	334	945	2104	4501	7239	7875	7299	6863	4374	2673	914	328
	CDH80	22678	60	284	816	2259	4125	4478	3885	3523	1960	1009	231	48
(14) Wind	WSAvg	4.2	3.3	4.1	4.7	5.1	4.8	5.1	5.1	4.7	3.9	3.5	3.3	3.3
(15) Precipitation	PrecAvg	9.8	0.4	0.2	0.3	0.2	0.7	1.1	1.9	1.5	2.0	0.7	0.4	0.2
	PrecMax	20.2	2.2	2.7	3.7	0.8	3.2	3.6	6.9	6.6	5.3	2.3	2.6	2.2
	PrecMin	4.3	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.0	0.1	0.0	0.0	0.0
	PrecStd	4.0	0.6	0.5	0.8	0.2	0.7	1.1	1.7	1.5	1.3	0.6	0.6	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.7	90.6	93.5	99.1	103.4	103.0	100.0	98.9	96.6	93.4	89.2	84.6
		MCWB	58.0	59.7	60.2	64.2	67.2	69.3	70.6	71.0	69.0	68.2	63.1	58.7
	2%	DB	80.9	86.4	90.5	96.6	100.4	100.5	97.4	96.9	93.6	91.0	85.6	80.9
		MCWB	57.4	58.8	60.1	63.0	67.6	69.2	70.2	70.1	68.8	67.0	62.2	58.8
	5%	DB	77.4	83.8	87.9	94.0	98.3	98.5	96.1	95.1	91.7	88.2	82.6	78.4
		MCWB	56.0	58.0	59.2	62.3	66.5	68.9	69.8	69.7	68.9	65.9	62.2	57.6
	10%	DB	73.8	80.3	84.7	91.5	95.4	96.4	94.6	93.3	89.7	86.1	79.6	74.9
		MCWB	54.5	57.1	58.4	61.8	65.7	68.7	69.2	69.2	68.5	65.3	60.7	56.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.8	66.2	66.6	71.2	75.7	78.3	77.0	77.6	76.1	73.3	69.7	64.8
		MCDB	78.4	82.9	85.5	91.3	97.1	95.2	93.9	92.3	89.5	87.4	82.7	77.8
	2%	WB	59.6	62.6	63.7	68.3	72.9	75.4	74.4	75.5	74.0	71.0	66.5	62.0
		MCDB	75.4	79.3	83.2	87.8	93.8	93.4	92.3	91.1	87.5	85.1	79.0	75.0
	5%	WB	57.7	60.6	62.1	66.3	71.0	73.6	72.8	73.8	72.2	69.4	64.4	59.7
		MCDB	72.7	77.7	81.0	86.1	91.3	91.9	90.6	89.0	85.0	82.9	78.0	73.3
	10%	WB	55.8	58.7	60.4	64.4	69.1	71.9	71.5	72.2	70.8	68.0	62.6	57.6
		MCDB	70.6	75.3	79.2	84.4	88.4	89.5	88.7	86.6	83.2	81.2	75.7	70.9
(35) Mean Daily Temperature Range	MDBR		25.9	27.0	26.9	27.3	26.2	23.1	21.7	20.9	20.2	22.7	24.8	25.0
	5% DB	MCDBR	30.2	30.4	30.0	29.6	28.1	25.5	23.0	22.4	23.0	24.9	27.5	28.8
		MCWBR	16.5	14.9	13.8	13.0	13.1	12.5	11.1	10.9	10.8	11.9	14.6	16.0
	5% WB	MCDBR	27.2	27.6	27.6	27.6	26.1	23.1	21.8	20.8	20.4	22.3	25.1	25.6
		MCWBR	16.6	15.6	14.5	14.1	13.8	12.0	10.8	11.2	10.2	11.6	14.8	16.0
(40) Clear-Sky Solar Irradiance	taub		0.266	0.271	0.281	0.320	0.373	0.369	0.384	0.366	0.369	0.311	0.281	0.267
	taud		2.653	2.579	2.537	2.411	2.295	2.395	2.384	2.443	2.425	2.599	2.635	2.648
	Ebn at Noon		320	324	323	310	291	290	286	292	290	305	312	315
	Edh at Noon		25	30	32	38	43	38	39	36	36	29	26	25
(44) All-Sky Solar Radiation	RadAvg		1351	1671	2027	2299	2416	2358	2208	2131	1829	1727	1465	1273
	RadStd		97	129	102	134	77	128	115	98	108	97	96	78

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page